
NIT Enquiry letter No.: Mech/SE-I/25/18/2748 dated 12.10.2018

Present: Kolkata Port Trust Officials:

- 1. Sri S. Sarkar Executive Engineer (Elect)
- 2. Sri N. Behera Executive Engineer (Elect)

Firm Representative

1. Sri S. Roy Chowdhury - M/s Modern Software Systems Pvt. Ltd.

The site was shown to the representative of the prospective bidder. The matter of installation of Boards was discussed and following is to be read in conjunction with SI. No. 5 of BOQ:

 For installation of 2 nos. LED Sign Board are to be installed at Rabindra Setu (both ends), 4 Core, 10 sq.mm. Aluminium armoured Cable of 150 meter (approx) and 2 nos. 32 Amp, 10 KA, DP, MCB / 32 Amp. DP Main switch along with sheet steel enclosure are to be considered in BOQ SI. No. 5, in the NIT document. Price quoted against SI. No. 5 should include supply and installation of the above mentioned items and no additional payment will be made in this regard.

All other terms and conditions of the NIT remain unchanged. This minute is to be considered as a part of the NIT.

CHIEF MECHANICAL ENGINEER