

## **CORRIGENDUM**

**Ref: E-Tender No. KoPT/Haldia Dock Complex/P&E Div/15/18-19/ET/288 for design, supply, delivery, installation, testing & commissioning of 01(one) Set Submersible Slurry Pump with agitator to Haldia Dock Complex, Kolkata Port Trust.**

<b>Page &amp; Clause reference</b>	<b>In place of</b>	<b>To be modified as</b>
SCOPE OF WORK & TECHNICAL SPECIFICATION Page no.28, Clause no. 1. (e)	Duel Volute Suction type	Open Single Suction
SCOPE OF WORK & TECHNICAL SPECIFICATION Page no.28, Clause no. 1. (f)	Pump must have an integral Agitator	Pump must have an integral Inducer/Agitator
SCOPE OF WORK & TECHNICAL SPECIFICATION Page no.28, Clause no. 1. (g)	Horizontal Pumping distance -700 Mtrs.	Horizontal Pumping distance -250 Mtrs.
SCOPE OF WORK & TECHNICAL SPECIFICATION Page no.28, Clause no. 1. (h)	As per IS 325-1996 with it's latest amendment, if any.	Deleted
SCOPE OF WORK & TECHNICAL SPECIFICATION Page no.29, Clause no. 4	Shaft– Material of Construction – Stainless Steel Grade –SS 316  Fastener & lock nut – Material of Construction – Stainless Steel Grade –SS 316  Shaft Sleeve - Material of Construction – Hardenable Stainless Steel  Inducer - Material of Construction – Hardenable Stainless Steel  Agitator - Material of Construction – Stainless Steel Grade –SS 316	Shaft – Material of Construction – Stainless Steel, Grade –S29-431  Fastener & lock nut – Material of Construction – Stainless Steel, Grade –SS 304  Shaft Sleeve - Material of Construction – Hardenable Stainless Steel, Grade 17.4 ph(FV520B)  Inducer/Agitator - Material of Construction – Hardenable Stainless Steel, Grade 17.4 ph(FV520B)  Deleted
SCOPE OF WORK & TECHNICAL SPECIFICATION Page no.29, Clause no. 5	Automatic Control Panel(IP-68 ratings)  Voltmeter	Automatic Control Panel(IP-65 ratings)  Deleted, however, suitable space may be kept in the panel for providing Voltmeter
SCOPE OF WORK & TECHNICAL SPECIFICATION Page no.29, Clause no. 8	Test at Manufacturers Work – Routine test as per IS	Test at Manufacturers Work – Pump Shaft Speed Test & Vibration Test at no load

All other terms & conditions and clauses will remain same as per original tender document.

**General Manager (Engineering)**  
**Haldia Dock Complex**  
**Kolkata Port Trust**