



KOLKATA PORT TRUST
MECHANICAL & ELECTRICAL ENGINEERING DEPARTMENT
8, Garden Reach Road, Kolkata- 700 043

Dated: 02nd July, 2019

Corrigendum-1

Sub: “Procurement, Supply, Installation & Commissioning of Emergency Self Generating Mobile Tower Lights at KPD & NSD, KoPT.”

Ref: Notice Inviting Tender No.: KoPT/KDS/Mech/SE-I/ ADV/528 dated 13.06.2019

Reference	As Published	Should be read as
Page 34, Sl. No. 2 of BOQ	Supply of 300W (min) non-integrated LED Flood light Luminaries with secondary optics in epoxy powder coated pressure die-cast aluminum housing with IP66 protection, including suitable potted driver as having technical spec. as follows: i. System Lumen: 31500 min ii. System Luminous Efficacy>105 lm/W. iii. Colour Temp.: 5700K (Approx.) iv. Operating Voltage Range: 140-300 V AC. v. Potted Driver Details: Nominal Current 1.300A at 240V AC, PF>=0.95 & THD<=10%. vi. Surge Voltage protection upto 10kV with SPD. All other spec will be as per Technical Specification.	Supply of 300W (min) integrated LED Flood light Luminaries with secondary optics in epoxy powder coated pressure die-cast aluminum housing with IP66 protection, including suitable potted driver as having technical spec. as follows: i. System Lumen: 31500 min ii. System Luminous Efficacy >105 lm/W. iii. Colour Temp.: 5700K (Approx.) iv. Operating Voltage Range: 140-300 V AC. v. Potted Driver Details: Nominal Current 1.300A at 240V AC, PF>=0.95 & THD<=10%. vi. Surge Voltage protection upto 10kV with SPD. All other spec will be as per Technical Specification.

This CORRIGENDUM -I shall be read in conjunction with the Bidding Document (including Notice Inviting Tender).

All other terms and conditions of the NIT will remain the same.

CHIEF MECHANICAL ENGINEER