# **ADDENDUM**



## **KOLKATA PORT TRUST**

### HALDIA DOCK COMPLEX

E-Tender No. KoPT/Haldia Dock Complex/P&E Div/5/17-18/ET/59

for

Dismantling & shifting of one no. defective 6 MVA, 33 KV / 3.3 KV, 3 Phase Transformer from its present location at Ore & Coal Handling Plant, at HDC, KoPT and Design/manufacture, supply, delivery, installation, testing & commissioning of one no. new 6 MVA, 33 KV / 3.3 KV, 3 Phase, 50 Hz, Outdoor Type Transformer, along with all accessories, at Coal Handling Plant, under Haldia Dock Complex, Kolkata Port Trust, at Haldia.

☆ ADDENDUM-I ☆

#### [CORRECTIONS / ADDITIONS / DELETIONS, ETC.]

[Total Number of Pages: This cover page and page 1]

#### NOTE:

- 1) This "Addendum-I" should be read in conjunction with the **Tender Documents** (including e-Tender Notice).
- 2) Consequential changes, arising out of this "Addendum-I", will be deemed to have been effected, even if the same were not incorporated specifically in the Bidding Documents.
- 3) All other terms and conditions of the **Tender Documents** (including e-Tender Notice) will remain unchanged.

## Kolkata Port Trust <u>Haldia Dock Complex</u>

E-tender no. KoPT/Haldia Complex/P&E Div/5/17-18/ET/59 Dock

SI. No.	Reference / Clause No.	Line / para No.	As specified in the Bidding Documents	To be Read As:-
1.	ANNEXURE-IV / Scope of Work / SI. No. 4.2 .7		4.2.7 The new 6 MVA transformer should be supplied with first fill of new transformer oil. The transformer oil should conform to relevant IS specification (IS: 325 or latest amendments if any).	<b>4.2.7</b> The new 6 MVA transformer should be supplied with first fill of new transformer oil. The transformer oil should conform to relevant IS specification (IS: 335 or latest amendments if any).
2.	Annexure –TS (new)/ SL No. i)		<ul> <li>i) Tapping: Tappings on 33 KV side to vary by ± 2.5, ± 5% &amp; ± 7.5% by On Load Tap Changer.</li> </ul>	

Note: All other contents of the Tender Document will remain same.