Minutes of site inspection followed by Pre-bid Meeting held on 20.11.2017 at 11.00 hours for the work for "Electrical Installation Work for development and up gradation of 2 KPD & 11 KPD sheds in connection with Central Sector Scheme for Coastal Cargo"

N.I.T No. KoPT/KDS/Mech/SE-I/ADV/458 dt. 13.11.2017 E-Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410

Present:

Kolkata Port Trust Officials

- 1. Sri S. K. Das Superintending Engineer (Elect-I)
- 2. Sri S. Sarkar Executive Engineer (Elect)

Firm Representatives

- 1. Sri Tarkar Dey
- M/s. H.S. Enterprise
- 2. Sri Subhash Singh
- M/s. Subhas Electric Works

The existing Electrical installation of 2 KPD and 11 KPD were shown to the prospective bidders and the work to be carried out there was explained to them. Various points were raised by participating bidders and following clarifications relating to work are as furnished below:

- 1. In BOQ Sl. NO. 4 it was mentioned as "Supply & Delivery of Add-on indoor type L.T. Panel of protection IP-54 with technical details as mentioned in technical specification Sl No 3(B)". The Add-on Panel is to be supplied as per Technical Specification Sl. No. 3A instead of Sl. No. 3(B).
- 2. Quantity of BOQ Sl. NO. 5 (Supply & Delivery of Add-on L.T. Panel indoor type of protection IP-54 fabricated and with technical details as mentioned in technical specification Sl No. 3B) will be 01 nos. instead of 02 nos.
- 3. In BOQ Sl. No. 41 it was mentioned as "Supply and delivery of Joint Box of suitable size for interconnection of old PILC Cable with new XLPE Cable with necessary sealing arrangement for PILC Cable". Cost of installation charges is to be considered with the same item.

All other trams and conditions of the NIT remain unchanged. This minute is to be considered as a part of the NIT.

(S. K. Das)

Superintending Engineer (Elect-I)

(S. Sarkar)
Exe. Engineer (Elect-I)

(Subhash Singh)

M/s. Subhash Electric Works

(Tarak Dey)

M/s. H.S. Enterprise