



# KOLKATA PORT TRUST

KOLKATA DOCK SYSTEM  
MECHANICAL & ELECTRICAL ENGINEERING DEPARTMENT  
8, Garden Reach Road, Kolkata – 700 043

---

## **TENDER DOCUMENT**

for

Work : “Electrical Installation Work for development and up gradation of 2 KPD & 11 KPD sheds in connection with Central Sector Scheme for Coastal Cargo.”

Notice Inviting Tender No.: KoPT/KDS/Mech/SE-I/ADV/458 dated 13.11.2017

E- Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410

- Site inspection followed by pre bid meeting : 20. 11.2017 at 11.00 hrs.
- Start date of submission of e-tender : 24.11.2017 from 12.00 Hrs
- Closing date for e- Tender : 15.12.2017 up to 14.30 hrs.
- Date of opening of Techno commercial bid : 15.12.2017 at 15.00 hrs.

Tender Fee: 3,000/- (Non-Refundable)

Chief Mechanical Engineer

## **TENDER DOCUMENT**

### **KOLKATA PORT TRUST KOLKATA DOCK SYSTEM**

**e-TENDER FOR “Electrical Installation Work for development and up gradation of 2 KPD & 11 KPD sheds in connection with Central Sector Scheme for Coastal Cargo”.**

**NOTICE INVITING TENDER No. KoPT/KDS/Mech/SE-I/ADV/458 dated 13.11.2017**

#### **TENDER NOTICE:**

Mechanical & Electrical Engineering Department of Kolkata Port Trust invites E-Tender under single stage two part system (Part I: Techno-Commercial Bid and Part II: Price Bid) for **“Electrical Installation Work for development and up gradation of 2 KPD & 11 KPD sheds in connection with Central Sector Scheme for Coastal Cargo”.**

Bid Document may be downloaded from MSTC website [www.mstcecommerce.com/](http://www.mstcecommerce.com/) eprochome/kopt and KOPT website. [www.kolkataporttrust.gov.in](http://www.kolkataporttrust.gov.in) Corrigenda or clarifications, if any, shall be hosted on the above mentioned websites only.

#### **SCHEDULE OF TENDER (SOT)**

<b>Work Title</b>	<b>“Electrical Installation Work for development and up gradation of 2 KPD &amp; 11 KPD sheds in connection with Central Sector Scheme for Coastal Cargo.”</b>
<b>Tender Inviting Authority</b>	<b>Chief Mechanical Engineer.</b>
<b>TENDER NO.</b>	<b>KoPT/KDS/Mech/SE-I/ADV /458 Dated 13.11.2017</b>
<b>MODE OF TENDER</b>	e-Procurement System (Online Part I - Techno-Commercial Bid and Part II - Price Bid through <a href="http://www.mstcecommerce.com/">www.mstcecommerce.com/</a> eprochome/kopt of MSTC Ltd. The intending bidders are required to submit their offer electronically through e-tendering portal. <b>No physical tender is acceptable by Kolkata Dock System.</b>
<b>E-Tender No.</b>	KoPT/Kolkata Dock System/CME/26/17-18/ET/410
<b>Estimated Value of Work</b>	<b>Rs. 86,96,663/-</b>
<b>Date of NIT available to parties to download</b>	06.09.2017 at 14:00 hrs.
<b>Date and time of Pre-Bid Meeting and site inspection</b>	11.09.2017 at 11:00 hrs.
<b>i) Earnest Money Deposit</b>	The intending bidders should submit Earnest Money of <b>Rs 1,73,934/- (Rupees One Lakh Seventy Three Thousand Nine Hundred &amp; Thirty Four only)</b> to KoPT in the form of Demand Draft/Banker's Cheque/Pay Order from any of the

<p><b>ii) Cost of Tender document</b></p> <p><b>iii) Transaction Fee</b></p>	<p>Nationalized/Scheduled Banks in India having branch in Kolkata drawn in favour of <b>“Kolkata Port Trust.”</b></p> <p><b>“Cost of Tender document”</b> containing Banker’s cheque or Pay Order or Demand Draft from any of the Nationalized/Scheduled Banks in India having branch in Kolkata drawn in favour of <b>“Kolkata Port Trust”</b> of Rs.3,000/- (Rupees Three Thousand only) as the cost towards purchase of tender document (applicable for downloaded NIT only) or Treasury Receipt of the deposit issued by the Treasurer, Kolkata Port Trust, as the case may be. <b>All Banker’s cheques/Pay Orders/Demand Drafts should be drawn in favour of “Kolkata Port Trust” on any nationalized/Scheduled bank having branch in Kolkata.</b></p> <p><b>Rs.5132/-</b> [(service charge = 0.05% on estimate value) plus GST @18% on Service Charge] Payment of Transaction fee by NEFT/RTGS in favour of MSTC LIMITED (refer clause. No. 4 of Annexure -A )</p>
<p>Last date of submission of Tender Document Fee and Earnest Money</p> <p><b>Last date of submission of Transaction fee through RTGS/NEFT in favour of MSTC Limited, Kolkata.</b></p>	<p><b>15.12.2017 up to 14.00 hrs.</b></p> <p><i><u>Three working days before the last date of closing of online bidding for the e-tender.</u></i></p>
<p><b>Date of Starting of e-Tender for submission of on line (Techno-Commercial Bid and price Bid) at</b> <b><a href="http://www.mstcecommerce.com/eprochome/kopt">www.mstcecommerce.com/eprochome/kopt</a></b></p>	<p><b>24.11.2017 at 12:00 hrs.</b></p>
<p><b>Date of closing of online e-tender for submission of Techno-Commercial Bid &amp; Price Bid.</b></p>	<p><b>15.12.2017 at 14:30 hrs.</b></p>
<p>Date and time of opening of Part-I (i.e. Techno-commercial Bid after confirmation of submission of Tender Document Fee and Earnest Money Deposit).</p>	<p><b>15.12.2017 at 15:00 hrs.</b></p>
<p>Date and time of opening of Price Bid (Part-II). Bidders shall be informed separately.</p>	<p><b>To be informed separately.</b></p>

**List of Annexure**

**E-Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

Instruction to Tenderers	Annexure – A	Page : 5 - 9
Terms and Conditions of Tender	Annexure – B	Page :10 - 14
Special Conditions of Contract	Annexure – C	Page : 15 - 23
Scope of Work and Technical Specification	Annexure – D	Page : 24 - 33
Bill of Quantity	Annexure - E	Page : 34 - 45
Profile of Tenderer, Covering letter & Schedule “O”	Annexure – F	Page : 46 - 52
Affidavit for ESI	Annexure – G	Page : 53
Indemnity bond for ESI	Annexure – H	Page : 54
Declaration format	Annexure – I	Page : 55
General Conditions of Contract, Forms and Agreement	Annexure – J	Page : 56 – 79

**Instructions to Tenderers****Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

**This is an e-procurement event of Kolkata Port Trust. The e-procurement service provider is MSTC Ltd., 225C, A.J.C. Bose Road, Kolkata-700 020.**

You are requested to read the terms & conditions of this tender before submitting your online tender. Tenderers who do not comply with the conditions with documentary proof (wherever required) will not qualify in the Tender for opening of price bid.

1.	<p><b>Process of E-tender :</b></p> <p><b>A) Registration:</b> The process involves vendor's registration with MSTC e-procurement portal which is free of cost. Only after registration, the vendor(s) can submit his/their bids electronically. Electronic Bidding for submission of Techno-Commercial Bid as well as Price Bid over the internet will be done. The Vendor should possess Class III signing type digital certificate. Vendors are to make their own arrangement for bidding from a P.C. connected with Internet. MSTC is not responsible for making such arrangement. (Bids will not be recorded without Digital Signature).</p> <p><b>SPECIAL NOTE: THE PRICE BID AND THE COMMERCIAL BID HAS TO BE SUBMITTED ON-LINE AT <a href="http://www.mstcecommerce.com/eprochome/kopt">www.mstcecommerce.com/eprochome/kopt</a></b></p> <p>1). Vendors are required to register themselves online with <a href="http://www.mstcecommerce.com">www.mstcecommerce.com</a>→ e-Procurement →Psu/Govt depts→Register as Vendor under KOPT-- Filling up details and creating own user id and password→ Submit.</p> <p>2). Vendors will receive a system generated mail confirming their registration in their email which has been provided during filling the registration form.</p> <p><b>In case of any clarification, please contact KOPT/MSTC, (before the scheduled time of the e-tender).</b></p> <p><b>Contact person (KOPT):</b></p> <table border="0"> <tr> <td>1. Mr. Sanjib Sarkar Executive Engineer (Elect)) Mobile No. 9674720094 Email:<a href="mailto:sanjib@kolkataporttrust.gov.in">sanjib@kolkataporttrust.gov.in</a></td> <td>2. Mr. Santanu Kr. Das Superintending Engineer (Elect) Mobile No. 9674720037 Email: <a href="mailto:santanudas@kolkataporttrust.gov.in">santanudas@kolkataporttrust.gov.in</a></td> </tr> </table> <p><b>Contact person (MSTC Ltd):</b></p> <table border="0"> <tr> <td>1. Mr. Arindam Bhattacharjee Deputy. Manager (E-commerce) MobileNo:09330102643 Email-arindam@mstcindia.co.in.</td> <td>2. Mr. Sabyasachi Mukherjee Junior Manager (E-commerce) Mobile- 07278030407 Email: <a href="mailto:smukherjee@mstcindia.co.in">smukherjee@mstcindia.co.in</a>.</td> </tr> </table> <p><b>Landline:03322901004</b></p> <p>1. Ms Sumona Maity Management Trainee(E-Commerce) Mobile-09831155225</p>	1. Mr. Sanjib Sarkar Executive Engineer (Elect)) Mobile No. 9674720094 Email: <a href="mailto:sanjib@kolkataporttrust.gov.in">sanjib@kolkataporttrust.gov.in</a>	2. Mr. Santanu Kr. Das Superintending Engineer (Elect) Mobile No. 9674720037 Email: <a href="mailto:santanudas@kolkataporttrust.gov.in">santanudas@kolkataporttrust.gov.in</a>	1. Mr. Arindam Bhattacharjee Deputy. Manager (E-commerce) MobileNo:09330102643 Email-arindam@mstcindia.co.in.	2. Mr. Sabyasachi Mukherjee Junior Manager (E-commerce) Mobile- 07278030407 Email: <a href="mailto:smukherjee@mstcindia.co.in">smukherjee@mstcindia.co.in</a> .
1. Mr. Sanjib Sarkar Executive Engineer (Elect)) Mobile No. 9674720094 Email: <a href="mailto:sanjib@kolkataporttrust.gov.in">sanjib@kolkataporttrust.gov.in</a>	2. Mr. Santanu Kr. Das Superintending Engineer (Elect) Mobile No. 9674720037 Email: <a href="mailto:santanudas@kolkataporttrust.gov.in">santanudas@kolkataporttrust.gov.in</a>				
1. Mr. Arindam Bhattacharjee Deputy. Manager (E-commerce) MobileNo:09330102643 Email-arindam@mstcindia.co.in.	2. Mr. Sabyasachi Mukherjee Junior Manager (E-commerce) Mobile- 07278030407 Email: <a href="mailto:smukherjee@mstcindia.co.in">smukherjee@mstcindia.co.in</a> .				

	<p><a href="mailto:Email-smaity@mstcindia.co.in">Email-smaity@mstcindia.co.in</a>.  <b>Google hangout ID – (for text chat) – mstceproc@gmail.com</b></p> <p>B) System Requirement:</p> <ol style="list-style-type: none"> <li>Windows 7 or above Operating System</li> <li>IE-7 and above Internet browser.</li> <li>Signing type digital signature.</li> <li>Latest updated JRE 8 (x86 offline) software to be downloaded and installed in the system.</li> </ol> <p>To disable “Protected Mode” for DSC to appear in The signer box following settings may be applied.</p> <ul style="list-style-type: none"> <li>Tools =&gt; Internet Options =&gt;Security =&gt; Disable protected Mode. If enabled-i.e. Remove the tick from the tick box mentioning “Enable Protected Mode”.</li> <li>Other Settings :</li> </ul> <p>Tools=&gt;Internet Options =&gt;General =&gt;Click On Settings under “browsing history/Delete Browsing History” =&gt;Temporary Internet Files =&gt;Activate “Every time I Visit the Webpage”.</p> <p>To enable ALL active X controls and disable ‘use pop up blocker’ under Tools→Internet Options→custom level (Please run IE settings from the page <a href="http://www.mstcecommerce.com">www.mstcecommerce.com</a> once).</p>
2.	<p>The Techno-commercial Bid and the Price Bid shall have to be submitted online at <a href="http://www.mstcecommerce.com/eprochome/kopt">www.mstcecommerce.com/eprochome/kopt</a></p> <p>(A). Part – I (Techno-Commercial bid) : Would be opened electronically on specified date and time as given in the NIT. Bidder(s) can witness the opening of Techno-commercial Bid electronically.</p> <p>(B) Part – II (Price bid) : Would be opened electronically of only those bidder(s) whose Part – I Techno-Commercial bid are acceptable by KoPT. Such bidder(s) will be intimated the date of opening of Part II (Price bid) through valid e-mail confirmed by them.</p> <p>The tenderers are advised to offer their best possible rates. There would generally be no negotiations. Bidders are requested to submit their most competitive prices while submitting the price bid.</p>
3.	<p>All entries in the tender should be entered in online Technical &amp; Commercial Formats without any ambiguity.</p>
4.	<p><b>Special Note towards Transaction fee:</b></p> <p>“The vendors shall pay the transaction fee using “Transaction Fee Payment” Link under “My Menu” in the vendor login. The vendors have to select the particular tender from the event dropdown box. The vendor shall have the facility of making the payment either through <b>NEFT or Online payment</b>. On selecting NEFT, the vendor shall generate a challan by filling-up a form. The vendor shall remit the transaction fee amount as per the details printed on the challan without making change in the same. On selecting Online payment, the vendor shall have the provision of making payment using its Credit / Debit Card / Net Banking. Once the payment gets credited to MSTC’s designated Bank Account, the transaction fee shall be auto authorized and the vendor shall be receiving a system generated mail”</p> <p><b>Transaction fee is non-refundable</b> - The vendor will not have the access to online e-tender without making the payment towards transaction fee.</p> <p><b>NOTE :-</b> The bidders are advised to remit the transaction fee well in advance before the closing time of the event so as to give themselves sufficient time to submit the bid.</p>

	<p><b>Contact Details :</b></p> <p>Fax No. : 033- 22831002.</p> <p>Email ids: sanjibpoddar@mstcindia.co.in, arindam@mstcindia.co.in, rpradhan@mstcindia.co.in, smukherjee@mstcindia.co.in.</p> <p>Bidders may please note that the transaction fee should be deposited by debiting the A/C of the bidder only; transaction fee deposited from or by debiting any other party's a/c will not be accepted. Transaction fee is nonrefundable.</p> <p>In case of failure to submit the payment towards Transaction fee for any reason, the vendor, in term, will not have the access to online e-tender.</p>
5.	<p>In case of failure to submit the payment towards cost of Tender Document and Earnest Money Deposit (EMD), the vender will not have the access to on line e-tender and no correspondence in this respect will be entertained and KoPT will not be responsible for any such lapses on this account. Bidder(s) are advised to make remittance of Tender Fee and EMD through separate Banker's Cheque or Pay Order or Demand Draft, well in advance and verify completion of transaction in respect of Tender Fee and EMD. Vendors are instructed to use <i>Upload Documents</i> link in "My menu" to upload documents in document library. Multiple documents can be uploaded. Maximum size of single document for upload is 5 MB. Once the documents are uploaded in the library, vendors can attach documents through "Attach Document" link against the particular tender. For further assistance please follow instructions of vendor guide.</p>
6.	<p>All notices. /corrigendum and correspondence to the bidder(s) shall be sent by email only during the process till finalization of tender by KOPT. Hence the bidders are required to ensure that their corporate email I.D. provided is valid and updated at the stage of registration of vendor with MSTC (i.e. Service Provider). Bidders are also requested to ensure validity of their DSC (Digital Signature Certificate).</p>
7	<p>E-tender cannot be accessed after the due date and time mentioned in NIT.</p>
8	<p><b>Bidding in e-tender:</b></p> <p>(a).Bidder(s) need to submit necessary Tender Document Fee, EMD and Transaction Fee for their eligibility to bid online in the e-tender. Tender Document Fee and Transaction fees are non refundable. No interest will be paid on EMD. EMD of the unsuccessful bidder(s) will be refunded by KOPT. In case of the successful tenderer, this amount may be adjusted against the Security Deposit.</p> <p>(b). <b>An amount of Rs 1,73,934/- for EMD and Rs.3,000/- for Tender Fee</b> has to be deposited by Demand Draft/Pay Order/ Banker's Cheque from any Scheduled/ Nationalized Bank in favour of "Kolkata Port Trust" payable at Kolkata to be submitted physically in the office of M&amp;E Eng. Dept.</p> <p>(c). If any tenderer withdraws his tender before 120 days from the date of opening of the Techno-commercial Bid of the tender, the Earnest Money Deposit will be forfeited by the Trustees.</p> <p>(d). Tender without the Earnest Money or depositing the Earnest Money in a manner other than what has been stipulated here-in-before or for an amount less than the specified amount would be considered as invalid tender and would be summarily rejected.</p>

- (e). NSIC registered firms under Single Point Registration scheme are exempted from depositing Tender Fee and Earnest Money. But all the NSIC registered firms are not exempted from depositing Tender Fee and Earnest Money. Only those firms, having documents of such exemption for the entire tendered work (as per the Bill of Quantity) would be exempted. Documentary evidence must be uploaded for claim of such exemption, failing which their tender would be summarily be rejected.
- (f). The process involves Electronic Bidding for submission of Tender Document Fee and EMD, Techno- Commercial Bid as well as Price Bid.
- g). The vendor (s) who have submitted transaction fee can only submit their Technical Bid and Commercial Bids through internet in MSTC website [www.mstcecommerce.com](http://www.mstcecommerce.com) → e-procurement →Psu/Govt depts→ Login under KOPT→My menu→ Auction Floor Manager→ live event →Selection of the live event.
- (h).The vendor should allow running JAVA Application. This exercise has to be done immediately after opening of Bid floor. Then they have to fill up Common terms/Commercial specification and save the same. After that clicking on the Technical Bid. If this application is not run then the vendor will not be able to save/submit his Technical bid.
- (i). After filling the Technical Bid, vendor should click ‘save’ for recording their Technical bid. Once the same is done, the commercial bid link becomes active and the same has to filled up and then vendor should click on “save” to record their commercial bid. Then once both the Technical bid & commercial bid has been saved, the vendor can click on the “Final Submission” button to register their bid. Vendors are instructed to use *Attach Doc Button* to upload documents. Multiple documents can be uploaded.
- (j). In all cases, bidder should use their own ID and Password along with Digital Signature at the time of submission of their bid.
- (k). During the entire e-tender process, the bidders will remain completely anonymous to one another and also to everybody else.
- (l). The e-tender floor shall remain open from the pre-announced date & time and for as much duration as mentioned above.
- (m). All electronic bids submitted during the e-tender process shall be legally binding on the bidder. Any bid will be considered as valid bid if it fulfills all the terms and conditions of the Tender Document.
- (n). It is mandatory that all the bids are submitted with digital signature certificate otherwise the same will not be accepted by the system.
- (o). KoPT reserves the right to cancel or reject or accept or withdraw or extend the tender in full or part as the case may be without assigning any reason thereof.
- (p). No deviation of the terms and conditions of the tender document is acceptable. Submission of



	<p>bid in the e-tender floor by any bidder confirms his acceptance of terms and conditions for the tender.</p> <p>(q). Unit of Measure (UOM) is indicated in the e-tender Floor. Rate to be quoted in Indian Rupee Currency as per UOM indicated in the e-tender floor/tender document.</p>
<b>9.</b>	The e-tender shall be governed by the terms and conditions mentioned therein.
<b>10.</b>	No deviation to the technical and commercial terms & conditions are allowed.
<b>11.</b>	KOPT has the right to cancel this e-tender or extend the due date of receipt of bid(s) without assigning any reason thereof.
<b>12.</b>	The online tender should be submitted strictly as per the terms and conditions and procedures laid down in the website <a href="http://www.mstcecommerce.com/eprochome/KoPT">www.mstcecommerce.com/eprochome/KoPT</a> of MSTC Ltd.
<b>13.</b>	The bidders <b><u>must upload</u></b> all the documents required as per Pre-qualification criteria and the documents enlisted under techno-commercial bid and Price-bid, failing which the tender shall lead to disqualification. Any other document uploaded which is not required as per the terms of the NIT shall not be considered.
<b>14.</b>	The bid will be evaluated based on the filled-in technical and commercial formats uploaded.
<b>15.</b>	The documents uploaded by bidder(s) will be scrutinized. In case any of the information furnished by the bidder is found to be false during scrutiny, EMD of defaulting bidder(s) will be forfeited. Punitive action including suspension and banning of business can also be taken against defaulting bidders.
<b>16.</b>	Bidders are requested to read the vendor guide and see the video in the page <a href="http://www.mstcecommerce.com/eprochome">www.mstcecommerce.com/eprochome</a> to familiarize them with the system before bidding.

=====

**Terms and Conditions of Tender**

**Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

**Pre-qualification Criteria of the Bidders**

The intending Tenderers shall satisfy the following conditions with supporting documents:

- i) The firms must have average annual financial turnover during the last three years ending 31st March, of the previous financial year of at least 30% of the estimated cost.
- ii) The firms must have either of the following as experience of having successfully completed similar works during last seven years, ending on last day of month, previous to the one in which applications are invited:
  - a) Three similar completed works costing not less than 40% of the estimated value.  
Or
  - b) Two similar completed works costing not less than 50% of the estimated value.  
Or
  - c) One similar completed works costing not less than 80% of the estimated value.

Here "similar works" means **"Supply, Installation, testing and commissioning of LT Panel, Pillar Box, Luminaries, including cable laying & allied works, circuit wiring , earthing.**

Work experience as a subcontractor or supply contractor shall not be considered as requisite qualification. The Tenderer shall have to upload documents (certified copy), viz. order letter and proof of execution to establish his credentials.

**OTHER INSTRUCTION:**

1. **Tender Fee and Earnest Money or NSIC Certificate, if applicable, are to be uploaded and must be physically submitted to the Chief Mechanical Engineer, Mechanical and Electrical Engineering Department, Kolkata Port Trust, 8, Garden Reach Road, Kolkata -700 043, failing which techno-commercial bid will not be opened. Details of which are as under -**
  - (a) Demand Draft/Pay Order/ Banker's Cheque from any Scheduled/ Nationalized Bank in original, for Rs.3,000/- (Rupees Three Thousand only) as cost of Tender Document.
  - (b) Demand Draft/Pay Order/ Banker's Cheque from any Scheduled/ Nationalized Bank in original, for Rs. 1,73,934/- (Rupees One Lakh Seventy Three Thousand Nine Hundred & Thirty Four only) as Earnest Money Deposit.
  - (c) NSIC Certificate in case of Micro and Small Enterprises (MSEs) registered with NSIC (under single point Registration Scheme) having valid certificate.

2. In addition to above as mentioned in Sl.No.1, following documents are to be **UPLOADED** :--
- (i) Last three years balance sheet and profit & loss account in support of Annual Financial turnover (i.e. 2013-14, 2014-15 and 2015-16), and the same should be audited as per relevant norms wherever required.
  - (ii) Self attested documentary evidence of successful completion of similar work as proof of fulfilling the Pre-qualification Criteria of the tender.
  - (iii) Copies of self attested valid GST Registration Certificate.
  - (iv) Copy of self attested ESI registration certificate, **OR** an affidavit before a first class judicial magistrate as per the format given in Annexure-G (in case the Tenderer is not covered under ESI Act or exempted from it). The tenderers, if not covered under ESI Act, shall, additionally, indemnify KoPT against all damages and accidents to his labourer in a non-judicial stamp paper as per the format given in Annexure-H. The contractors should declare and state in the averment in the Affidavit and in the indemnity bond that in case such declaration will be found wrong and false, they will be held responsible for all consequences in respect of compliance of The Employees State Insurance Act 1948.
  - (v) Certified copy of valid Trade License and Electrical Contractor's License.
  - (vi) Copy of self attested PAN Card of the firm / company issued from Income Tax Department.
  - (vii) Statement to confirm the status of the Tenderer – whether a Partnership Firm, Company or Proprietorship Firm. If demanded by KoPT, the tenderer would be bound to furnish necessary documents in support of their statement in this regard.
  - (viii) Copy of valid Professional Tax clearance / Uptodate Profession Tax Payment challans (if applicable) / else document in support of exemption.
  - (ix) Proof of being registered with Employees' State Insurance Corporation (ESIC), ESI Registration Certificate.
  - (x) Proof of possessing valid Employees' Provident Fund (EPF) Account/ PF Registration Certificate.
  - (xi) NSIC Certificate in case of Micro and Small Enterprises (MSEs) registered with NSIC (under single point Registration Scheme) having valid certificate.
  - (xii) A separate statement of the tenderer containing full name and office address of the Tenderer, names and designation of the officials of the Tenderer connected with the instant Tender, their land and mobile telephone nos., e-mail id and Fax No. etc. as per enclosed **Proforma (Form-D)**.
  - (xiii) Declaration of the tenderer in the form of a COVERING LETTER with certain undertaking and also that they or their associates have not been banned or delisted by any Govt. or Quasi-Govt. agencies or PSUs in India as per enclosed Proforma.

- (xiv) Details of the firm as per 'Schedule-O' of the tender document.
- (xv) A declaration has to be furnished by the tenderer stating (undertaking) that the entire tender document, GCC and addenda has fully been read and understood (Annexure -I).
4. All the document as mentioned here-in-before shall have to be UPLOADED failing which the related offer will be liable to be cancelled. The tenderer should clearly understand that no information/indication as to price should be entered in the page of "Bill of Quantities" or elsewhere in the Techno-commercial Bid. Indication of price anywhere in any manner in the Techno-commercial part of the tender would lead to rejection of the offer.
5. Please note that there is no provision to take-out the list of parties downloading the tender document from the website mentioned in NIT. As such bidders are requested to see the website once again before the due date of tender opening to ensure that they have not missed any CORRIGENDUM uploaded against the said tender after downloading the tender document. The responsibility of downloading the related CORRIGENDUM, if any, will be that of downloading parties.

**Tenderers may note that non-submission of any of the aforesaid documents/non-fulfillment of any of the aforesaid criteria shall lead to disqualification of their offers.** No alteration shall be made by the Tenderer in the tender and the tender must be in accordance with the specification. Non conformation to this instruction shall be treated as non responsive & hence may disqualify the tender.

6 Techno-commercial bids will be opened on the schedule date of opening of techno-commercial bid. Price Bids of only techno commercially qualified bidders shall be opened on a suitable date, to be intimated beforehand.

7. The Trustees reserve the right to accept or reject the tender without assigning any reason whatsoever.

8. The Trustees will not be responsible for any cost or expense incurred by the Tenderer in connection with preparation or submission of the tenders.

9. In case of unscheduled holiday, Strike/Bandh etc. on the scheduled date of Site Inspection, Pre-bid Meeting, submission of bids, opening of Techno-commercial or Price Bid, the same time (as per the schedule) on the next working day will be considered as scheduled time for the purpose of Site Inspection, Pre-bid meeting, submission of bids, opening of Techno-commercial or Price Bid, as the case may be. Here, Trustees' working day means Monday to Friday in between 9-30 hrs. to 17-30 hrs.

10. Should there be any doubt or ambiguity as to the meaning of any portion of the tender document or if any further information is required, the same shall be clarified/amended by KoPT in the Site Inspection and Pre-bid meeting. No excuse of ignorance in this regard shall be accepted at a later date after the Pre-bid meeting. In the event of making any important clarification or amendment of terms of the tender, pursuant to the discussion in the Pre-bid meeting, the same shall be immediately hoisted in KoPT's website for information of all concerned and the same shall form a part of the Tender Document. Any offer having deviation from KoPT's terms and conditions shall render such offer unacceptable to KoPT. No alteration shall be made by the Tenderer in the tender document and the offer must be in accordance with the terms and conditions of the tender. The prospective tenderers may inspect the site prior to the date of Site Inspection and Pre-bid meeting in order to make themselves fully aware of the work, site and scope of work as mentioned in the Bill of

Quantity as per tender. For attending the Pre-bid Meeting, the representatives of the tenderers should accompany proper authorizations letters from their respective organizations.

11. The quoted rate should be inclusive of all taxes duties and other charges except Service Tax. The rate quoted in the tender shall hold good and shall be binding on the tenderer notwithstanding any increase in the prices of the materials and labour or in the freights or levy or other charges whatsoever and the tenderers shall not be entitled to claim any increase over the rates quoted by them during the pendency of the contract.

12. **Validity of offer:** The quoted rates would be kept valid for **4 months** from the date of opening of the Techno-commercial Bid. If before expiry of this validity period, the Bidder amends his quoted rates or tender, making them unacceptable to the Trustees and / or withdraws his e-tender, the Earnest Money deposited shall to be forfeited.

13. The tenderers shall distinctly understand that they will be strictly required to conform to all the terms of the tender and the plea of custom prevailing will not in any case be accepted as an excuse on their part for infringing of any of the conditions and they shall refrain from sending revised or amended quotations, after the closing date and time of the tender.

**14. Evaluation criteria:**

(i) A fully priced bill of quantities duly totaled shall be submitted with the tender. A price shall be inserted against each item of the bill of quantities and these prices shall include all manner of labour, material plant tools and all other matters necessary for the execution of the contract in accordance with the General Conditions of Contract, specifications, drawing, if any, and bill of quantities.

(ii) If it is found on examination of a tender that there is a discrepancy between the total amount inserted in the bill of quantities and the amount arrived at by valuing the quantities set out therein with the rates and prices set against them, by the tenderer, calculation for the total amount will be made on the basis of Unit Rates multiplied by quantities. Evaluation of the tender will be done on the basis of the total price thus arrived excluding GST as applicable.

**The tenderer must not keep any column/space blank in any item under BOQ, else the tender is liable for disqualification.**

(iii) The price offer should be exclusive of GST and any statutory levies and or other charges levied by any central/state/local authorities. GST and any other extra charges/statutory levies will be paid extra at applicable rates at the time of supply of goods and services.

15. If excess work is required to be carried out in addition to the quantities stipulated in BOQ, the amount will be paid as per unit rate quoted in BOQ as per actual measurement. In case of extra work the same will be paid as per rate of PWD schedule rate/ rate of reputed manufacturer/market rate with justification of rates as the case may be.

16. The contract document shall be drawn in English language only.

17. The contract shall be governed by all relevant Indian Acts as applicable only within the jurisdiction of High Court of Kolkata, West Bengal, India including the Acts like The Indian Contract Act, The Major Port Trusts Act, The Workmen's Compensation Act, The Minimum Wages Act, The Contract Labour (Regulation & Abolition) Act, The Dock Worker's Act, The Indian Arbitration & Conciliation Act, The Dock Safety Regulations, Act(s) or any other act, law, rule as may be

applicable. Payment to the labourers to be made as per the minimum wage rate fixed by Chief Labour Commissioner (Central) and as per M.W.A. Govt. of W.B. whichever is higher and revision from time to time along with EPF /ESI and other statutory benefits, if applicable.

It will be the duty of the contractor to abide by the provisions of the Act, Ordinances, Rules, Regulations, Bey-laws and procedures as are lawfully necessary in the execution of the works. The contractor will be fully responsible for any delay / damages etc. and keep the Engineer indemnified against all penalties and liabilities of any kind of noncompliance or infringement of such Acts, Ordinances, Rules, Regulations, Bey-laws and procedures.

The aforesaid regulations shall be deemed to be a part of this contract and any breach thereof shall be deemed to be a Breach of Contract. It will be obligatory on the part of Contractor to obtain necessary Labour Licence from the Competent Authority for deploying requisite Nos. of labours in the work and submit the Engineer-In-Charge prior to commencement of the work.

The contractor shall also be required to comply regarding 'Workmen Compensation Act,1923 as amended by Amendment Act No. 65 of 1976' In addition to the above, the Personal Injuries (Compensation Insurance) Act,1963 and any modifications thereof and rules made there under from time to time. The contractor shall take into account all the above said financial liabilities in his quoted rates and nothing extra, whatsoever, shall be payable to him on this account.

**Special Conditions of Contract**

**E- Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

1. The Tenderer shall carefully examine the whole tender document and shall visit and inspect the site on his own, obtain all information, which may be necessary for the purpose of the tender/offer. The Tenderer is advised to acquaint himself with the job involved at the site, laws and bye-laws enforced by the Govt. and other statutory bodies. No excuse of ignorance as to site condition and local information will be accepted. All costs/charges/expenses that may be incurred by the Tenderer in connection with the preparation of his tender shall be borne by the Tenderer and KoPT accepts no liability in this regard.
2. Disclosure/indication of price in Techno-commercial part of the tender shall be liable to be disqualified.
3. Any quotation received for part supply or of doing a portion of the work with responsibility for carrying out remaining works by the Trustees, will not be considered.
5. No alteration shall be made by the Tenderer in the tender and the tender must be in accordance with the specification. Non conformation to this instruction shall be treated as non responsive & hence may disqualify the tender.
6. The contract shall be governed by the Indian Contract Act and all payments due to the Contractor under the Contract shall be made in India in Rupee Currency. No foreign exchange is payable on this contract.
7. The Contractor shall take adequate insurance cover for persons to be deployed for execution of this contract. The Contractor shall at his own expenses pay compensation for any injury, loss or reinstate and make good to the satisfaction of KoPT for loss or damage accrued to any property or rights of KoPT whatever, including KoPT's agents/ servants/ employees, or any third party arising out of or in any way in connection with the execution or purported execution of the contract and further the contractor shall indemnify KoPT against all claims enforceable against KoPT (or agents/servants/employees of KoPT) or which would be so enforceable against KoPT where KoPT is a private person, in respect of any such injury (including injury resulting to death), loss or damage to any person whomsoever or property including all claims which may arise under the Workmen's Compensation Act or otherwise.
8. Attention of the tenderer is drawn to clause no 3.4, 3.5, 3.6 of GCC regarding earnest money & security deposit and clause no.8 regarding delay/extension of time /LD / Termination of contract including GCC.
9. The tender shall remain valid for acceptance for a period of 120 days from the date of opening the Techno-commercial Bid. In the event of tenderer withdrawing their tender before the expiry of tender validity period of 120 days from the date of opening of the Techno-commercial Bid, the offer of such tenderer shall be cancelled and EMD deposited by them shall be forfeited. If tender process could not be finalized within 90 days, the EMD's to be revalidated accordingly.
10. Successful Tenderer shall be in all cases responsible for the execution of the work in accordance with the General Conditions of Contract. Specifications, Drawings if any, and the Bill of Quantities which the tenderer shall be deemed to have examined.

11. KoPT reserves the right to disqualify any offer, in case they are satisfied that any bribe/commission, gift or advantage has been given, promised or offered by or on behalf of any of the Tenderers to any officer, employee or representative of KoPT or any other person on his or their behalf in relation to the acceptance of this tender.

12. The Tenderer shall disclose the names of their Partners /Directors/ Members in the manner stipulated in this tender document. Any change in the composition of the same during subsequent stage of tender finalization as well as during the period of execution of the contract shall be immediately notified in writing to KoPT. In the event of any Tenderer failing to comply with the aforesaid requirement, the tender/ contract, if entered into, may be terminated.

13. At any time, prior to the last date of submission of Tenders, KoPT reserves the right to amend and modify the Tender Document. Such amendment shall be hoisted in MSTC's Portal as well as in KoPT's Portal and KoPT would in no way be responsible for any likely ignorance of any prospective Tenderer in this regard. Such amendment/ modification shall form part of the Tender and shall be binding upon all the Tenderers. KoPT may, at its discretion, alter any of the major dates like pre-bid meeting, last date of submission and date of opening of the Tender etc. to enable the Tenderer(s) to have reasonable time to submit their offer after taking into consideration such amendment / modification.

14. The Tenderer should note that the plea of custom prevailing will not in any case be admitted as an excuse on their part for infringing any of the conditions of the tender.

15. The Contract shall be governed by all the acts as listed under Clause No. 4.1 of the General Conditions of Contract and also by all other relevant Acts/Laws/ Regulations/Bye-laws/Statutory Requirements including Dock Safety Regulations as may be in vogue as well as any amendment thereof, if any, in executing the tender and during the pendency of the contract. It will be the sole responsibility of the Contractor to comply with the same.

16. While submitting tender, the conditions of tender, the general conditions of contract and specifications, drawings etc. shall be read in conjunction with the bill of quantities.

**17. Completion time: Thirty Two (32) weeks from the date of placement of order letter.**

18. The tenderer/s shall not rely merely on the descriptions given on the bill of quantities. The quantities shown on the bill of quantities are approximate only and the actual quantities will be intimated when formal order will be placed. If when preparing the tender documents, the tenderer feels that any essential item has been omitted from the bill of quantities the prices of which cannot be conveniently included under any other item, the tenderer shall request the Engineer to insert a suitable item at the time of Pre-bid meeting. Should the tenderer omit to mention the price of any item in the bill of quantities, the tender may be treated as cancelled.

**19. The tenderer/s shall distinctly understand:-**

- a. that they will be strictly required to conform to the General Conditions of Contract and Specification as contained in each of its clause;
- b. Non-acceptance/or non-compliance of any of the above terms and conditions may render the tenders liable to rejection.

Tenderer/s shall also sign every page of the tender documents in token acceptance thereof.

**20. Warranty/Defect Liability Period:** The contractor shall make good at his own expenses of all defects, due to faulty design, materials and workmanship, which may develop under proper use during a period of 12 months from the date of commissioning / handing over of the



work. Should any difference of opinion arise on any of the provisions of this clause, the decision of the Engineer shall be final and binding. In default, the Trustees will be at liberty to get the repairs done and reimbursed themselves so far as costs therefore are concerned out of the amount lying with them as security deposit so far as that is practicable. If the costs of such repairs exceeding the amount of security deposit, the Contractor shall pay the balance to the Trustees forthwith on demand. Where the Contractor has submitted bank guarantee in lieu of cash security money, the cost of such repairs will be payable to the Trustees forthwith on demand.

21. **Safety:** The Contractor shall take adequate safety precautions for prevention of accidents at site. The Contractor shall ensure that his employees observe the statutory safety rules and regulations

22. **Entry Permit:** The Contractor shall be governed by the following provisions for interfacing safety custody and proper use of Dock Permits :

- a. **All** representatives and workers of the contractor shall possess the Dock Permit issued by Dock Permit Office at the recommendation of concerned officer/Engineer on monthly or daily basis, free of cost. A token charge of Rs. 7.00 per person per occasion will be levied for creation of new IDs in the permit system. A separate receipt indicating the details of the ID along with the amount charged will be issued which may be kept for future reference.
- b. **The** Contractor shall ensure that any Dock Permit issued to their workmen or representative by the Permit Office are not misused by unauthorised persons for entry into the protected dock area.
- c. **It** shall amount to breach of rules and regulations regarding entry into the prohibited area by the Contractor in case the Dock Permit issued at their request are found to be misused by any authority/person.
- d. **The** Contractor and their defaulting employees shall be liable for legal action against them for breach of rules regarding entry into the protected area.

23. **Permission from statutory bodies:** The Contractor shall make arrangement from his own cost for obtaining permission and relevant clearance from the statutory bodies such as Municipal Corporation, Electricity Authorities etc. on payment of necessary charges/fees etc. by the bidder.

24. **Drawings:** On completion of all work, the Contractor shall furnish the “DIAZO” and three copies of all “As made” drawings including cable route diagram to the Engineer without any cost.

25. **Testing and commissioning:** Before each test, the Contractor shall obtain permission from the Engineer and all tests shall be conducted in presence of duly authorized representative and the Electrical Inspector wherever it is necessary. Record of each test shall be prepared after the test and this record shall be signed by the Contractor's representative conducting the test. Copies of those records in quadruplicate shall be submitted to the Engineer. A certificate in quadruplicate shall be furnished by the Contractor countersigned by his certified Supervisor under whose direct supervision the installation has been carried out. The Testing & Commissioning and its related charges are to be borne by the Contractor at his own cost.

26. **Identification mark:** For identification of various equipment letter/figure writing of sizes varying from 12 mm. to 75 mm. with enamel paint of approved shade /standard ferules are to be carried out at the expenses of the contractor as per directive of Engineer.

27. The tenderer must produce evidence with his tender that he and his proposed sub-contractors have had experience and fully capable of carrying out work of this class and magnitude and by way of proof shall submit along with his tender under Schedule ‘O’ a list of important works of a similar nature successfully carried out by him giving the dates of commencement and completion

of such works and full particulars of his business organization.

**28. Cleaning during execution and after completion :-**

**Any damage done to the structures during execution of work should be made good by the contractor at his own cost.** On completion of works, the contractor shall reinstate and make good at his own expense any property or land which might have been disturbed and/or damaged by his works. He should also clean the site as required during execution and fully clear the site after completion of all the works.

The contractor shall forward any usable material found during the course of construction at the work site or its vicinity to KoPT store/yard, dispose off the debris beyond the port area all at his own expenses by his own transport and labour and clean out all part of the work and leave everything clean and tidy to the entire satisfaction of the Engineer.

**29. Protection of existing service :**

The contractor must pay full attention to the fact that the existing service facilities for KoPT are not disturbed at any time due to storing of materials and rubbish and take every precaution to keep the entrance passage clear is the same are being used by the labourer. The contractor shall be held liable for all damage and inference to the existing service/structures caused by him in execution of works. Should any damage be done to the existing service/structures in general, the contractor shall make good the same and any further work considered necessary by the Engineer's representative without any delay otherwise the cost of such repairing shall be recovered from his running account bill for which Engineer's decision shall be final & binding.

**30. Forwarding of Materials**

All dismantled unserviceable materials are to be disposed off beyond the office compound and in conformity with the Municipal/corporation Rule at the contractor's own cost. The contractor shall have to arrange transport for forwarding the saleable/ unusable/ defective/ usable materials that may be found during the process of execution of the work to the Trustees sales yard or any other site/ Godown including labour, transportations, loading, unloading all complete as per the direction of the Engineer.

31. Kolkata Port Trust will issue necessary permits/ photo permits free of costs for all the personnel of the contractor or his sub-contractor who will be involved in the tendered work. On closure of the contract, all these permits shall have to be returned before finalization of the pending bills/dues.
32. The Contractor shall arrange all necessary tools, tackles, equipment, measuring & testing equipment etc. required for the repair & maintenance work at no extra cost to Kolkata Port Trust.
33. The contractor shall start the work on "As-is-where-is" basis of the electrical installations.
34. The Contractor shall arrange the services, if any, required from indigenous/ foreign companies at no extra cost to Kolkata Port Trust.
35. Kolkata Port Trust will provide general security of the entire working area. Kolkata Port Trust is covered by ISPS (International Ship and Port Facilities Security) code and the contractor shall have to arrange for further security of their stock etc., if considered necessary and related coverage at his cost in terms of ISPS code.
36. The stores/equipment/plant/machineries shall strictly conform to the tender specifications and shall be capable of satisfactorily performing the duties intended for in the specification.

37. Electricity will be provided free of cost from nearest available source for carrying out the works, if necessary. Water and Toilet facility, as available within the premises, shall be extended to the Contractor's men free of cost.
38. The contractor or his employees shall not use the premises allotted to him for any purpose other than for carrying out the work allotted as per the contract and shall not act in any manner as to cause any nuisance or annoyance to KoPT or the participants /visitors at the port. **The firm/contractor shall not allow or permit employees to participate in any trade union activities, organization in and around the premises of KoPT.**
39. The contractor shall have to arrange at his own cost for all necessary insurance coverage for men and materials to be used this contract.
40. Kolkata Port Trust and the contractor will nominate a number of officers with their contact nos. indicating the chain of command at the field level who will operate within the terms of the contract to ensure minimum interruption, smooth functioning and optimum utilization of the electrical installations and the related distribution system.
41. The contractor shall conform to all the formalities as laid down in the Contract Labour (Regulation and Abolition) Act, 1970 and rules framed there under in vogue and subsequent amendments, if any, while executing the contractual works.
42. The Contractor shall supply, bound into suitable folder two sets of operating and maintenance & fault finding manual for use by the Engineer with three sets of complete general lay out, assembly drawings and illustrated spare parts catalogue for the stores/ plant/ equipment/ item.
43. Security Deposit will be guided by clause. 3.4, 3.5 & 3.6 of the GCC, Forms & Agreement of the tender document.
44. **Dock Safety Regulations** shall be applicable for the work. All Dock Safety Regulations in vogue and as amended from time to time shall have to be satisfied.
45. Contractor shall have to arrange further security for their equipment/office/stores etc. at their own cost and responsibility.
46. All equipment covered under this tender must be available from indigenous sources and the tenderer/s shall confirm that spares will be available freely at least for a period of 5 years from the date of commissioning. No foreign exchange will be made available.
47. The tenderer/s shall submit manufacturers Test Certificates for all the bought-out items envisaged in the equipment.
48. An agreement shall have to be executed at the expense of the contractor within 15 days from the date of issuance of **Order letter** by successful tenderer on a non-judicial stamp paper of at least Rs. 60/- as per format enclosed with the General Conditions of Contract. All correspondence between the contractor and KoPT and all documents to be submitted from the date of opening of tender till the submission of the Security Deposit should form part of the contract agreement.
49. Very particular emphasis will be laid on the completion period of the contract. The Trustees would desire early completion of work. The tenderer should note that time will be essence of the contract.

50. For erection, if applicable, of the stores/ plant/ equipment/ machineries/ item, all connected work including grouting bolts, Base frame and Bed plate etc. shall be provided by tenderer. During erection all tools and tackles are to be provided by Tenderer. Tenderer should guard all equipments, etc. at site by his own men at his own cost. However, only space for keeping the materials for execution of the work may be provided by Kolkata Port Trust on free of cost basis.
51. The contract shall be drawn up in English language only.
52. The firm /contractor shall at all times, during the continuance of agreement, obey and observe all direction and instruction given by the Engineer or his authorized officials.
53. The contract may be terminated at one month's notice by KoPT if any one of the stipulated conditions agreed upon by the selected bidder is not met to the satisfaction of KoPT. Further, the contract shall stand terminated automatically after completion of the work.
54. The responsibility in respect of the antecedents / Credentials of the persons engaged by the contractor rest with the contractor.
55. Operation and maintenance of all electrical installation in accordance with Manufacture's specification, instruction Manuals, IE Rules and other relevant rules are to be carried out.
56. The staff provided by the contractor to KoPT are in case found to be indulging in any undesirable or unfair activities in the premises of KoPT, the contractor will solely be responsible for all the consequences apart from the liberty of KoPT office to lodge complaints before appropriate authorities.
57. All excisable goods for which supply rate has to be quoted, the contractor shall buy such items from the manufacturer or first stage dealer or second stage dealer and obtain Invoice of such items a/c '**KOLKATA PORT TRUST**' for the 'subject work'. Payment of all such items will be made on production of proper documents. Contractor, however, will be paid for supply items at his quoted rate and not on the basis of actual invoice value of the manufacturer or first stage dealer or second stage dealer. Any purchase for supply items from other sources, not specified will not be allowed for payment purpose.
58. The tenderer/s shall afford all facilities to the Engineer at their own arrangement for inspection and demonstration of the equipment, quoted for.
59. The tenderer shall along with the tender submit the detailed description of the equipment quoted for and enumerate the aspect of operation and maintenance facilities and shall enclose necessary literature.
60. The equipment shall be supplied and delivered at the specified site at your own cost.
61. All payments like refund of Earnest Money, Security Deposit and all bills of contractors' will be paid through ECS. For this purpose, following details are to be furnished by the tenderer:-
  - i). Name of the bank :-
  - ii). Name of the Branch with Code No. :-
  - iii). Bank account no. :-
  - iv). Type of account :- Saving/Current/Cash Credit
  - v) MICR No :-
  - vi) IFSC Code :-

The account shall have to be with a bank within the ECS zone prescribed by the RBI.

62. The tenderer/s have to fill in the Technical Data. The successful tenderer shall have to supply materials and execute the work as per Technical Data offered by them.
63. All materials are to be supplied progressively as required at site subject to prior approval of Engineer or his representative.
64. During course of examination of Part-I of the Bid, the bidders if asked for shall furnish any or additional documents for the purpose of evaluation of his / their bids. The price bids i.e. part-II of those bidders who meet the qualifying criteria of the NIT shall be opened.

66. **Priority of Contract Documents**

The several documents forming the Contract are to be taken as mutually explanatory to one another, but in case of ambiguity or discrepancies, the same shall be explained and adjudicated by the Engineer of the Contract (EoC), who shall thereupon issue to the Contractor instructions thereon which will be final and binding on the Contractor. Unless otherwise provided in the Contract, if the stipulations in the various documents forming a part of the Contract are found to be in variation in any respect then, unless a different intention appears, the provision(s) of one will override others (but only to the extent these are at variance) in order of precedence as given in the list below i.e. a particular item in the list will take precedence over all those placed lower down the list:

The following documents of the Contract Agreement will be in the following sequence :-

- a. Letter of Intent (LoI) / Work Order
- b. Special Conditions of Contract
- c. Scope of work and Terms of Payment
- d. Bill of Quantities
- e. Instructions to the Tenderer
- f. General Conditions of Contract
- g. Any other document(s) forming part of the Contract.

67. **Custodian Certificate** : After delivery at site the supplied materials are to be verified by KoPT Officials and the custodian certificate is to be issued by the Contractor in this regard, for consumption of such materials in the instant work.
68. **Termination of contract and Risk Purchase Clause** : Will be applicable as per clause No. 8 of KoPT's General Conditions of Contract.
69. **Special / Additional Security** may be arranged by the contractor at the site at no extra cost to KoPT over and above the General Security provided within KoPT premises by Port Security Authority.
70. In case of any dispute, question or difference either during the execution of the work or any other time as to any matter or thing connected with or arising out of this Contract, the decision of the Engineer, Kolkata Port Trust, thereon shall be final and binding upon all parties.
71. All other terms and conditions excepting those mentioned separately shall be governed by KoPT's General Condition of Contract.

72. **TERMS OF PAYMENT**

(i) **Supply items :-**

- a. 60% payment against supply and delivery of materials / equipment / machineries / items on production of proper purchase documents/challans at site together with required Test Certificates etc. from appropriate authorities including inspection certificate of KoPT's representative, as applicable and on submission of Custodian Certificate.
- b. 30% payment against installation and commissioning.
- c. 10% payment against testing and handing over of the entire work after completion of work as per NIT.

(ii) **Installation and Commissioning:-**

- a. 90% payment against installation and commissioning.
- b. 10% payment against testing and handing over of the entire work after completion work as per NIT.

Any defect and / or deficiency in the equipment supplied shall have to be made good by the contractor before any bill is passed for payment. Payment will be made subject to security deposit clause 3.4, 3.5 & 9 of GCC. Payment will be made on the basis of actual measurement.

**73 Taxes & Duties:** The rate quoted by the tenderer should be considered to complete the work in all respect and should be exclusive of GST or any statutory levies and or other charges levied by any central/state/local authorities. GST and any other extra charges/statutory levies will be paid extra at applicable rates at the time of supply of goods and services.

**Relevant GST Clause:**

- i. Supplier/Service Provider to confirm that the GST amount charged in Invoice is declared in its returns and payment of taxes is also made.
- ii. The supplier/service Provider agrees to comply with all applicable GST Laws, including GST acts, rules, regulations, procedures, circulars and interaction there under applicable in India from time to time and to ensure that such compliance is done within the time prescribed under such laws. Supplier/Service Provider should ensure accurate transaction details, as required by GST Laws are timely uploaded in GSTN. In case there is any mismatch between the uploaded in GSTN by supplier/service provider and details available with Kolkata Port Trust, then payment to supplier/service provider to the extent of GST relating to the invoice/s under mismatch may be retained from due payment till such time Kolkata Port Trust is not sure that accurate tax amount is finally reflected in the GSTN to KoPT's account and is finally available to the Kolkata Port Trust in terms of GST Laws and that the credit of GST taken by Kolkata Port Trust is not required to be reversed at a later date along with applicable interest.
- iii. Kolkata Port Trust has the right to recover mandatory loss including interest and penalty suffered by it due to any non-compliance of tax law by the supplier/service provider. Any loss of input tax credit to Kolkata Port Trust for the fault of supplier shall be recovered by Kolkata Port Trust by way of adjustment in consideration payable.
- iv. Supplementary invoices/debit note/credit note for price revision to enable Kolkata Port Trust to claim tax benefit on the same shall be issued by you for a particular year before September of the succeeding financial year.
- v. The purchase order/work order shall be void, if at any point of time you are found to be a blacklisted dealer as per GSTN rating system and further no payment shall be entertained.

#### **74. DETAILED SCRUTINY OF E-TENDERERS:**

##### **Documents are to be uploaded:**

- (i) GST Registration certificate.
- ii) Valid Trade Licence.
- iii) Valid Professional Tax Clearance Certificate / Upto date tax payment challan(if applicable) / else document in support of exemption.
- iv) Proof of possession of valid Employees' Provident Fund (EPF) Account.
- v) Proof of being registered with Employees' State Insurance Corporation (ESIC) / Affidavit and Indemnity Bond.
- vi) Details of the firm as per Schedule-O (in Volume-I) of the tender document.
- vii) Credentials in the form of copies of Letters of Award of Works along with corresponding Completion Certificates from owners to justify that the intending bidder satisfies the earlier mentioned pre-qualification criteria.
- viii) Copies of balance sheet and Profit and Loss account / Trading account for the last 3 (three) financial years (i.e. 2013 – 2014, 2014 – 2015, 2015-16) and the same should be audited as per relevant norms wherever required.
- ix) Addendum / Corrigendum / Notice / Extension Notice issued and drawings (if any) duly signed by the Bidder under office seal.
- x) EMD & Cost of Tender documents / NSIC Registration certificate.
- xi) Certified copies of PAN Card.
- xii) Electrical Contractor Licence.
- xiii) Proforma (Form -D).
- xiv) Covering Letter.
- xv) Statement to confirm the status of the Tenderer – whether a Partnership Firm, Company or Proprietorship Firm. If demanded by KoPT, the tenderer would be bound to furnish necessary documents in support of their statement in this regard.
- xvi) A declaration has to be furnished by the tenderer stating (**undertaking**) that the entire tender document, GCC and addenda has fully been read and understood (Annexure –I).

During techno-commercial evaluation, i.e. evaluation of Part-I of tender, an offer shall be considered non-responsive in case it –

- (i) is not accompanied by requisite earnest money,
- (ii) is not accompanied by requisite tender paper cost,
- (iii) validity of the offer is less than tender stipulation,
- (iv) It does not meet the qualification criteria as stipulated in the NIT.
- (v) The bidder submits conditional offer / impose own terms and conditions / does not accept tender conditions completely / offer or tender if submitted with any deviation from the tender terms & conditions.
- (vi) if the tender is conditional,
- (vii) if all the documents required as per NIT are not uploaded.

##### **In addition to the above, a bidder may be disqualified if :-**

- (a) The bidder provides misleading or false information in the statements and documents submitted.
- (b) Record of unsatisfactory performance during the last seven years, such as abandoning of work or rescinding of contract for which the reasons are attributable to the non-performance of the contractor or inordinate delays in completion or financial bankruptcy, etc.

**The decision of Kolkata Port Trust in this regard shall be final and binding on the Bidder.**

**SCOPE OF WORK**

**Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

**Name of the Work:-** “Electrical Installation Work for development and up gradation of 2 KPD & 11 KPD shed in connection with Central Sector Scheme for Coastal Cargo.”

1. Supply, delivery, Installation and Commissioning of L.T. Panels, Add-on Panel & Pillar Boxes as per BOQ.
2. Supply, delivery, laying, termination and commissioning of 3.5C x 240 sq. mm., 3.5C x 150 sq. mm., 3.5C x 70 sq. mm., 3.5C x 35 sq.mm., 3.5C x 25 sq.mm., 4C x 16 sq. mm. , 4C x 10 sq. mm. , XLPE insulated, 1.1 kV grade, armoured Al. Cable as per BOQ.
3. Supply, delivery, installation and commissioning of DBs & Sub DBs as per BOQ.
4. Supply, delivery, installation and commissioning of Pillar Box , as per BOQ.
5. Supply, delivery, installation and commissioning of LED Tube Light, Industrial Integral well glass, LED high bay, Flood Light Luminaries as per BOQ.
6. Supply, delivery, installation and commissioning of cable loop box, DOL starters, timers
7. Supply, delivery, installation and commissioning of CFL Lamp with Bakelite holder.
8. Supply, delivery, installation and commissioning of outdoor type Luminaries with 400/250/150 watt. SON-T/SON-E Lamp.
9. Supply, delivery, installation and commissioning of LED Light Fittings.
10. Supply, delivery, installation and commissioning of Power Plug & Socket.
11. Supply, delivery, installation and commissioning of 1200mm ceiling fan with electronic fan regulator.
12. Distribution wiring in PVC rigid conduit should be carried out conforming to relevant IS specification with up to date latest amendment.
13. Shifting & Re-installation of existing 4x180AH rating battery installed inside the KPD(west) Substation room.
14. Earthing of the Electrical Installation as per IS specification.
15. Buy back of Bus Bar Chambers, LT switches, Different rating and sizes of Iron Clad Switches, Cu/Al wires and GI/PVC conduit, with dismantling.

Including all appurtenant works as described and set forth in, Bill of quantities, Special Conditions of contract, Technical Specification of works, Specification of materials & Workmanship with all additional or varied works which may thereafter be required in Accordance with Clause-7 of General conditions of contract and as per direction of The Engineer of the Contract. The intending tenderer shall inspect the site of work in consultation with the Engineer and acquaint himself with the nature of Work before preparing his tender. His attention is drawn to Clause No. 3.1 of the General Conditions of Contract in this regard. No excuse on ignorance as to the site conditions will be entertained.

Any work, considered required by the contractor and not mentioned hereunder, for successful completion of the project, is to be included in the item of bill of Quantity suitably, which should be finalized in the pre bid meeting.



The work shall be carried out as per Indian Electricity Act, 2003, Central Electricity Authority (Measures relating to safety & electricity supply) Regulation ,2010 with latest revised IS code of Practice and relevant portion of National Building Code particularly with respect to fire safety and also code of practice for fire safety of buildings (general): Electrical Installations, IS:1646: 1997.

Unless otherwise specified, the work to be provided for by the contractor shall include but not be limited to the following :-

- a) Provide all materials, supervision, services, scaffolding and temporary lighting as required for work purposes etc.
- b) Prepare and submit for review and assessment to the Engineer working drawings showing how the work is actually going to be done as may be required by him.
- c) The contractor shall carry out the work in phased manner as per availability of the site so that normal day to day activities are not affected for which no such extra payment will be entertained.

**Danger Notice Plate** (designed as per **IS: 255**) at the installation shall have to be affixed by the contractor permanently in a conspicuous position in accordance with **Indian Electricity Rules, 1956** with latest amendments at Switch Room of 2KPD shed.

**Fire Buckets** filled with clean dry sand and ready for immediate use for extinguishing fires, in addition to **Fire Extinguishers** suitable for dealing with electric fire, shall have to be conspicuously marked and kept in Switch Room of 2KPD shed.

Instruction for **restoration of persons suffering from electric shock (Shock Treatment Chart)**, shall have to be affixed in a conspicuous place in Switch Room of 2KPD shed in accordance with the **Indian Electricity Rules, 1956** with latest amendments.

The **Electrical Layout Drawings, Single Line Diagram, Distribution Diagram, Circuit Drawings, Details drawing of LT Panels, Add-on Panels ,Pillar Boxes and Main & Sub DB**, etc. should be prepared by the Successful Tenderer and the same should be submitted to the Engineer for necessary approval, in triplicate, before installation.

-----

## **TECHNICAL SPECIFICATIONS**

### **E-tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

#### **01.00 Cables :**

##### **Cables**

**1.01 Item Details: -** Following sizes of XLPE insulated, armoured, overall PVC sheathed armoured Stranded Al. conductor cable of 1100 volts grade conforming to IS: 7098(Part – I) / 1988 with latest amendment, are included under the scope of this tender.

- a) 3.5 C X 240 mm<sup>2</sup> XLPE insulated PVC sheathed armoured Aluminium cable
- b) 3.5 C x 150mm<sup>2</sup> XLPE insulated PVC sheathed armoured Aluminium cable
- c) 3.5 C x 70 mm<sup>2</sup> XLPE insulated PVC sheathed armoured Aluminium cable
- d) 3.5 C x 35 mm<sup>2</sup> , XLPE insulated PVC sheathed armoured Aluminium cable
- e) 3.5 C x 25 mm<sup>2</sup> , XLPE insulated PVC sheathed armoured Aluminium cable
- f) 4 C x 16 mm<sup>2</sup> XLPE insulated PVC sheathed armoured Aluminium cable
- g) 4 C x 10 mm<sup>2</sup> XLPE insulated PVC sheathed armoured Aluminium cable
- h) 2 C x 10 mm<sup>2</sup> XLPE insulated PVC sheathed armoured Aluminium cable

± 5% variation will be allowed as per practice.

It shall be ensured that before dispatch, both ends of the cables are properly sealed to prevent ingress of moisture in the insulation. Direction of arrow must be marked on the cable drum.

##### **Laying**

##### **Laying Underground:-**

Cable shall be laid generally in accordance with I S:1255-1983. The average depth of trench for laying cable shall be as below:-

- i) Directly on ground - 0.75 m.
- ii) At road crossing - 1.00 m.

The trenches shall be excavated in reasonably straight line, and where there is a change in direction suitable curvature shall be provided, with 12D radius where D is the diameter of the cable. Where gradients and changes in depth are unavoidable, this shall be gradual, except where otherwise directed by the Engineer. The cable shall be laid on a cushion of sand, protected with bricks placed on both sides (along the length of the cable) and top (across the length of the cable). After laying of the cable the duct shall have to be filled up by sand. Where cables run in parallel, separate ducts as stated shall have to be provided. Existing G.I. pipes shall have to be used where cable pass through walls, roads, drains, culverts, railway line etc. For one run of cable one GI pipe is to be considered. In other word two or more run of cable will not pass through one pipe.

The cable trench shall be filled back with riddled soil obtained from excavation. This shall be done in layer and compacted. Cable route marker shall have to be provided at a maximum distance of 50m.

##### **Laying on wall or structure:-**

Where cable shall be laid on wall or structure, the cable shall be laid by using MS Clamp of adequate strength and size. The maximum distance between clamps shall not be more than 400mm. The cable shall run as straight as possible. There shall be GI pipe protection of 1 meter from each floor level during vertical run. When the cable shall pass through wall/floor etc pipe protection shall have to be given. Wherever cable shall be required to be laid inside the building, the cable shall be laid on perforated GI Tray of adequate size and mechanical strength. The tray shall be rigidly fixed on wall in a proper manner at suitable height using MS angle. The cable shall be fixed on tray using MS clamp of proper size and thickness at a distance should not be more than 300mm. In case cable pass from one building to another building; GI protection pipe of adequate size is to be provided with proper fixing. Neatness must be maintained.

##### **Laying through existing trench :-**

Cable shall be laid through existing covered/uncovered masonry trench inclusive supply of RC covers ,if required, setting them in order, mending good the damages filling the trench with fine dry sand.

**Termination and Finishing:-**

Termination of cable shall have to be made by using suitable compression cable gland and sockets by crimping to the size of the cable.

**02.00 L.T. Panels (Item details:)**

**2A. For 2 KPD :** The L.T Power distribution Panel should be fabricated not less than 2.5 mm thick MS sheet over suitable size of Angle Iron Frame for base channel and stiffener and should have IP-54 protection. The LT panel shall be self supporting, compartmentalized and door shall be removable type mounted on hinged locking arrangement for each compartment. The rear side of the panel should be removable type for getting maintenance facility. The panel should be painted with powder coated superior quality paint after degreasing and phosphate treatment. The panel shall have the following components :-

Sl. No.	Description	Qty.
1.	35KA, 415V AC, 400A, 4P, MCCB of adjustable thermal & fixed magnetic setting (Incomer).	03 nos.
2.	25KA, 415V AC, 200A, 4P, MCCB of adjustable thermal & fixed magnetic setting.	01 nos.
3.	25KA, 415V AC, 100A, 4P, MCCB, of adjustable thermal & fixed magnetic setting.	03 nos.
4.	25KA, 415V AC, 63A, 4P, MCCB of 'C' type characteristics.	04 nos.
5.	Cu Bus Bar of 1000 A, 415 V, 50 Hz, 3 phase & Neutral with suitable size and length.	01 set
6.	Digital Ammeter with selector switch	01 nos.
7.	Digital Voltmeter with selector switch with 3 nos. LED indication lamp and fuses.	01 set

The bus – bars shall be designed for 1000 A current ratings and for a maximum temperature rise of **50° C** over an ambient temperature of **40°C**. The bus – bars shall be of hard drawn high conductivity electrolytic grade copper flats. The bus- bars shall be of uniform cross section along its entire length. No tapering of the bus bars' cross-section is allowed. Current density at any part shall not exceed prescribed limits.

Interconnection of the components with suitable size of copper wire /strip /Bar, jointing materials, sockets, taps, etc. as required are to be carried out. Along with this the LT panels should be fitted with LED indication lamps for each phases, continuous earth bus-bar, cable glands, lugs, jointing materials, C.T. shorting link, extended terminals/ spreader link etc. as necessary for incoming & outgoing cables.

**2B. For 11 KPD :** The L.T Power distribution Panel should be fabricated not less than 2.5 mm thick MS sheet over suitable size of Angle Iron Frame for base channel and stiffener and should have IP-54 protection. The LT panel shall be self supporting, compartmentalized and door shall be removable type mounted on hinged locking arrangement for each compartment. The rear side of the panel should be removable type for getting maintenance facility. The panel should be painted with powder coated superior quality paint after degreasing and phosphate treatment. The panel shall have the following components :-

Sl.	Description	Qty.
1.	35KA, 415V AC, 400A, 4P, Type-C, MCCB of adjustable thermal & fixed magnetic setting (Incomer).	02 nos.
2.	25KA, 415V AC, 125A, 4P, Type-C, MCCB of adjustable thermal & fixed magnetic setting. (Outgoing)	01 nos.
3.	25KA, 415V AC, 63A, Type-C, 4P, MCCB, of adjustable thermal & fixed magnetic setting. (Outgoing)	06 nos.
4.	25KA, 40A, 4P, 415V AC, MCCB of 'C' type characteristics. (Outgoing)	02 nos.
5.	Cu Bus Bar of 1000 A, 415 V, 50 Hz, 3 phase & Neutral with suitable size and length.	01 set

6.	Digital Ammeter with selector switch	01 nos.
7.	Digital Voltmeter with selector switch with 3 nos. LED indication lamp and fuses.	01 set

The bus – bars shall be designed for 1000 A current ratings and for a maximum temperature rise of **50° C** over an ambient temperature of **40°C**. The bus – bars shall be of hard drawn high conductivity electrolytic grade copper flats. The bus- bars shall be of uniform cross section along its entire length. No tapering of the bus bars' cross-section is allowed. Current density at any part shall not exceed prescribed limits.

Interconnection of the components with suitable size of copper wire /strip /Bar, jointing materials, sockets, taps, etc. as required are to be carried out. Along with this the LT panels should be fitted with LED indication lamps for each phases, continuous earth bus-bar, cable glands, lugs, jointing materials, C.T. shorting link, extended terminals/ spreader link etc. as necessary for incoming & outgoing cables.

## **2C. Installation:**

The L.T panels should be installed at 2 KPD & 11KPD switch room. The Panel is to be floor mounted placed on suitable iron channel . Suitable sizes of Hot Deep Galvanized Steel Base Channels / Angles should be grouted, leveled in cement concrete foundation. A proper bonding surface should be made by cheeping the floor while making cement concreting. All the panels should be assembled, aligned and leveled. The Fixing Bolts should be grouted only after satisfying all these requirements Adequate support system and fixtures to be given for mechanical strength by making suitable arrangements. The LT panel should be doubly earthed.

## **3. Add-ON LT Panel**

### **3A Add on Panel for 2 KPD**

#### **Item details**

The Add-on LT panel shall be indoor type of protection IP 54 fabricated not less than 2.5mm thick MS sheet over suitable size of angle iron frame for base channel & stiffener. The Add-on panel shall be floor mounting, self supporting, compartmentalized and door shall be removable type mounting on hinged locking arrangement for each compartment. The rear side of panel should be removable type for getting maintenance facility. The Panel shall incorporate the following components :-

Sl. No.	Description	Qty.
1.	50KA, 415V, AC, 630A, 4P, ACB	01 nos.
2.	35KA, 415V AC, 200A, 4P, MCCB	02 nos.
3.	Cu Bus Bar of 2000 A, 415 V, 50 Hz, 3 phase & Neutral with suitable size and length. (details as given below)	01 set

1 No. 415 Volt, 630 A, FP, 50KA, ACB with microprocessor release of type IPR-1 having current adjustment facility of ( 40% - 100% ) is to be provided. It shall conform to IS:13947-2 and should be complete in all respects having the following minimum requirements :-

- Motor wound spring closing mechanism.
- Full draw-out type with indication for service, test and isolated positions. Suitable guides shall be provided to facilitate easy withdrawal of the trolley.
- Trip free mechanism.
- Mechanical open, closed and spring charges indicator.
- Main contacts made up of copper.
- 3 Nos. indicating lamps for ON / OFF and Breaker 'Auto Trip' indication.
- Relay for O/C, S/C, E/F protection and others as indicated.
- The operating mechanism shall be trip-free. Failure of spring, vibrations or shocks shall not cause unintended operation of breaker or prevent intended tripping operation. Closing of breakers shall be prevented unless the spring is fully charged.
- The breaker shall be provided with all necessary interlocks to prevent inadvertent operations and to ensure safety of operating personnel and also the equipment.

Along with both the panels should have 1 set Bus Bar for 2000A,415volts,50Hz,3phase &Neutral made of copper with suitable size and length and bus bar chamber shall be extended/projected suitably so that the new bus bar can be properly jointed/coupled with the bus bar of the exiting panel at KPD west sub station. Interconnection with suitable size cooper wire/strip/bar, jointing materials, sockets, tapes, etc as required are to be provided. Cable glands, lugs, spreader link etc. as necessary for Incoming/outgoing cables are also to be provided. Continuous earth bus bar of suitable size should also provided. The colour of the Add-on Panel should be in line existing panel.

### 3B Add on Panel for 11 KPD

#### Item details

The Add-on LT panel shall be indoor type of protection IP 54 fabricated not less than 2.5mm thick MS sheet over suitable size of angle iron frame for base channel & stiffener. The Add-on panel shall be floor mounting, self supporting, compartmentalized and door shall be removable type mounting on hinged locking arrangement for each compartment. The rear side of panel should be removable type for getting maintenance facility. The Panel shall incorporate the following components :-

Sl. No.	Description	Qty.
1.	50KA, 415V, AC, 630A, 4P, ACB	02 nos.
2.	Cu Bus Bar of 2000 A, 415 V, 50 Hz, 3 phase & Neutral with suitable size and length. (details as given below)	01 set

2 Nos. 415 Volt, 630 A, FP, 50KA, ACB with microprocessor release of type IPR-1 having current adjustment facility of ( 40% - 100% ) is to be provided. It shall conform to IS:13947-2 and should be complete in all respects having the following minimum requirements :-

- Motor wound spring closing mechanism.
- Full draw-out type with indication for service, test and isolated positions. Suitable guides shall be provided to facilitate easy withdrawal of the trolley.
- Trip free mechanism.
- Mechanical open, closed and spring charges indicator.
- Main contacts made up of copper.
- 3 Nos. indicating lamps for ON / OFF and Breaker 'Auto Trip' indication.
- Relay for O/C, S/C, E/F protection and others as indicated.
- The operating mechanism shall be trip-free. Failure of spring, vibrations or shocks shall not cause unintended operation of breaker or prevent intended tripping operation. Closing of breakers shall be prevented unless the spring is fully charged.
- The breaker shall be provided with all necessary interlocks to prevent inadvertent operations and to ensure safety of operating personnel and also the equipment.

Along with both the panels should have 1 set Bus Bar for 2000A,415volts,50Hz,3phase &Neutral made of copper with suitable size and length and bus bar chamber shall be extended/projected suitably so that the new bus bar can be properly jointed/coupled with the bus bar of the exiting panel at KPD East side sub-station. Interconnection with suitable size cooper wire/strip/bar, jointing materials, sockets, tapes, etc as required are to be provided. Cable glands, lugs, spreader link etc. as necessary for Incoming/outgoing cables are also to be provided. Continuous earth bus bar of suitable size should also provided. The colour of the Add-on Panel should be in line existing panel.

### 3 C. Installations:-

Add-On Panels shall be installed at KPD West side Sub-station & East side Sub-station. Panels shall be floor mounted and to be fixed with foundation bolts. The cables to be tightened with cable glands through gland plates fitted under the panel. Adequate support system and fixtures to be given for mechanical strength by suitable arrangements and should be doubly earthed. The cost for necessary modification work on existing LT distribution panel at KPD (WEST) & KPD (EAST) sub-station to connect with the add- on ACB panels shall be included in the cost of installation of the panel.

#### 4.00 Pillar Boxes:-

##### Item details

The Pillar Boxes shall be made up of sheet metal as per IS norm having applicable protection standard in all sides having two hinged door on front and back side with panel key type and pad locking type. All the four corners are supported by suitable size of MS 'L' angles. The bottom plate of the box shall be detachable and shall knockout holes for entering u/G cables. The pillar box is to be suitable for outdoor type installation and should be complete with integral canopy and a panel lock. The sheet metal should be hot dip galvanized. Door sealing arrangements are to be made of neoprene rubber gasket of thickness not less than 3mm. Cable entry is to be from bottom only with detachable gland plate. The pillar boxes shall be suitable for IP-55 protection and shall be doubly earthed. 2nos of fully threaded bolts along with GI nuts and washers are to be provided on two sides of the pillar boxes as earth stud.

The Pillar Boxes shall have Copper bus bars for 3 phase and neutral connection and a continuous running earth bus comprising 50mm X 6mm thick Aluminium flat is to be provided at the bottom of the pillar box. Two no danger boards are to be provided on the front and back door of the pillar box.

**There are two type of pillar boxes which are to be provided . One is Type 1 pillar box for feeding power to vessels at 2 KPD Berth and the other Type-2 pillar box for providing power to 2 KPD Gate and Pump room**

**Type 1 Pillar Box should** consists the following: (For 2KPD)

Sl.No.	Description	Qty.
1.	25 KA,415V, 200A, 4P, MCCB	01
2.	25KA, 415V, 100A, TPN, C-type, MCB	02
3.	100 A, 3Phase Stud type Terminals	02

**Type 2 Pillar Box should consist the following :** (For 2KPD)

Sl. No.	Description	Qty.
1.	25A, 415V,100A, 4P, MCCB	01
2.	10KA,415V, 40A, TPN, C-Type, MCB	04

**Type 3 Pillar Box should** consists the following: (For 11KPD)

Sl.No.	Description	Qty.
1.	25 KA,415V, 100A, 4P, MCCB	01
2.	25KA, 415V, 63A, TPN, C-type, MCB	02
3.	10KA, 415V, 32A, TPN, C-type, MCB	02
4.	10KA, 415V, 32A, DP, C-type, MCB	02

##### Installation

The pillar box is to be installed on a raised brick foundation (approximately 1 metr) above ground level . The brick foundation is to be covered with neat cement finish. The cables are to be tightened with cable glands through gland plates fitted under the panel. Adequate support system and fixtures to be given for mechanical strength by making suitable arrangements and should be connected to the earth system with the help of spring washers, thimbles etc.

#### 05.00 Distribution Boards:-(for 2KPD)

##### Item Details

The Main Distribution board with IP-42/43 protection will comprise of 63A, 415V, 25 KA ,FP MCCB as incomer with 6 nos 40 A, 415V, 10 KA,TP MCB, as outgoing units of adjustable thermal(MCCB) & fixed magnetic setting mounted in factory built /fabricated distribution boards of sheet steel, phosphatised, powder painted , dust, vermin, and weather proof complete with bus bars, neutral links, blanking plates etc. conforming to IS norm. The DB shall be accessible from front by lockable hinged with double door enclosure The Main Distribution Board shall be used for three phase four wire system to

distribute three phase power supply to different boards. Necessary clamping arrangements shall have to be made for clamping of cables inside the DB so that the cables can be properly dressed. Internal wiring shall have to be done by suitable size of copper wire. The body and all metal parts not carrying current must be connected with earth.

#### **05.01 Distribution Boards:-(for 11KPD)**

##### **Item Details**

The Main Distribution board with IP-42/43 protection will comprise of 63A, 415V, 10 KA ,TPN MCB as incomer with 12 nos 32A-6A, 230V, 10 KA,SP MCB, as outgoing units mounted in factory built /fabricated distribution boards of sheet steel, phosphatised, powder painted , dust, vermin, and weather proof complete with bus bars, neutral links, blanking plates etc. conforming to IS norm. The DB shall be accessible from front by lockable hinged with double door enclosure The Main Distribution Board shall be used for three phase four wire system to distribute three phase power supply to different boards. Necessary clamping arrangements shall have to be made for clamping of cables inside the DB so that the cables can be properly dressed. Internal wiring shall have to be done by suitable size of copper wire. The body and all metal parts not carrying current must be connected with earth.

#### **05.02 Distribution Boards:-(for 11KPD)**

##### **Item Details**

The Main Distribution board with IP-42/43 protection will comprise of 125A, 415V, 25 KA ,TPN MCCB as incomer with 1 no. 100A, 415V, 25 KA,TPN MCCB and 1 no. 32A, 415V, 10 KA,TPN MCB as outgoing units of adjustable thermal(MCCB) & fixed magnetic setting mounted in factory built /fabricated distribution boards of sheet steel, phosphatised, powder painted , dust, vermin, and weather proof complete with bus bars, neutral links, blanking plates etc. conforming to IS norm. The DB shall be accessible from front by lockable hinged with double door enclosure The Main Distribution Board shall be used for three phase four wire system to distribute three phase power supply to different boards. Necessary clamping arrangements shall have to be made for clamping of cables inside the DB so that the cables can be properly dressed. Internal wiring shall have to be done by suitable size of copper wire. The body and all metal parts not carrying current must be connected with earth.

##### **Installation:-**

The DB is to be installed in the 2 KPD/11KPD Switch room/Shed inside. The DBs shall be installed on wall by suitable iron leg/flat iron frame/angle iron frame and are to be double earthed with the earth busbar adequately. All hardware items required for this job, should be provided & installed by the contractor. Necessary civil work required for grouting the wall bracket inside the wall is also under the Scope of the Contractor

#### **06.00 Sub Distribution Board(for 2KPD)**

The Sub Distribution board with IP-42/43 protection will comprise of 32A, 415V, 10KA , TPN MCB as incomer and 9 nos. 6-32 A, 230V, 10 KA,SP MCB as outgoing interconnection suitable size of copper wire and neutral link & provision for earthing attachment units mounted in factory built /fabricated TPN distribution boards of sheet steel, phosphatised, powder painted , dust, vermin, and weather proof complete with bus bars, neutral links, blanking plates etc. conforming to IS norm.

#### **06.01 Sub Distribution Board(for 11KPD)**

The Sub Distribution board with IP-42/43 protection will comprise of 32A, 230V, 10KA , SPN MCB as incomer and 9 nos. 6-32 A, 230V, 10 KA,SP MCB as outgoing units mounted in factory built /fabricated TPN distribution boards of sheet steel, phosphatised, powder painted , dust, vermin, and weather proof complete with bus bars, neutral links, blanking plates etc. conforming to IS norm.

##### **Installation**

3 no of such Sub Distribution boards are to be provided. The Sub- DBs shall be installed on wall of 2 KPD/11 KPD shed and are to be double earthed with the earth busbar adequately

## **7. Luminaries**

### **Item details**

- (a) Surface mounted single tube light fittings fitted with 20W LED tube light complete in all respects are to be provided having high power factor and good light output at low voltages.
- (b) Recess/Suspended mounted single tube light fittings fitted with 20W LED tube light complete in all respects are to be provided having high power factor and good light output at low voltages.
- (c) Indoor Industrial 80W LED high bay luminaire, coated with Powder having high pressure die-cast aluminium housing fitted with LED driver compartment, Eye-bolt for suspension mounting, heat sink for proper thermal management, Secondary lens optics for constant voltage constant current are to be provided. The operation voltage range to be from 100-300VAC, provided with open and short circuit protection and input surge voltage protection, Completely prewired with accessories with electrical components which are necessary to operate the lamps.
- (d) Outdoor type Luminaires complete with two nos SONT-400 W lamp together with electrical components like Ballast, Igniter, etc. which are necessary to operate the lamp with pressure die cast aluminium housing and heat resistance toughened glass cover are to be provided.
- (e) Indoor Industrial Integral well glass luminaire fitted with one SON-E 150W lamp with electrical components Ballast & Starter which are necessary to operate the lamps complete in all respect shall be provided.
- (f) Outdoor type luminaries with pressure die cast aluminium housing POT optics reflector and polycarbonate cover with one SON T 250W lamp and inclusive of electrical components like ballast, starter and other accessories complete in all respect are to be provided.

### **Installation**

Installation of the above Luminaires are given in BOQ.

## **8. Ceiling Fans , Exhaust Fans, Cabin Fan**

### **Item details**

Energy saving, 3 blade, ball bearing type, armature with copper winding, ceiling fan of 1200 mm sweep complete with blade, canopy similar to that of Havells make Pacer model or equivalent to any other approved make of appropriate colour are to be provided.

### **Installation**

The ceiling fans complete with blades, canopy, fork, rubber and electronic speed regulator are to be installed in the ceiling hook of shed office. Down rods are to be provided wherever necessary. Cost of down rod shall be included in its installation price.

## **09. Circuit wiring/Distribution wiring/ Point wiring and wires:**

Details are given in BOQ.

**10. Earthing :** All Panels, Distribution board, Sub distribution boards and Main switches shall have to be connected to Earth stations (double earth) in accordance with the requirement of Indian Electricity Rules and IS 3043. Interconnections of two earth stations have to be done by 25 x 6 mm GI flats shall be used for same. Earthing shall be provided with 50 mm dia GI pipe 3.64 mm thick x 3.04 Mts long and 1x4 SWG GI (Hot Dip) wire (4 Mts. Long), 13 mm dia x 80 mm long GI bolts, double nuts, double washers incl. S & F 15 mm dia GI pipe protection (1 Mt. long) to be filled with bitumen, partly under the ground level and partly above ground level driven to an average depth of 3.65 Mts. below the ground level & restoring surface duly rammed. Masonry enclosure shall be provided on the top of earth electrode of overall size 86.36cm x 86.36cm x 46cm deep (below Ground level) complete with cemented brickwork (1:6) of 25 cm width duly plastered with cement mortar (inside) CI hinged inspection cover of size 35.56 x 35.56 cm with locking arrangement, GI reducer including drilling of 46 nos 12 mm dia holes on the GI pipe and treatment of soil by using salt & charcoal or coke for plate electrode

**Other Items specifically not mentioned in the T.S.** shall be as per BOQ. Any other item required for installation but specifically not mentioned either in the BOQ or the T.S. like requisite length of MS Pipes, clamps and accessories shall be deemed to be included in the rates for installation of the items for which these items are intended. Tenderers are advised to build up the installation prices accordingly. Any claim in this regard on the plea that the item is not specifically mentioned shall not be entertained.



**Cleaning of site.**

On completion of works, the contractor shall reinstate and make good at his own expense any property or land which might have been disturbed and/or damaged by his works. Contractor should also clean the site as required during execution and fully clear the site after completion of all the works. Any holes/drillings/openings/damages made on the wall/roof for drawing of cables/installation of equipments shall be made good by the tenderer at his own cost.

**List of Approved Makes**

<b>Item</b>	<b>Make</b>
ACB/MCCB / MCB / DBs/Sub DBS/ DOL Starters	ABB/Siemens/ Havells/L&T/ Crompton / GE/Legrand /Any other reputed make
Luminaries, lamps.	Philips/ Bajaj/ Crompton /Anchor/Crompton/GE/Havells
PVC Copper wire for internal wiring	KDK-Evershine/Finolex/Havells/ National/Nicco/ Supercab/ Polycab
Piano type switches/ Socket/Ceiling Rose/ Electronic regulator.	Havells/Anchor/ Ellora/ Precision/ Rider/ /Pritam/Sleek/any other reputed make
L.T. power cable	NICCO/ Gloster/Universal/ Polycab /Havells.
CeilingFan	Havells/Usha/Orient /Crompton Greaves/Polar
Timer/ Comtactor	L&T/Schneider /any other reputed make

**N.B: Any other reputed make of any particular item will only be considered if none of the specified make for that particular item is available in the market for some reason or the other which is to be acceptable to competent authority**

**Inspection & Testing**

Inspection and testing will be carried out by KOPT Engineers/concerned experts. Inspection will be carried out **as applicable** as per **relevant IS 2189:2008** clauses and also as per relevant Standard/ Technical Specification/Approved Drawing etc.

Manufacturer's Test and guarantee certificate as applicable will have to be submitted for verification. All pre commissioning tests shall be carried out by the authorized representative of the firm having valid Certificate of Competency.

Inspection of the items to be supplied by the contractor will be carried out **by the Engineer or his representative in presence of contractor or his representative prior to dispatch**. The Engineer reserves the right to waive inspection at Manufacturer's premises (witnessing tests) or to inspect (physically) the materials at site, against Manufacturer's Internal Test Certificate & Guarantee Certificate as applicable. **The cost of conducting inspection at the factory premises to be carried out by the Engineer or his representative is to be borne by the contractor**. Inspection will be carried out as applicable as per relevant Standard/ Technical Specification/Approved Drawing etc. Manufacturer's Test and guarantee certificate as applicable will have to be submitted for verification. Inspection and Testing by **the Engineer or his representative** shall not relieve the successful bidder of their obligation for supplying the items and execution of the entire work in accordance with the **Contract Condition** and relevant **Acts, Rules and Codes of Practice**. **The tenderer/s shall afford all facilities to the Engineer or his representative at their own cost & arrangement for inspection and testing of the equipment.**

**PRICE NOT TO BE QUOTED HERE.**

**BILL OF QUANTITY (BOQ)**

**E-Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

Item No.	Description	Qty.	Unit	Unit rate (in Rs)	Total Value (in Rs)
1.	Supply & Delivery of L.T. Power Distribution Panel having protection of IP-54 and with technical details as mentioned under technical specification SI No 2(A). <b>Location: 2KPD Switch Room.</b>	01	No.		
2.	Supply & Delivery of L.T. Power Distribution Panel having protection of IP-54 and with technical details as mentioned under technical specification SI No 2(B). <b>Location: 11KPD Switch Room.</b>	01	No.		
3.	The Panels under SI. No. 1 & 2 are to be installed on the floor with suitable iron channel. Adequate support system and fixtures to be given for mechanical strength by making suitable arrangements and double earthing connection should be made to the earth system with the help of spring washers, thimbles etc. to secure from contact with technical details as mentioned under technical specification SI No 2I.	02	Nos.		
4.	Supply & Delivery of Add-on indoor type L.T. Panel of protection IP-54 with technical details as mentioned in technical specification SI No 3(B). <b>Location: KPD West Sub Station.</b>	01	No.		
5	Supply & Delivery of Add-on L.T. Panel indoor type of protection IP-54 fabricated and with technical details as mentioned in technical specification SI No 3B. <b>Location: KPD East side Sub Station.</b>	02	Nos.		
6	The Add-On Panels shall be installed on floor with iron channel and foundation bolts. The cables to be tightened with cable gland plates fitted under the panel. Adequate support system and fixtures to be given for mechanical strength by suitable arrangements and should be connected to the earth system with the help of spring washers, thimbles etc. to secure from contact. Necessary modification and connection with existing LT Panel at Sub Station is to be carried out in order to make the add on panel as an integral part of the existing LT panel with technical details as mentioned under technical specification SI No 3C.	02	Nos.		
7	Supply and delivery of 3.5C x 240 sq. mm. Cable with the following specification, Conductor : Str-anded Aluminium comply IS:8130-1984 or latest amendment if any, Colour coded, Voltage Grade: 1.1KV, Insulation Sheathed: XLPE, Inner Sheathed: Extruded PVC, Armour: Galvanized Steel Strips, Conforming to IS:7098 (Part-I)/1988 or latest amendment if any. <b>Location: From Sub-Station to 2KPD &amp; 11KPD Electrical switch Room.</b>	900	Mtr.		
8.	Laying of 3.5Cx240 sq.mm. XLPE cables in an	700	Mtr.		

	underground trench with brick protection.				
9	Laying of 3.5Cx240 sq.mm. Aluminum Armoured XLPE cable through existing RCC/Hume/GI Pipe/masonry trench	200	Mtrs.		
10	Supply and delivery of 3.5C x 150 sq. mm. Cable with the following specification, Conductor : Str-anded Aluminium comply IS:8130-1984 or latest amendment if any, Colour coded, Voltage Grade: 1.1KV, Insulation Sheathed: XLPE, Inner Sheathed: Extruded PVC, Armour: Galvanized Steel Strips, Conforming to IS:7098 (Part-I)/1988 or least amendment if any. <b>Location: From 2KPD Switch Room to North side of 2KPD Shed and to 4KPD Switch Room.</b>	250	Mtrs.		
11	Laying of 3.5Cx150sq.mm. Cable through existing RCC/Hume/GI Pipe/masonry trench.	250	Mtrs		
12	Supply and delivery of 3.5C x 70 sq. mm. Cable with the following specification, Conductor : Str-anded Aluminium comply IS:8130-1984 or latest amendment if any, Colour coded, Voltage Grade: 1.1KV, Insulation Sheathed: XLPE, Inner Sheathed: Extruded PVC, Armour: Galvanized Steel Strips, Conforming to IS:7098 (Part-I)/1988 or least amendment if any. <b>Location: 2KPD Switch Room to PB No.2 near Gate No.2 and 11KPD Switch Room to LDB Shed Office &amp; to P.B.</b>	310	Mtrs.		
13	Laying of 3.5Cx70sq.mm. Cable on wall/surface incl.,S&F MS saddles with earthing attachment in 10 SWG GI (Hot Dip) wire,making holes etc. as necy.,mending good damages and painting.	100	Mtrs.		
14	Laying of 3.5Cx70sq.mm. Cable through existing RCC/Hume/GI Pipe/masonry trench.	180	Mtrs.		
15	Laying of 3.5Cx70 sq.mm. XLPE cables in an underground trench with brick protection.	30	Mtrs.		
16.	Supply and delivery of 3.5C x 35 sq. mm. Cable with the following specification, Conductor : Str-anded Aluminium comply IS:8130-1984 or latest amendment if any, Colour coded, Voltage Grade: 1.1KV, Insulation Sheathed: XLPE, Inner Sheathed: Extruded PVC, Armour: Galvanized Steel Strips, Conforming to IS:7098 (Part-I)/1988 or least amendment if any. <b>Location: 2KPD Switch Room to DB &amp; HM Tower, PB-2 to Pump.</b>	220	Mtrs.		
17	Laying of 3.5Cx 35 sq.mm. Cable on wall/surface incl. S&F MS saddles with earthing attachment in 2x10SWG GI (Hot Dip) Wire, making holes etc., necy., mending good damages.	20	Mtrs		
18	Laying of 3.5Cx35 sq.mm. Cable through existing RCC/Hume/GI Pipe/masonry trench.	70	Mtrs		
19	Laying of 3.5Cx35 sq.mm. XLPE cables in an underground trench with brick protection.	130	Mtrs.		
20	Supply and delivery of 3.5C x 25 sq. mm. Cable with the following specification, Conductor : Str-anded Aluminium comply IS:8130 -1984 or latest amendment if any, Colour coded, Voltage Grade: 1.1KV, Insulation Sheathed: XLPE, Inner Sheathed: Extruded PVC, Armour: Galvanized Steel Strips, Conforming to IS:7098 (Part-I)/1988 or least amendment if any. <b>Location:11KPD Switch Room to LCD Scanner Room.</b>	80	Mtrs.		

21	Laying of 3.5Cx 25 sq.mm. cable on wall/surface incl. S&F MS saddles with earthing attachment in 10SWG GI (Hot Dip) Wire, making holes etc., as necy. , mending good damages and painting.	80	Mtr.		
22	Supply and delivery of 4C x 16 sq. mm. Cable with the following specification, Conductor : Str-anded Aluminium comply IS:8130-1984 or latest amendment if any, Colour coded, Voltage Grade: 1.1KV, Insulation Sheathed: XLPE, Inner Sheathed: Extruded PVC, Armour: Galvanized Steel Strips, Conforming to IS:7098 (Part-I)/ 1988 or least amendment if any. <b>Location: For 2KPD (DB to SDB-1,2,3, PF &amp; Yard).For 11KPD (11KPD Switch Room to LDB inside Shed and Pump Room</b>	1120	Mtr.		
23	Laying of 4Cx 16 sq.mm. cable on wall/surface incl. S&F MS saddles with earthing attachment in 10SWG GI (Hot Dip) Wire, making holes etc., as necy. , mending good damages and painting.	650	Mtrs.		
24	Laying of 4Cx16 sq.mm. , aluminum armoured XLPE Cable of distribution wiring for Quay line/Yard/PF Lighting with loop in & loop out on wall/surface incl.	420	Mtrs.		
25	Laying of 4Cx25 sq.mm. Cable through existing RCC/ Hume/ GI Pipe/masonry trench.	50	Mtrs.		
26	Supply and delivery of 4C x 10 sq. mm. Cable with the following specification, Conductor : Str-anded Aluminium comply IS:8130-1984 or latest amendment if any, Colour coded, Voltage Grade: 1.1KV,Insulation Sheathed: XLPE, Inner Sheathed: Extruded PVC, Armour: Galvanized Steel Strips, Conforming to IS:7098 (Part-I)/1988 or least amendment if any. <b>Location: Yard/P.F Ltg. (11KPD).</b>	400	Mtrs.		
27	Laying of 4Cx10 sq.mm. ,aluminum armoured XLPE Cable of distribution wiring for Quay line/Yard/PF Lighting with loop in & loop out on wall/surface incl. S&F MS saddles with earthing attachment in 10 SWG GI (Hot Dip) wire, making holes incl. S&F approved GI waterproof type 4Pole looping cable box etc., as necy. Mending good damages. <b>Location: Yard/P.F Ltg.(11KPD)</b>	400	Mtrs.		
28	Supply and delivery of 2C x 10 sq. mm. Cable with the following specification, Conductor : Str-anded Aluminium comply IS:8130-1984 or latest amendment if any, Colour coded, Voltage Grade: 1.1KV,Insulation Sheathed: XLPE,Inner Sheathed: Extruded PVC, Armour: Galvanized Steel Strips, Conforming to IS:7098 (Part-I)/1988 or least amendment if any. <b>Location: 11KPD Shed Office to Gate 3A and Toilets.</b>	150	Mtrs.		
29	Laying of 2Cx 10 sq.mm. cable on wall/surface incl. S&F MS saddles with earthing attachment in 10SWG GI (Hot Dip) Wire, making holes etc., as necy. , mending good damages and painting.	50	Mtrs.		
30	Laying of 2Cx10 sq.mm. Cable through existing RCC/ Hume/ GI Pipe/ masonry trench.	100	Mtrs.		

31.	Supply & delivery of approved GI waterproof type loop-	80	Nos.		
-----	--	----	------	--	--

	in loop-out cable box suitable size having 4mm thick with rubber gasket etc. comprising of one 250v, 15A Kit-Kat fuse unit with terminal and 4Pole/2Pole, as necy., mending good damages and painting. <b>Location: For 11KPD.</b>				
32	Installation of the above boxes.	80	Nos		
33.	End termination by providing compression type gland complete with brass gland, brass ring & rubber ring for dust & moisture proof entry of 3.5C x 240 sq. mm., XLPE/PVC aluminum cable. <b>Location: 2nos for 2KPD and 4nos. for 11KPD.</b>	6	Nos.		
34.	End termination by providing compression type gland complete with brass gland, brass ring & rubber ring for dust & moisture proof entry of 3.5C x 150 sq. mm., XLPE/PVC aluminum cable. <b>Location: 4nos for 2KPD.</b>	04	Nos		
35.	End termination by providing compression type gland complete with brass gland, brass ring & rubber ring for dust & moisture proof entry of 3.5C x 70 sq. mm. XLPE/PVC aluminum cable. <b>Location :2 nos for 2KPD and 4nos. for 11KPD.</b>	06	Nos		
36.	End termination by providing compression type gland complete with brass gland, brass ring & rubber ring for dust & moisture proof entry of 3.5C x 35 sq. mm., XLPE/PVC aluminum cable. <b>Location: 6nos for 2KPD.</b>	06	Nos		
37.	End termination by providing compression type gland complete with brass gland, brass ring & rubber ring for dust & moisture proof entry of 3.5C x 25 sq. mm., XLPE/PVC aluminum cable. <b>Location: 2nos. for 11KPD.</b>	02	Nos.		
38.	End termination by providing compression type gland complete with brass gland, brass ring & rubber ring for dust & moisture proof entry of 4C x 16 sq. mm., XLPE/PVC aluminum cable. <b>Location: 50 nos for 2KPD and 10 nos. for 11KPD.</b>	60	Nos		
39.	End termination by providing compression type gland complete with brass gland, brass ring & rubber ring for dust & moisture proof entry of 4C x 10 sq. mm., XLPE/PVC aluminum cable. <b>Location: 30 nos. for 11KPD.</b>	30	Nos.		
40.	End termination by providing compression type gland complete with brass gland, brass ring & rubber ring for dust & moisture proof entry of 2C x 10 sq. mm., XLPE/PVC aluminum cable. <b>Location: 10 nos. for 11KPD.</b>	10	Nos.		
41.	Supply and delivery of Joint Box of suitable size for interconnection of old PILC Cable with new XLPE Cable with necessary sealing arrangement for PILC Cable. <b>Location: 2 nos. for 2KPD.</b>	02	Nos.		
42.	Supply and delivery of double door Distribution Board with IP-42/43 protection along with 63A, FP, 415V, 25KA, C-Type MCCB as Incomer and 6 Nos. 40A, 415V, TP, 10KA, C-Type, MCB as Outgoing interconnection with suitable size of copper wire and neutral link & provision for earthing attachment. <b>Location: 2KPD Elect. Switch Room.</b>	01	No.		

43	Installation, Testing and Commissioning of above Distribution Board on wall with suitable arrangement mending good the damages to the original finish as per Technical Specification.	01	No.		
44	Supply and delivery of double door Distribution Board (Type-1) with IP-42/43 protection along with 63A,TPN, 415V, 10KA, C-Type MCB as Incomer with S&F extended terminals/ spreader link, sockets, tapes etc., if necessary, for incoming cables and 12Nos. 6A-32A, 230V, SP, 10KA, C-Type, MCB as Outgoing interconnection with suitable size of copper wire and neutral link & provision for earthing attachment. . <b>Location: 4nos. for shed inside and 1no. for scanner Room (11KPD).</b>	05	No.		
45	Supply and delivery of double door Distribution Board (Type-2) with IP-42/43 protection alongwith 125A,TPN ,415V, 25KA, MCCB as Incomer with S&F extended terminals/ spreader link, sockets, tapes etc., if necessary, for incoming cables and 1No.100A,TPN ,415V, 25KA, MCCB, 1No. 32A, 10KA,C-Type, TPN MCB,3Nos. 32A, 10KA, SPMCB as Outgoing interconnection with suitable size of copper wire and neutral link & provision for earthing attachment. <b>Locatin: Shed Office (11KPD).</b>	01	No.		
46	Installation, Testing and Commissioning of above Distribution Board on wall with suitable arrangement mending good the damages to the original finish as per Technical Specification.	06	Nos.		
47	Supply and delivery of double door Sub-Distribution Board with IP-42/43 protection alongwith 32A, TPN, 415V, 10KA, C-Type MCB as Incomer and 9 Nos. 6-32A, 230V, 10KA, C-Type, SPMCB as Outgoing interconnection with suitable size of copper wire and neutral link & provision for earthing attachment. <b>Location: 2KPD Shed.</b>	03	Nos.		
48	Installation, Testing and Commissioning of above Sub Distribution Board on wall with suitable arrangement mending good the damages to the original finish as per Technical Specification.	03	Nos.		
49	Supply and delivery of Sub Distribution Board With 32A, 10KA,230V, SPMCB as incomer and 6 Nos. 6A,10KA,SP,MCB as outgoing. <b>Location: Shed Offic and Toilet(11KPD).</b>	02	Nos.		
50	Installation, Testing and Commissioning of above Sub Distribution Board on wall with suitable arrangement mending good the damages to the original finish as per Technical Specification.	02	Nos.		
51	Supplying and delivery 32A, TPN ,10KA, , C-type, MCB, with sheet steel enclosure	01	No.		
52	Installation of the above MCB on flat iron/angle on wall with nuts bolts etc. as required. <b>Location: Pump Room(11KPD).</b>	01	No		

53	Supply and delivery at site of MS Pillar Box No.1 with	01	No.		
----	--	----	-----	--	--

	double door arrangement of approved design with earthing attachment and powder coated /2 coats of synthetic enamel paint over 1 coat of red lead priming fabricated from not less than 3 mm thick MS Sheet with fixing following accessories: 1) 1 No. FP, 200A, 415V, 25KA, MCCB as Incomer 2) 2Nos. 100A, TPN, 415V, C-Type, MCB. 3) 4Nos. aluminium bar as 3phase busbar & neutral busbar and 1No. Aluminium bar as earth busbar. 4) Stud type terminals for 2 Nos. 100A, 3phase outgoing. <b>Locaton : 2KPD Berth.</b>				
54	The P.B. is to be installed on concrete foundation base having at least 1mtr. height from ground level. These cable to be tightened with cable glands through gland plates fitted under the panel. Adequate support system and fixtures to be given for mechanical strength by making suitable arrangements and should be connected to the earth system with the help of spring washers, thimbles etc. to secure from contact alongwith S&F extended terminals/spreader link, sockets, tapes etc., if necessary.	01	No.		
55	Supply and delivery at site of MS Pillar Box No.2 with double door arrangement of approved design with earthing attachment and powder coated /2 coats of synthetic enamel paint over 1 coat of red lead priming fabricated from not less than 3 mm thick MS Sheet with fixing following accessories: 1) 1 No. FP, 100A, 415V, 25KA, MCCB as Incomer 2) 4Nos. 40A, TPN, 415V, C-Type, MCB. as outgoing 3) 4Nos. aluminium bar as 3phase busbar & neutral busbar and 1No. Aluminium bar as earth busbar and 1No. Aluminium bar as earth busbar. <b>Locaton : 2KPD Gate for Pump &amp; Gate supply.</b>	01	No.		
56	The P.B. No.2 is to be mounted on concrete foundation base having at least 1mtr. height from ground level. Cables are to be tightened with cable glands through gland plates fitted at the bottom of the pillar box. Adequate support system and fixtures to be given for mechanical strength by making suitable arrangement and should be connected to the earth system with the help of spring washers, thimbles etc. to secure from contact.	01	No.		
57	Supply and delivery at site of MS Pillar Box with double door arrangement of approved design with earthing attachment and 2 coats of synthetic enamel paint over 1 coat of red lead priming, fabricated from not less than 3 mm thick MS Sheet with fixing following accessories: 1) One No. FP, 100A, 415V, 25KA, MCCB as Incomer 2) 2Nos. 63A, TPN, 415V, C-Type, MCB, 2) 2Nos. 32A, TPN, C-Type, MCB 2) 2Nos. 32A, DP, MCB as Outgoing 3) 4Nos. aluminium bar as 3phase busbar & neutral busbar and 1no. aluminium bar as earth busbar. <b>Locaton : 11KPD Customs office ,</b>	01			
58	The P.B. is to be installed on concrete foundation base having at least 1mtr. height from ground level. These cable to be tightened with cable glands through gland plates fitted under the panel. Adequate support system and fixtures to be given for mechanical strength by making suitable arrangements and should be connected	01			

	to the earth system with the help of spring washers, thimbles etc. to secure firm contact alongwith S&F extended terminals/spreader link,sockets,tapes etc., if necessary.				
59	Wiring from SDB to Main Switches for shed inside LED Luminaries with supplying and drawing 1.1KV grade single stranded FR,PVC insulated and unsheathed 2x84/ 0.3(6sq.mm.) + 1x56/0.3(4sq.mm.) ECC, FR copper wire in suitable PVC rigid conduit incl...Necessary fittings as required.	130	Mtr		
60	Distribution wiring for shed inside lighting with supplying and drawing looping in & looping out in 1.1 KV 2x84/0.3(6sq.mm.) single core stranded "FR" PVC insulated & unsheathed copper wire in suitable size PVC rigid conduit "FR"(Precision make),with 1x56/0.3(4sq.mm.) single core stranded "FR" PVC insulated & unsheathed copper wire for ECC to light Points including necy., fittings as required along with S/F of GI/"FR" PVC looping box approved by EIC. <b>Location: 2KPD Shed.</b>	800	Mtr		
61	Distribution wiring in 1.1 KV single core stranded 'FR' PVC insulated & unsheathed copper wire (Approved make ) of sizes 2 x 36/0.3(2.5 sqmm ) + 1 x 22/0.3 (1.5 sqmm ) ECC in 20 mm size PVC rigid conduit 'FR' (Precision make ) incl. necy. Fittings as required. (DB to Switch Board.) <b>Location:11KPD Shed.</b>	700	Mtr		
62	Supplying and delivery Sheet Steel 11-18A, 240V, DOL Starter switches.	13	Nos.		
63	Installation of the DOL starter on wall with suitable arrangement. <b>Location: 2KPD Shed.</b>	13	Nos		
64	Supply and delivery of outdoor type Luminaries (Approved Brand) with pressure die cast Aluminium housing POT optics reflector and polycarbonate cover (IP65) with one SON-T 250watt lamp and inclusive of electrical components like Ballast & Starter, accessories etc. which are necessary to operate the lamp. <b>Location: 2KPD Shed (Yard/Q-line).</b>	09	Nos.		
65	Installation and Commissioning of above outdoor type Luminaries complete with all accessories to be fixed/ projected from wall of the building incl. by suitable GI pipe making holes/ providing clamping arrangement & necy.GI reducer as required. S&F suitable size & length with suitable bend. S&F necessary length of 1.5sq.mm. PVC insulated single core stranded anneal copper wire and making connection as required and mending good damages to wall. <b>Location: Yard Ltg(East &amp; South)</b>	09	Nos.		
66	Supply and delivery of outdoor type flood Luminaries(Approved Brand) with pressure die cast aluminum housing and heat resistance toughened flat glass (IP-65)complete with single CG Box and two nos. SON-T <b>400W lamp</b> , the optical components to distribute the light from lamp and the electrical components Ballast, Starter which are necessary to operate the lamp. <b>Location: North side of 2KPD Shed.</b>	04	Nos.		



67	Installation and Commissioning of above outdoor type Luminaries complete with all accessories to be fixed / projected from wall of the building incl. supply of suitable G.I. pipe making holes/providing clamping arrangement & necessary GI reducer as required. S&F necy. Length of 2.5 sq.mm. PVC insulated single core stranded annealed copper wire and making connection as required and mending good to wall.	04	Nos.		
68	Supply and delivery of indoor Industrial <b>80W LED</b> high bay luminaries, Power coated high pressure die-cast Aluminium housing, LED driver compartment, Eye bolt provided for suspension mounting, LED fixed on die-cast aluminum heat sink for proper thermal management, Secondary lens optics provided, Driver (constant voltage constant current SMPS, operating voltage range 100-300V, AC, provided with open and short circuit protection and input surge voltage protection), Completely prewired with accessories up to terminal block and IP66 protection. Complete lighting unit, with electrical components which are necessary to operate the lamps. <b>Location: Inside Shed of 2KPD.</b>	52	Nos.		
69	Installation and Commissioning of above Indoor Industrial <b>80W LED</b> high bay Luminaries complete with all accessories to be fixed from Ceiling Structure of inside Shed by suitable arrangement and electrical wiring with PVC insulated & unsheathed single core stranded copper wire "FR" in PVC "FR" Rigid Conduit wiring from loop box incl. clamping arrangement & necy. Fittings etc. as necessary.	52	Nos.		
70	Supply and delivery of Indoor Industrial Integral well glass luminaries (Brand approved by EIC) complete lighting unit, consisting of one SON-E <b>150W lamp</b> with electrical components Ballast & Starter which are necessary to operate the lamps. <b>Location: P/F of 2KPD Shed.</b>	09	Nos.		
71	Installation Commissioning of above Indoor type Integral well glass luminaries complete with all accessories to be fixed from Ceiling Structure of inside Shed by suitable arrangement and electrical wiring with PVC insulated & unsheathed single core stranded "FR" copper wire in "FR" PVC rigid conduit from loop box incl. clamping arrangement & necessary fittings as necy.	09	Nos.		
72	Supply and delivery of Timer-Contactor unit	09	Nos.		
73	Installation and Commissioning of Timer-Contactor unit in a sheet steel ccesso with suitable arrangement for controlling platform and Yard light. <b>Location: 2KPD Shed and 11KPD Shed.</b>	09	Nos.		
74	Wiring from SDB to SB with supplying and drawing 1.1KV single core stranded "FR" PVC insulated & unsheathed 2x36/0.3(2.5sq.mm.)+ 1x22/0.3(1.5 sq.mm.) ECC copper wire (Brand approved by EIC) in suitable size PVC rigid conduit "FR" (Precision make) incl. necy. Fittings as required. <b>Location: 2KPD Shed Office.</b>	100	Mtr		

75	Distribution wiring with supplying and drawing 1.1KV grade 2x22/0.3(1.5sqmm)single core stranded FR PVC insulated & unsheathed copper wire (Brand approved by EIC) in suitable size PVC rigid conduit "FR" (Precision make), with 1x22/0.3 (1.5sqmm) single core stranded "FR" PVC insulated & unsheathed copper wire for ECC, to light/fan/call bell points with Modular type switch (Brand approved by EIC) fixed on Modular GI switch board with top cover plate and 2no. suitable size 'Ph&N' copper bar & earthing attachment fixed on wall incl. mending good damages to original finished. Average run 6mtr. <b>Location: 2KPD Shed Office.</b>	10	Points		
76	Distribution wiring in 2x 22/0.3(1.5sq.mm.) single core strandewd 'FR' PVC insulated & unsheathed copper wire (brand approved by EIC) in 20mm size PVC rigid conduit"FR" (Precision make) with 1x22/0.3 (1.5 sq.mm.)single core stranded 'FR' PVC insulated & unsheathed copper wire for ECC, to light/fan points with Piano Key type switches fixed on sheet metal (16SWG) switch board with Bakelite/ Perspex top cover3mm thick and mending good the damages to the original. Avg. run 12 mtr. <b>Location:11KPD Shed.</b>	250	Points		
77	Distribution wiring with supplying and drawing 1.1KV grade 22/0.3(1.5 sq.mm.)single core stranded "FR" PVC insulated & unsheathed copper wire (Brand as approved by EIC) in 20mm size PVC rigid conduit "FR" (Precision make), with 1.1KV grade 1x22/0.3(1.5 sq.mm.) single core stranded "FR" PVC insulated & unsheathed copper wire as ECC, to 5A 3pin plug socket & Piano Key type switch fixed on MS CRC sheet metal (16SWG) switch board cum JB on wall incl., Bakelite/ Perspex top cover 3mm thick and incl. painting the MS box and mending good the damages to original finish. (On Board.) <b>Location: 2 KPD Shed Office.</b>	02	Nos.		
78	Distribution wiring from SDB to 15A Plug Point with supplying and drawing 1.1KV 2x36/0.3(2.5sq.mm.) single core stranded "FR" PVC insulated & unsheathed copper wire (Brand approved by EIC) in suitable size PVC rigid conduit "FR"(Precision make) with 1x22/0.3 (1.5sq.mm.) single core stranded "FR" PVC insulated & unsheathed copper wire for ECC incl. necy. Fittings as required. <b>Location: 2KPD Shed Office</b>	100	Mtr		
79	Supply and delivery of 240V, 15A, Piano Key type switch and 6 pin 5/15A combined switch socket unit (approved make)	04	Nos.		
80	Installation of the above item on sheet metal switch board having Bakelite/perplex top cover. <b>Location: 2KPD Shed Office.</b>	04	Nos		
81	Distribution wiring in 1.1 KV single core stranded 'FR' PVC insulated & unsheathed copper wire(Approved make ) of sizes 2 x 56/0.3 (4sqmm ) + 1 x 36/0.3 (2.5 sqmm ) ECC in 20 mm size PVC rigid conduit 'FR' (Precision make ) incl. necy. Fittings as required. (DB to Power Plug Socket for Scanner machines.). <b>Location: 11KPD Shed.</b>	100	Mtr.		

82	Supply and delivery of Indoor <b>20W LED Tube light</b> white luminaries complete lighting unit, consisting of LED lamp with inbuilt driver which are necessary to operate the lamp. <b>Location: 2KPD Shed Office.</b>	06	Nos.		
83	Installation & Commissioning of above surface mounted luminaries with all accessories by fixing directly on wall/ ceiling/ HW round block and suitable size of fastener.	06	Nos.		
84	Supply and delivery of <b>1200mm ceiling fan</b> complete with blade, canopy.	105	Nos.		
85	Supply & Delivery of <b>stepped electronic fan regulator.</b>	105	Nos.		
86	Installation & Commissioning of the fan with electronic fan regulator. <b>Location:2KPD Shed Office.</b>	05	Nos.		
87	Installation of ceiling fan complete with blade, regulator, canopy etc. with MS down rod of minimum length 1.5 Mtr. or as required as per site condition& making necessary connection. <b>Location:11KPD Shed Office.</b>	100	Nos.		
88	Shifting & Re-installation of existing 4x180AH rating battery installed inside the KPD (west) Substation room.Necessary connection to be carried out similar to the existing system. <b>Location: KPD west, Sub-Station.</b>	01	No.		
89	Supply and delivery of suitable size of sheet metal enclosure for the purpose of existing 4x180AH lead acid battery installed in the room of Sub Station. <b>Location: KPD West Sub-Station.</b>	01	No.		
90	Supply and delivery of Indoor LED recess mounted / suspended <b>20W LED Tube light</b> White luminaires complete lighting unit, consisting of LED lamp with inbuilt driver which are necessary to operate the lamp.	130	Nos.		
91	Installation of above indoor LED luminaire on false ceiling with necessary arrangement or with suitable size of down rod from the ceiling. <b>Location: 11KPD Shed.</b>	130	Nos.		
92	Supply of 23 watt CFL lamp.	10	Nos.		
93	Installation of above CFL with accessor holder. <b>Location: 11KPD Shed.</b>	10	Nos.		
94	Supply and delivery of outdoor type Luminaires (Approved Brand) with pressure die cast aluminium housing POT optics reflector and polycarbonate cover (IP65) with one SON-T 250watt lamp and inclusive of electrical components like Ballast, & Starter, ccessories etc. which are necessary to operate the lamp. <b>Location: Yard/Q-line of 11KPD.</b>	15	Nos.		
95	Installation and Commissioning of above outdoor type luminaires complete with all accessories to be fixed/projected from wall of the building incl. making holes/providing clamping arrangement & necy. GI reducer as required.S&F suitable size of GI Pipe (ISI-Medium) quality having suitable length &bend S&F necy, length of 2.5sqmm PVC insulated single core stranded wire from loop box and making connection as required and mending good damages to wall incl. painting.	15	Nos.		

96	Supply and delivery of outdoor type Luminaires (Approved Brand) with pressure die cast aluminium housing POT optics reflector and polycarbonate cover (IP65) with one SON-T 250watt lamp and inclusive of electrical components like Ballast, & Starter, ccessories etc. which are necessary to operate the lamp. <b>Location: Yard/Q-line of 11KPD.</b>	12	Nos.		
97	Installation and Commissioning of above Integral well glass fitting with necessary arrangements.	12	Nos.		
98	Supply and fixing of approved GI waterproof type looping cable box suitable size having 4mm thick with rubber gasket etc. comprising of one 250V,15A Kit-Kat fuse unit with terminal and 4Pole/2Pole, as necy., mending good damages and painting. <b>Location: 11KPD Shed.</b>	27	Nos.		
99	Supply, delivery of wall mounted Joint Box suitable for 3.5 Core 240 sqmm XLPE cable.	1	No		
100	Installation of the above joint box	1	No		
101	Supply, delivery of wall mounted Joint Box suitable for 3.5Core 70 sq mm XLPE cable.	1	No		
102	Installation of the above joint box	1	No		
103	Earthing with 50mm. Dia. GI pipe ISI Medium 3.64mm thick, 3.04 mtrs long and 1x4SWG GI earth wire (4 mtrs. Long),13mm dia x 80mm long GI nuts and bolts, double washer, incl. S&F 15mm dia GI pipe protection (1 mtr. long) to be filled with bitumen partly under the ground level and partly above ground level driven to an average depth of 3.65 mtrs. below the ground level including providing necessary masonry enclosure of overall size 86.36cm x 86.36cm x 46cm deep (below the ground level ), CI hinged inspection cover of size 36.56cmx36.56cm and treating of soil by using salt and charcoal as required. Earthing work is to be carried out as per relevant IS. <b>Location: 2KPD and 11KPD.</b>	12	Nos.		
104	Connecting the earth station to earth bus bar at electrical panel room inclusive of S&F 50mm x 6mm Galvanized (Hot Dip) MS flat under the ground level/on wall/floor with GI saddle as required inclusive drilling holes, bolts, nuts, washers etc. and mending good the damages as required. <b>Location: 2 KPD &amp; 11 KPD.</b>	180	Mtrs.		
105	S&F earth bus bar of galvanized(hot dip) MS flat 50mm x 6mm on wall having clearance of 6mm from wall including providing bolts, nuts, washers, spacing insulator etc. <b>Location: 3nos for 2KPD and 3nos. for 11KPD.</b>	06	Mtrs.		
106	Connecting the equipments body to earth bus bar including S&F GI(hot dip) wire of size 8SWG on wall/floor with staples buried inside wall / floor as required and making connection to the equipments with bolts, nuts, washers, cable lugs etc. as required and mending good the damages.	1000	Mtrs.		

107	Dismantling of existing LT Panel, old cable and existing installation/ wiring / light fittings/fan/ accessories etc. Dismantling of old cable/ Sodium Vapour light fittings including lamp/ Fans are to be handed over to Exe. Engr.(Elect) KPD. <b>Location: Both 2KPD Shed &amp;11KPD Shed.</b>	1	Lot		
	<b>Sub-Total:</b>				
108	<b>Less: Buy Back of LT bus bar</b> , one lot of LT Panel/ switches, old cables and electrical fittings except Sodium Vapour light fittings including lamp/Fans.	L.S.			
	<b>Grand Total</b>				

**Note:**

- (i) The quantity above may increase or decrease as per requirement, for which payment will be made as per actual.
- (ii) The rate quoted by the tenderer/firm should be considered to complete the work in all respect and should be exclusive of GST or any statutory levies and or other charges levied by any central/state/local authorities.
- (iii) GST and any other extra charges/statutory levies will be paid extra at applicable rates at the time of supply of goods and services.

KOPT

=====

**Profile of Tenderer / FORM –D****E-Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

This is to confirm that we agree to abide by all the terms and conditions of this NIT No. **KoPT/ KDS/ Mech/SE-I/ADV/458 dated 13.11.2017**, those mentioned in the “General Conditions of Contract” enclosed with this Tender Document as well as decisions taken in the pre-bid techno-commercial conference, if any.

Our relevant particulars are furnished hereunder:

Particulars	To be filled in by the Tenderer or to be mentioned as “none ”
Name of the Tenderer	
Name of the owner(s) of the Tenderer	
Full postal address of the Tenderer including Police Station	
Telephone No. of the Tenderer	
Fax No. of the Tenderer	
E-mail ID of the Tenderer	
Name of the contact person of the Tenderer	
Mobile/land line Telephone No. of the contact person of the Tenderer.	
Name of the partners/directors/ members, as applicable, in this particular contract	
Name of their authorized representative(s) who would handle the contract on their behalf.	

**[DOCUMENT TO BE DOWNLOADED, FILLED IN UNDER BIDDER'S LETTERHEAD,  
SIGNED, SCANNED AND UPLOADED]**

**Covering Letter**

Ref. No.....

Date

The Chief Mechanical Engineer,  
Kolkata Port Trust,  
Mechanical and Electrical Engineering Department,  
8, Garden Reach Road,  
Kolkata – 700 043

Dear Sir,

1. We, .....(Name of Tenderer) having examined the Tender Document and understood its contents, hereby submit our Tender for ..... ( NIT No. KoPT/KDS/Mech/SE-I/ADV/..... dated. ....) and confirm that we unconditionally accept all the terms and conditions of the same including the Addendum (if issued).

2. All information and proofs provided in the Tender including Addendum and in the Appendices are true and correct and all documents accompanying such tender are true copies of their respective originals.

3. We shall make available to Kolkata Port Trust (hereinafter referred to as KoPT) any additional information it may find necessary or require to supplement or authenticate the Tender.

4. We, .....(Name of Tenderer) hereby undertake that we will abide by the decisions of KoPT in the matter of examination, evaluation and selection of Successful Tenderer and shall refrain from challenging or questioning any decision taken by KoPT in this regard. We further acknowledge the right of KoPT to reject our tender without assigning any reason or otherwise and hereby waive our right to challenge the same on any account whatsoever.

5. We also certify the following

(a) We have not been debarred by the Central/State Govt. or any entity controlled by them or any other legal authority from participating in any Tender/Contract/Agreement of whatever kind.

(b) We have also not been expelled from any project or contract nor have had any contract terminated for breach in the last 3 years ending on the date of opening of the techno commercial part of the tender.

6. We declare that:

(a) We have examined and have no reservations to the Tender Document, including the Addendum, if any, issued by KoPT thereon.

(b) We hereby certify that we have taken steps to ensure that no person acting for us or on our behalf will engage in any corrupt, fraudulent or coercive practices to influence the evaluation process of the tender.

7. We understand that KoPT reserves the right to accept or reject any tender and to annul the tendering process and reject all tenders at any time without any liability or any obligation for such acceptance, rejection or annulment without assigning any reason thereof.

Yours faithfully,

Signature of Tenderer.....

Name: .....

Designation: .....

Date : .....

Seal of the tenderer.....



**KOLKATA PORT TRUST**  
**SCHEDULE – “O”**

Tenderers must fill in the undernoted column :

Sl. No	Full particulars of similar works carried out by Tenderer	Value of work	Contract for completion time	Actual completion time	Name and Addresses of Authorities for whom work was carried out	Name and Addresses to whom reference can be made

**SCHEDULE – “O”**  
**Sheet – 2**

The Tenderers are also requested to furnish the following particulars :

**A. In case of a Limited Company:**

1. Name of the Company :
2. Address of its present registered office :
3. Date of its incorporation :
4. Full name and address of each of its Directors – any special particulars as to Directors if desired to be stated :
5. Name, address and other necessary particulars of Managing Agents, if any, appointed by the Company :
6. Copies of Memorandum and Articles of Association (with the latest amendments, if any) :
7. Copies of audited Balance Sheets of the Company for the last three years. :

**SCHEDULE – “O”**

**SHEET – 3**

**B. In case of a Firm :**

1. Name and address of the firm :
2. When business started :
3. If registered, a certified copy of Certificate of Registration :
4. A certified copy of the Deed Of Partnership :
5. Full name and address of each of the Partners and the interest of each partner in the Partnership. Any special particulars as to Partners if desired to be stated :
6. Whether the firm pays income tax over Rs.10, 000/- per year :

**SCHEDULE – “O”**

**SHEET – 4**

**C. In case of an Individual :**

1. Full name and address of the Tenderer; any special particulars of the Tenderer if desired to be stated :
2. Name of the father of the Tenderer :
3. Whether the Tenderer carried on business in his own name or any other name :
4. When business was started any by whom :
5. Whether any other person is interested in the business directly or indirectly, if so, name, address, etc. of such persons and the nature of such interest. :
6. Whether the Tenderer pays income tax over Rs.10,000/- per year :

DATED, the.....

Signature of Tenderer

**E- Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

**FORMAT OF AFFIDAVIT  
On the Rupees Ten Non – Judicial Stamp Paper**

**BEFOR THE 1<sup>ST</sup> CLASS JUDICIAL MAGISTRATE AT-----**

**AFFIDAVIT**

I ----- son of ----- aged about -----  
-Years , by faith ----- , by occupation -----, residing at-----  
-----  
do hereby solemnly affirm and declare as follows:-

1. That I am the proprietor/Partner of ----- having office at -----  
and carrying on business on the said name and style.

(In case the above Deponent is an enlisted Contractor at Kolkata Port Trust, the same should be mentioned in affidavit.)

2. THAT my aforesaid Firm is exempted from E.S.I. Act and the said Firm has no valid E.S.I Registration.
3. THAT the present affidavit is to be files before the Kolkata Port Trust as per the clause no -----  
----- of Tender no-----issued by Kolkata Port Trust in respect of the work (the name of the work is to be mentioned)  
That the statements made above are all true to be the best of my knowledge and belief.

That in the event the declaration is found to be wrong and false, I will be held responsible for all the consequences in respect of compliance of The Employees State Insurance Act, 1948

DEPONENT

Identified by me

**E- Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

(FORMAT OF INDEMNITY BOND)  
**On the Rupees Fifty Non – Judicial Stamp Paper**

**I N D E M N I T Y   B O N D**

By THIS BOND I, Shri/Smt-----, son of Shri/Smt-----

Residing at ----- by occupation -----the Partner/Proprietor/Director  
-----having office at ----- am a tenderer under Mechanical Engineering  
Department, Kolkata Port Trust(A statutory body under MPT Act, 1963)

- 2 WHEREAS , the said Kolkata Port Trust asked the every tenderer, who is not covered under E.S.I Act or exempted to furnish an Indemnity Bond in favour of Mechanical Engineering Department, Kolkata Port Trust against all damages and accident to the Labourer Tenderer/contractor.
- 3 NOW THIS BOND OF INDEMNITY WITNESSTH THAT the Tenderer/contractor named herein above shall indemnify the Kolkata Port Trust AGAINST ALL DAMAGES AND ACCIDENT OCCURRING TO THE Labourers of the Tenderer/contractor as demanded by the Kolkata Port Trust and which shall be legal and /or claimed by the Kolkata Port Trust during the execution of the work stated in the NIT No----- of -----
- 4 AND the contractor hereunder agree to indemnity and at all times keep indemnified the Kolkata Port Trust and its administrator and representative.
5. And also all such possible claim or demand for damages and accidents. In the event the declaration is found to be wrong and false, the tenderer will be held responsible for all the consequences in respect of compliance of The Employees State Insurance Act, 1948.

In WITNESS WHEREOF I-----, the Partner/Proprietor/Director----- Hereto set  
and seal this the----- Day of-----  
In the year----- at-----

**Sureties**

Signature of the Indemnifier

1      Signature  
         Name:-  
         Address

2      Signature  
         Name:-  
         Address

**3      Witness**

Signature  
Name:-  
Address

**ANNEXURE –I**

**E-Tender No. KoPT/Kolkata Dock System/CME/26/17-18/ET/410**

**[DOCUMENT TO BE DOWNLOADED, FILLED IN UNDER BIDDER'S LETTERHEAD,  
SIGNED, SCANNED AND UPLOADED]**

**Undertaking to be submitted in lieu of uploading/submitting signed copy of full tender  
document**

Ref. No.....

Date .....

The Chief Mechanical Engineer,  
Kolkata Port Trust,  
Mechanical and Electrical Engineering Department,  
8, Garden Reach Road,  
Kolkata – 700 043

Dear Sir,

We, .....(Name of Tenderer) have fully read and understood the entire Tender Document, GCC, and Addenda, if any, downloaded from the instant e-tender and no other source, and will comply to the said Tender document, GCC and Addenda.

We are submitting this undertaking in lieu of submission of signed copy of the full Tender document.

Yours faithfully,

Signature of Tenderer.....

Name: .....

Designation: .....

Date : .....

Seal of the tenderer.....

## **KOLKATA PORT TRUST**



**MECHANICAL & ELECTRICAL ENGINEERING DEPARTMENT  
8, Garden Reach Road, Kolkata – 700 043.**

---

KOPT

---

### **GENERAL CONDITIONS OF CONTRACT**

### **FORMS AND AGREEMENTS**

**SANCTIONED BY TRUSTEES UNDER RESOLUTION NO. 92  
OF  
THE 6<sup>TH</sup> MEETING HELD ON 27<sup>TH</sup> MAY, 1993.**

**(Copy of Booklet Published on May, 1993)**

---



## 1. DEFINITIONS

- 1.0. In the contract, as here-in-after defined, the following words and expressions shall have the meaning here-in assigned to them, except where the context otherwise required.
- 1.1. **"Employer"** or "Board" or "Trustees" means the Board of Trustees for the Port of Kolkata, a body corporate under Section 3 of the Major Port Trust Act, 1963, including their successors, representatives and assigns.
- 1.2. **"Chairman"** means the Chairman of the Board and includes the person appointed to act in his place under Sections 14 and 14A of the Major Port Trusts Act, 1963.
- 1.3. **"Contractor"** means the person or persons; Firm or Company whose tender /offer has been accepted by the Trustees and includes the Contractor's representative's heirs, successor and assigns, if any permitted by the Board / Chairman.
- 1.4. **"Engineer"** means the Board's official who has invited the tender on its behalf and includes the Chief Engineer, the Chief Mechanical Engineer, the Senior Executive Engineer the Chief Hydraulic Engineer, the Deputy Chief Engineer, the Deputy Chief Mechanical Engineer, the Senior Resident Engineer, The Manager (Infrastructure & Civic Facilities), the Manager (Plant & Equipment) the Deputy Manager ( Infrastructure & Civic Facilities) and the Deputy Manager (Plant & Equipment), or other official as may be appointed from time to time by the employer, with written notification to the Contractor, to act as Engineer for the purpose of the contract, in place of the "Engineer" so designated.
- 1.5. **"Engineer's Representative"** means any subordinate Engineer or Assistant to the Engineer or any other official appointed from time to time by the Engineer to perform the duties set forth in Clauses 2.4 to 2.6 hereof.
- 1.6. **"Work"** means the Work to be executed in accordance with the Contract and includes authorized "Extra Works" and "Excess Works" and Temporary Works.
- 1.7. **"Temporary Works"** means all temporary works of every kind required in or about the execution, completion or maintenance of the works and includes (without thereby limiting the foregoing definitions) all temporary erections, scaffolding, ladders, timbering, soaking vats, site offices, cement and other god owns, platforms and bins for stacking building materials, gantries, temporary tracks and roads, temporary culverts and mixing platforms.
- 1.8. **"Extra Works"** means those works required by the Engineer for completion of the Contract which were not specifically and separately included in the schedule of items of works (i.e., Bills of Quantities) of the tender. "Excess Works" means the required quantities of work in excess of the provision made against any item of the Bill of Quantities.
- 1.9. **"Specifications"** means the relevant and appropriate Bureau of Indian Standard's Specifications (latest revisions) for materials and workmanship unless stated otherwise in the Tender.
- 1.10. **"Drawings"** means the drawings referred to in the Tender and specification and any modification of such drawings approved in writing by the Engineer and such other drawings as may from time to time be furnished or approved in writing by the Engineer.
- 1.11. **"Contract"** means and includes the General and Special Conditions of Contract, Specifications, Drawings, priced Bill of Quantities, the Tender/ Offer, the letter of acceptance of the Tender/Offer, the Contract Agreement if separately entered into and the Schedule of Rates and Price, if any, adopted by the Trustees at their discretion.
- 1.12. **"Constructional Plant"** means all appliances or things of whatsoever nature required in or about the execution, completion or maintenance of the works or temporary works and includes (without thereby limiting the foregoing definition) all machinery and tools but does not include materials or other things intended to form or forming part of the permanent work.
- 1.13. **"Site"** means the land and other places, on, under, in or through which the works are to be executed or carried out and any other lands or places provided by the Trustees for the purpose of the Contract.
- 1.14. **"Contract Price"** means the sum named in the letter of acceptance of the Tender/ Offer of the Contractor, subject to such additions thereto and deduction there from as may be made by the Engineer under the provisions here-in-after contained.
- 1.15. **"Month"** means English Calendar Month.
- 1.16. **"Excepted risks"** are riot in so far as it is uninsurable, war, invasion, act of foreign enemies, hostilities (whether war be declared or not) Civil War, rebellion, revolution, insurrection or military or usurped power or use or occupation by the Trustees of any portion of the works in respect of which a certificate of completion has been issued (all of which are herein collectively referred to as the excepted risks)
- 1.17. Word importing the **singular** only, also includes the **plural** and vice-versa where the context so required.
- 1.18. The **headings and marginal notes** in these General Conditions of Contract shall not be deemed to be part thereof or be taken into consideration in the interpretation or construction thereof or of the contract.
- 1.19. Unless otherwise stipulated the word "Cost" shall be deemed to include overhead costs of the contractor, whether on or off the site.

## **2. DUTIES & POWERS OF ENGINEER & ENGINEER'S REPRESENTATIVE**

- 2.0. The Contractor shall execute, complete and maintain the works in terms of the contract to the entire satisfaction of the Engineer and shall comply with the Engineer's direction on any matter whatsoever.
- 2.1. The Contractor shall take instructions from the Engineer and subject to limitation of Clause 2.5 herein, from the Engineer's Representative
- 2.2. The Engineer shall have full power and authority
- (a) to supply to the contractor from time to time during the progress of the works such further drawings and instructions as shall be necessary for the purpose of proper and adequate execution and maintenance of the works and the contractor shall carry out and be bound by the same.
  - (b) to alter or modify the specification of any material and workmanship and to inspect the work at any time.
  - (c) to order for any variation, alternation and modification of the work and for extra works.
  - (d) to issue certificates as per contract
  - (e) to settle the claims & disputes of the Contractor and Trustees, as the first referee.
  - (f) to grant extension of completion time.
- 2.3. The Engineer's representative shall:
- (a) watch and supervise the works,
  - (b) test and examine any material to be used or workmanship employed in connection with the work.
  - (c) have power to disapprove any material and workmanship not in accordance with the contract and the contractor shall comply with his direction in this regard.
  - (d) take measurements of work done by the contractor for the purpose of payment or otherwise.
  - (e) order demolition of defectively done work for its reconstruction all by the Contractor at his own expense,
  - (f) have powers to issue alteration order not implying modification design and extension of completion time of the work and
  - (g) have such other powers and authorities vested in the Engineer, which have been delegated to him in writing by the Engineer under intimation to the Contractor.
- 2.4. Provided always that the Engineer's Representative shall have no power:
- (a) to order any work involving delay or any extra payment by the Trustees,
  - (b) to make variation of or in the works and
  - (c) to relieve the Contractor of any of his duties or obligations under the Contract.
- 2.5. Provided also as follows:
- (a) Failure of Engineer's Representative to disapprove any work or materials shall not prejudice the power of the Engineer thereafter to disapprove such work or materials and to order the pulling down, removal, braking-up thereof and re-construction at the contractor's cost and the contractor shall have no claim to compensation for the loss sustained by him.
  - (b) If the contractor shall be dissatisfied by reason of any decision of the Engineer's Representative, he shall be entitled to refer the matter to the Engineer who shall thereupon confirm, reverse or vary such decision.
  - (c) Any written instructions or written approval given by the Engineer's Representative to the contractor, within the terms of delegation of power and authority vested in Engineer to his Representative in writing shall bind the contractor and the Trustees as though it had been given by the Engineer, who may from time to time make such delegation. Contractor and the Trustees as though it had been given by the Engineer, who may from time to time, make such delegation.

## **3. THE TENDER / OFFER AND ITS PRE-REQUISITES**

- 3.0. The Contractor shall, before making out and submitting his tender / offer be deemed to have inspected and examined the site, fully consider all factors, risks and contingencies, which will have direct and in direct impact on his expenses and profit from the work and shall be specifically deemed to have taken the following aspects into consideration:
- (a) The form and nature of the site and its surroundings including their sub-surface, hydrological, tidal and climate conditions, the means of access to the site and all other local conditions including the likely charges and costs for temporary way-leave, if any, required for the work.
  - (b) The drawings, specifications, the nature and extent of work to be executed and the quality, quantity and availability of the required materials and labour for the work and the need to execute the work to the entire satisfaction of the Engineer, and also by complying with the General and Special Conditions of Contract.
  - (c) The accommodation required for the workmen and site office, mobilization / demobilization and storage of all plant, equipment and Construction materials.

- (d) The sources and means of procurement of water for drinking, washing and execution of work, and source and availability of electrical power, all of Contractor's cost.
- (e) Payment of taxes and duties and compliance of all applicable statutes, ordinances and law together with the rules made there under, the rules, regulations and bye-laws of public bodies or any local or other authority by the Contractor, keeping the Trustees indemnified against penalties and liabilities of every kind arising from the Contractor's failure in such compliance.
- (f) Payment of all kinds of stamp-duty for exacting the agreement or for any legal instrument including Bank Guarantees and Indemnity Bonds.
- 3.1. The Contractor's tender shall be in ink on the Tender Forms supplied by the Trustees, unless stipulated otherwise in the Notice-Inviting the Tender and shall be faultless in figures and free from erasing. Corrections, if any, shall only be made by scoring out and initialing of the revised figure.
- 3.2. If required by the Engineer or the Trustees, the Contractors in their tender or subsequently, shall disclose the names of their owners/partners/Share Holders at the required points of time. The failure in this regard shall be treated as a breach and a contract, if entered into, shall be liable to be cancelled.
- 3.3. (a) Unless other wise stipulated in the Notice Inviting the Tender/Offer, every tender must be submitted with Earnest Money of the amount calculated as per the following scale.

Estimated Value	Amount of Earnest Money	
	For works contract.	For contract of supplying materials of equipment only
Up to Rs.1,00,000/-	5% of the estimated value of work	1% of the estimated value of work.
Over Rs. 1,00,000/-	2% of the estimated value of work subject to a maximum of Rs.20,000/- and minimum of Rs. 5,000/-	1/2% of the estimated value of work subject to a maximum of Ts. 10,000/- and minimum of Rs. 1,000/-

(b) Earnest Money shall be deposited with Trustees' treasurer in cash or by Banker's Cheque of any Kolkata Branch of a Nationalized Bank of India drawn in favour of Kolkata Port Trust or in the form of an "Kolkata Port Trust" and payable at Kolkata / Haldia Holding as the case may be and the receipt granted there for be kept attached to the Tender / offer in the Sealed Cover.

(c) Earnest Money of un-accepted tender shall be refunded without any interest through A/c. Payee Cheque drawn on a Nationalized Bank of Kolkata / Haldia.

(d) The enlisted (registered) Contractors of the Trustees, who have deposited fixed Security with the Trustees FA & CAO / Manager (Finance) according to his Class of Registration, shall be exempt from depositing the Earnest Money, as per the following scale:

	Class of Registration	Amount of Fixed Security	Financial limit of each tender
(e)	A	Rs. 10,000/-	Any tender priced up to Rs. 2,00,000/-
	B	Rs. 5,000/-	Any tender priced up to Rs.1,00,000/-
	C	Rs. 2,500/-	Any tender priced up to Rs.50,000/-

- (i) Tender submitted without requisite Earnest Money may be liable to rejection.
- (ii) If before expiry of the validity period of his Tender / offer, the tender amends his quoted rates or tender/ offer making them unacceptable to the Trustees and / or withdraws his tender / offer, the Earnest Money deposited shall be liable to forfeiture of the option of the Trustees.
- (f) The Earnest Money of accepted Tender / offer shall be retained by the Trustees as part of the Security Deposit, for which a separate Treasury Receipt shall be issued to the Contractor after cancellation of the previous Receipt of Earnest Money.
- (g) Balance security for works contract shall be recovered by deduction from all progressive Bill (including final Bill, if necessary) @ 10% of the gross value of work in each such bill, so that the total recovery may not exceed the quantum computed as per the under noted percentages of the total value of work actually done up to the stage of completion.

Value of Work	% of Security Deposit for works contract	% of Security Deposit for Contract of supplying materials and equipments only
For works up to Rs. 10,00,000/-	10% (Ten percent )	1% ( One percent )
For works costing more than Rs.10,00,000/- and up to Rs.20,00,000/-	10% on first Rs. 10,00,000/- + 7 1/2% on the balance	1% on first Rs.10,00,000/-+1/2% on the balance
For works costing more than Rs.20,00,000/-	10% on first Rs. 10,00,000/- + 7 1/2% on next Rs.10,00,000/-+ 5% on the balance	1% on first Rs.10,00,000/-+1/2% on next Rs.10,00,000/-+ 1/4% on the balance

- (h) Balance Security for Contract of supplying materials and equipment computed in terms of the percentages given above, shall have to be deposited with the trustees' Treasurer in advance and within 30 days from the date of placement of supply order, either in cash or by A/c. Payee Draft of a Nationalized Bank of India drawn in favour of Kolkata Port Trust and payable at Kolkata / Haldia, as the case may be.
- (i) No interest shall be paid by the trustees to the Tenderer / Contractor on the amount of Earnest Money / Security Deposit held by the Trustees, at any stage.

3.4.

- (i) The Security Deposit shall be refunded to the Contractor in terms of Clause 9.3 hereinafter and subject to deduction, if any, under the provision of Sub-Clause 3.5(ii) herein below. If, however, the contract provides for any maintenance period, 50% of the Security Deposit may be refunded against any of the Treasury Receipt for that amount on expiry of half of the maintenance period and the balance deposit on the said maintenance period and after the Engineer has certified the final completion of work in form G.C.2 and the Contractor has submitted his "No Claim" Certificate in form G.C.3.
- (ii) The Security Deposit/Earnest Money may be liable to forfeiture at the option of the Trustees, if the Contractor fails to carry out the work or to perform/observe any of the conditions of the contract. The Trustees shall also be at liberty to deduct any of their dues from the Security Deposit, fixed Security, Earnest Money or from any sum due or to become due to the Contractor under any other contract.

3.5. If stipulated in the contract as a Special Condition, the Contractor shall have to submit to the Engineer a performance Bond in the form of an irrevocable guarantee from Kolkata/Haldia Branch, as the case may be, of any Nationalized Bank of India in the proforma annexed hereto and for the sum and period as mentioned in the letter of acceptance of the Tender/Offer, within 15 days from the date of such letter, failing which the contract shall be liable to be terminated and the Earnest Money are liable to forfeiture; all at discretion of the Engineer. The cost of obtaining this or any other Bank Guarantee and/or the revalidation thereof, wherever required, has to be borne by the Contractor and it shall be his sole responsibility to arrange for timely revalidation of such bank guarantee, failing which and for non-fulfillment of any contractual obligation by the Contractor, the Engineer and/or the Trustees shall be at liberty to raise claim against the Guarantee and/or enforce the same unilaterally.

#### 4. THE CONTRACT & GENERAL OBLIGATIONS OF CONTRACTOR

4.0.

- (a) The contract documents shall be drawn-up in English language.
- (b) The contract shall be governed by all relevant Indian Acts as applicable only within the jurisdiction of the High Court at Kolkata, India, including the following Act:
- The Indian Contract Act, 1872.
  - The Major Port Trust, Act, 1963.
  - The Workmen's Compensation Act, 1923.
  - The Minimum Wages Act, 1948.
  - The Contract Labour (Regulation & Abolition) Act, 1970.
  - The Dock Workers' Act, 1948.
  - The Indian Arbitration Act (1940) (in the case of a definite arbitration Agreement only).

- 4.1. After acceptance of his Tender / Offer and when called upon to do so by the Engineer or his representative, the Contractor shall, at his own expense, enter into and execute a Contract Agreement to be prepared by him in the form annexed hereto. Until such Contract Agreement is executed the other documents referred to in the definition of the term "Contract" here-in-before shall collectively be the Contract.
- 4.2. Several documents forming the contract are to be taken as mutually explanatory of one another. Should there be any discrepancy, ambiguity, omission or error in the various contract documents, the Engineer shall have the power to correct the same and his decision shall be final and binding on the parties to the Contract.

- 4.3. Two copies of the Drawing referred to in the General and Special Conditions of Contract and in the Bill of Quantities, shall be furnished by the Engineer to the Contractors free of cost for his use on the work, but these shall remain the property of the Trustees and hence, the Contractor shall return them to the Engineer or his Representative on completion of the work. if not torn or mutilated on being regularly used at site.
- 4.4. The Contractor shall prove and make at his own expense any working or progress drawings required by him or necessary for the proper execution of the works and shall, when required, furnish copies of the same free of cost to the Engineer for his information and/ or approval, without meaning thereby the shifting of Contractor's responsibility on the engineer in any way whatsoever.
- 4.5. The Contractor shall not directly or indirectly transfer, assign or sublet the Contract or any part thereof without the written permission of the engineer. Even if such permission be granted, the Contractor shall remain responsible (a) for the acts, defaults and neglect of any sub-contractor, his agents servants or workmen as fully as if these were the acts, defaults or neglects of the Contractor himself or his agents, servants or workmen, and (b) for his full and entire responsibility of the contract and for active superintendence of the works by him despite being sublet, provided always that the provision of labourers on a "piece rate" basis shall not be deemed to be subletting under this clause.
- 4.6. Unless otherwise specified, the Contractor shall be deemed to have included in his Tender / Offer all his cost for supplying and providing all constructional plant, temporary work, materials both for temporary and permanent works, labour including supervision thereof transporting to and from the site and in and about the work, including loading, unloading, fencing, watching, lighting, payment of fees, taxes and duties to the appropriate authorities and other things of every kind required for the construction, erection, completion and maintenance of the work.
- 4.7. The Contractor shall be solely responsible for the adequacy, stability and safety of all site operations and methods of construction, even if any prior approval thereto has been taken from the Engineer or his Representative. The Contractor shall not be responsible for the correctness of the design or specification of the Temporary and Permanent works formulated by the Engineer; but the contractor shall be fully responsible for the correct implementation thereof as also for any design and specification prepared / proposed / used by the Contractor.
- 4.8. Whenever required by the Engineer or his Representative, the Contractor shall submit to him the details of his (a) programme for execution of the work, (b) proposed procedure and methods of work, (c) proposed deployment of plant, equipment labour, materials and temporary works. The submission to and/ or any approval by the Engineer or his Representative to any such programme or particulars, shall not relieve the Contractor of any of his obligations under the contract. If for any reason the contractor be unable to adhere to his earlier programme, he shall submit his revised programme for completion of work within the stipulated time whenever asked to do so.
- 4.9. Necessary and adequate supervision shall be provided by the Contractor during execution of the works and as long thereafter as the Engineer or his Representative shall consider necessary during the maintenance period. The Contractor or his competent and authorised agent or representative shall be constantly at site and instructions given to him by the Engineer or his Representative in writing shall be binding upon the Contractor subject to limitation in clause 2.5 hereof. The Contractor shall inform the Engineer or his Representative in writing about such representative/agent of him at site.
- 4.10. The Contractor shall employ in execution of the Contract only qualified, careful and experienced persons and the Engineer shall be at liberty to direct the Contractor to stop deployment of any of his staff, workmen or official at site and the Contractor shall within 48 hours comply with such instruction without any demur, whenever the Engineer shall feel that the deployment of the person concerned will not be conducive to the proper and timely completion of the work.
- 4.11. The Contractor shall be responsible for the true and proper setting-out of the works in relation to reference points/lines/levels given by the Engineer in writing. The checking of any setting-out or of any alignment or level by the Engineer or his Representative shall not in any way relieve the contractor of his responsibility for the correctness thereof and he shall fully provide, protect and preserve all stakes, templates, bench marks, sight rails, pegs, level marks, profile marks and other things used in setting-out the works.
- 4.12. From the commencement of the works till issue of the completion certificate in Form G.C.1, vide Clause 5.12 hereof, the contractor shall take full responsibility for the care thereof. Save for the excepted risks, any damage, loss or injury to the work or any part thereof shall be made good by the Contractor at his down cost as per instruction and to the satisfaction of the Engineer, failing which the Engineer or his Representative may cause the same to be made good by any other agency and the expenses incurred and certified by the Engineer, shall be recoverable from the Contractor in whatever manner the Engineer shall deem proper. This Clause will not apply to that part of the work, which might have been taken over by the Trustees on partial completion of the work and in such case the

Contractor's obligation will be limited to repairs and replacement for manufacturing or construction defects during the Maintenance period (Guarantee Period) as per the directions of the Engineer as also for defects/ damages if any caused to the work by the Contractor during such repairs and replacement in the maintenance period.

- 4.13. The Contractor shall at his own cost protect, support and take all precautions in regard to the personnel or structure or services or properties belonging to the Trustees or not, which may be interfered with or affected or disturbed or endangered and shall indemnify and keep indemnified the Trustees against claim for injury, loss or damage caused by the Contractor in connection with the execution and maintenance of the work to the aforesaid properties, structures and services and/ or to any person including the Contractor's workmen. Cost of Insurance Cover, if any, taken by the Contractor shall not be reimbursed by the Trustees, unless otherwise stipulated in the Contract.
- 4.14. The Contractor shall immediately inform the Engineer's Representative if any fossil, coins, articles of value or antiquity and structures and other remains or things of geological or archaeological importance be discovered at site which shall remain the property of the Trustees and protect them from being damaged by his workmen and arrange for disposal of them at the Trustees expense as per the instruction of the Engineer's Representative.
- 4.15. The Contractor shall be deemed to have indemnified the Trustees against all claims, demands, actions and proceedings and all costs arising there from on account of:
- (a) Infringement of any patent right, design, trade-mark, or name or other protected right, in connection with the works or temporary work.
  - (b) Payment of all royalties, rent, toll charges, local taxes, other payments or compensation, if any, for getting all materials and equipment required for the work.
  - (c) Unauthorized obstruction or nuisance caused by the Contractor in respect of Public or Private road, railway tracks, footpaths, crane tracks, waterways, quays and other properties belonging to the Trustees or any other person.
  - (d) Damage / injury caused to any highway and bridge on account of the movement of Contractor's plants and materials in connection with the work
  - (e) Pollution of waterway and damage caused to river, lock, sea-wall or other structure related to waterway, in transporting contractor's plants and materials.
  - (f) The Contractor's default in affording all reasonable facilities and accommodation as per the direction of the Engineer or his Representative to the workmen of the Trustees and other agencies employed by or with the permission and / or knowledge of the Trustees on or near the site of work.
- 4.16. Debris and materials, if obtained by demolishing any properly, building or structure in terms of the Contract shall remain the property of the Trustees.
- 4.17. The Contractor's quoted rates shall be deemed to have been inclusive of the following :
- (a) Keeping the site free of unnecessary obstruction and removal from site of constructional plant wreckage, rubbish, surplus earth or temporary works no longer required.
  - (b) Cleaning and removal from site all the surplus materials of every kind to leave the site clean and tidy after completion of the work, without which payment against final bill may be liable to be withheld.
  - (c) Precautionary measures to secure efficient protection of Docks, the River Hooghly and other waterways against pollution of whatever nature during execution and maintenance of the works, and to prevent rubbish, refuse and other materials from being thrown into the water by the Contractor's men or those of his agency.
  - (d) Making arrangements for deployment of all labourers and workers, local or otherwise including payment for their wages, transport, accommodation, medical and all other statutory benefits and entry permits, wherever necessary.
  - (e) Making arrangements in or around the site, as per the requirements of Kolkata Municipal Corporation or other local authority or the Engineer or his Representative, for preventing (i) spread of any infectious disease like smallpox, cholera, plague or malaria by taking effective actions for destruction of rats, mice, vermin, mosquitoes etc. and by maintaining healthy and sanitary condition, (ii) illegal storage and distribution of Drugs, Narcotics, Alcoholic liquor, Arms and Ammunitions, (iii) unlawful, riotous or disorderly conduct of the Contractor's or his Sub-Contractor's workmen, (iv) deployment of workmen of age less than 16 years.
- 4.18. Every direction or notice to be given to the Contractor shall be deemed to have been duly served on or received by the Contractor, if the same is posted or sent by hand to the address given in the tender or to the Contractor's Site Office or in case of Trustee's enlisted Contractor to the address as appearing in the trustee's Register or to the Registered Office of the Contractor. The time mentioned in these conditions for doing any act after direction or notice shall be reckoned from the time of such posting or dispatch.

- 4.19. The Contractor and his sub-contractor or their agents and men and any firm supplying plant, materials, and equipment shall not publish or caused to be published any photographs or description of the works without the prior authority of the Engineer in writing.
- 4.20. The Contractor shall, at the Trustees' cost to be decided by the Engineer, render all reasonable facilities and Co-operation as per direction of the Engineer or his representative to any other Contractor engaged by the Trustees and their workmen, to the Trustees' own staff and to the men of other Public Body on or near the site of work and in default, the contractor shall be liable to the trustees for any delay or expense incurred by reason of such default.
- 4.21. The work has to be carried out by the Contractor causing the minimum of hindrance for any maritime traffic or surface traffic.
- 4.22. All constructional plants, temporary works and materials when brought to the site by the contractor, shall be deemed to be the property of the Trustees who will have a lien on the same until the satisfactory completion of the work and shall only be removed from the site in part or in full with the written permission of the Engineer or his Representative.

## **5. COMMENCEMENT, EXECUTION AND COMPLETION OF WORK**

- 5.0. The contractor shall commence the work within 7 days of the receipt of Engineer's letter informing acceptance of the Contractor's tender / offer by the Trustees or within such preliminary time as mentioned by the contractor in the Form of Tender or the time accepted by the Trustees. The contractor shall then proceed with the work with due expedition and without delay, except as may be expressly sanctioned or ordered by the Engineer or his Representatives, time being deemed the essence of the contract on the part of the Contractor.
- 5.1. The Contractor shall provide and maintain a suitable office at or near the site, to which the Engineer's Representative may send communications and instructions for use of the Contractor.
- 5.2. Unless specified otherwise in the contract or prior permission of the Engineer has been taken, the contractor shall not execute the work beyond the working hours observed by the Engineer's Representative and on Sundays and Holidays observed in the trustees system, except in so far as it becomes essential on account of tidal work or for safety of the work. If the progress of the work lags behind schedule or the work has been endangered by any act or neglect on the part of the contractor, then the Engineer or his Representative shall order and the contractor at his own expense shall work by day and by night and on Sundays and Public Holidays. Any failure of the Engineer or his Representative to pass such an order shall not relieve the contractor from any of his obligations. The Engineer's decision in this regard shall be final, binding and conclusive.
- 5.3. Unless stipulated otherwise in the contract, all materials required for the work shall be procured and supplied by the contractor with the approval of the Engineer or his Representative and subject to subsequent testing as may be required by the Engineer or his Representative. The engineer shall exercise his sole discretion to accept any such materials.
- 5.4. Unless stipulated otherwise, in the contract, all materials, workmanship method of measurement shall be in accordance with the relevant Codes (Latest Revision) of the Bureau of Indian Standards and the written instructions of the Engineer or his Representative. Where no specific reference is available in the contract, the materials and workmanship shall be of the best of their respective kinds to the satisfaction of the Engineer.
- 5.5. Samples shall be prepared and submitted for approval of the Engineer or his Representative, whenever required to do so, all at the contractor's cost.
- 5.6. Unless stipulated otherwise in the contract, the cost of any test required by the Engineer or his representative in respect of materials and workmanship deployed on the work shall be borne by the contractor.
- 5.7. Regarding the supply of any materials by the Trustees to the contractor in accordance with the contract, the following conditions shall apply:
  - (a) The contractor shall, at his own expense, arrange for transporting the materials from the Trustees' Stores, watching, storing and keeping them in his safe custody, furnishing of statement of consumption thereof in the manner required by the Engineer or his representative, return of surplus and empty container to the Trustees' Stores as per the direction of the Engineer or his Representative.
  - (b) Being the custodian of the Trustees' materials, the contractor shall remain solely responsible for any such materials issued to him and for any loss or damage thereof for any reason other than "Excepted Risks", the contractor shall compensate the Trustees' in the manner decided by the Engineer and shall at no stage remove or cause to be removed any such material from the site without his permission.
  - (c) The Trustees' materials will generally be supplied in stages and in accordance with the rate of progress of work, but, except for grant of suitable extension of completion time of work as decided by the Engineer, the contractor shall not be entitled to any other compensation, monetary or otherwise, for any delay in the supply of Trustees' materials to him. The Contractor shall, however communicate his requirement of such materials to the Engineer from time to time.

- (d) Unless stipulated otherwise in the contract, the value of the Trustees' materials issued to the contractor shall be recovered from the Contractor's bills and / or any of his other dues. Progressively according to the consumption thereof on the work and / or in the manner decided by the Engineer or his Representative and at the rate / stipulated in the contract. These rates shall only be considered by the contractor in the preparation of his tender / offer and these will form the basis of escalation / variation, if in future the contractor is required to procure and provide any such material on the written order of the Engineer consequent on the Trustees' failure to effect timely supply thereof.
- (e) If the Engineer decides that due to the contractor's negligence, and of the Trustees' materials issued to the contractor has been – (i) lost or damaged, (ii) consumed in excess of requirement, and (iii) wasted by the contractor in excess of normal wastage, then the value thereof shall be recovered from the contractor's bills or from any of his other dues, after adding 19 ¼% extra over the higher one of the followings—
  - i. The issue rate of the materials at the Trustees' Stores, and
  - ii. The market price of the material on the date of issue as would be determined by the Engineer.

5.8. The Engineer or his Representative shall have the power to inspect any material and work at any time and to order at any time – (i) for removal from the site of any material which in his opinion is not in accordance with the contract or the instruction of the Engineer or his Representative, (ii) for the substitution of the proper and suitable materials, or (iii) the removal and proper re-execution of any work, which in respect of material and workmanship is not in accordance with the contract or the instructions of the Engineer.

The contractor shall comply with such order at his own expense- and within the time specified in the order. If the contractor fails to comply, the Engineer shall be at liberty to dispose of such materials and re-do any work in the manner convenient to the Trustees by engaging any outside agency at the risk and expense of the contractor and after giving him a written prior notice of 7 days.

5.9. No work shall be covered up and put out of view by the contractor without approval of the Engineer or his Representative and whenever required by him the contractor shall uncover any part or parts of the work or make openings in or through the same as may be directed by the Engineer or his Representative from time to time and shall reinstate or make good those part of works thus affected to the satisfaction of the Engineer, all at the cost of the contractor. The Trustees shall reimburse such cost as determined by the Engineer, if the initial covering up was with prior written order of the Engineer or his Representative.

- 5.10. On a written order of the Engineer or his Representative the contractor shall delay or suspend the progress of the work till such time the written order to resume the execution is received by him. During such suspension the contractor shall protect and secure the work to the satisfaction of the Engineer or his Representative. All extra expenses in giving effect to such order shall be considered by the Trustees, unless such suspension is
- i. Otherwise provide for in the contract, or
  - ii. Necessary by reason of some default on the part of the Contractor, or
  - iii. Necessary by reason of climatic conditions on the site, or
  - iv. Necessary for proper execution of the works or for the safety of the works or any part thereof.

The Engineer shall settle and determine such extra payment and / or Extension of completion time to be allowed to the contractor, as shall, in the opinion of the Engineer, be fair and reasonable.

If at any time before or after commencement of the work the Trustees do not require the whole of the work tendered for, the Engineer shall notify the same to the contractor in writing and the contractor shall stop further works in compliance of the same. The Contractor shall not be entitled to any claim for compensation for underived profit or for such premature stoppage of work or on account of curtailment of the originally intended work by reason of alteration made by the Engineer in the original specifications, drawings, designs and instruction.

5.11. When the whole of the work has been completed to the satisfaction of the Engineer and has passed any final test prescribed in the contract, the contractor shall, within 21 days of submission of his application to the Engineer be entitled to receive from him a certificate for completion of work in Form G.C.1 annexed hereto. If any part of the total work having been completed to the satisfaction of the Engineer, be takeover and / or used by the Trustees the Contractor shall on application be entitled to partial completion certificate in the Form of G.C.1 indicating the portion of the work covered by it, so that the Contractor's liability during maintenance period of the contract, if any, shall commence from the date mentioned in such certificate so far as the completed portion of the work is concerned.



## **6. TERMS OF PAYMENT:**

- 6.0. No Sum shall be considered as earned by or due to the Contractor in respect of the work till final and satisfactory completion thereof and until a certificate of final completion in Form G.C.2 has been given by the Engineer. On account payments, if any, made prior to issue of the certificate in Form G.C.2, shall all be treated as mere advances, which shall stand recoverable in full or in part, if the Engineer so decides in the context of Contractor's unfulfilled contract condition, if any.
- 6.1. All payments shall be made to the Contractor on the basis of measurement of actual work done, as recorded in the Trustees' measurement books and at accepted tendered or at agreed rates, as the case may be except as otherwise provided in the contract and when the Engineer decided any other rate for change in the scope of work or omission, if any, on the part of the Contractor.
- 6.2. For work of sanctioned tender value more than Rs. 50,000/- or having an initially stipulated completion period of 4 months or more, on account payments may be made at the discretion of the Engineer or his Representative at intervals deemed suitable and justified by him. Provided always that, subject to execution of work of substantial value in the context of the contract price, the interval of such on account payments shall be decided by the Engineer or his Representative, which shall ordinarily not be less than 1 month in between two payments for on account bill and / or advance.
- 6.3. Measurement for works done shall be progressively taken by the Engineer's Representative and entered in the Trustees' Measurement Book, at intervals deemed suitable and proper by him and / or the Engineer. The Contractor or his duly accredited Representative or Agent shall remain present at the time of such measurement and assist the Engineer's Representative in every manner required by him. After the measurements taken have been entered in the Measurement Book, the Contractor or his Agent shall sign the Measurement Book at the end of such Measurements over the Contractor's Rubber Stamp as a taken of acceptance of all such measurements, recorded above and prior to such signature. If the Contractor or his Agent fails to participate even other 3 days written notice from the Engineer's Representative the measurement shall be taken ex-part by the Engineer's representative and those shall be accepted by the Contractor.
- 6.4. Based on the quantum of work and the value thereof computed in the Measurement Book, the Contractor shall type out his bill in the proforma approved by the Engineer and submit the same to the Engineer's Representative in quadruplicate, duly signed by him or his accredited Agent over his Rubber Stamp. The Engineer or his Representative may, in his absolute discretion, allow advance payment against such bill to the extent of an amount not exceeding 75% of the "net payable" sum of the said bill, subject to adjustment thereof against the bill at the time of checking and auditing the bill at the Trustees end., The measurement Book will not be handed over to the Contractor; but he will obtain the abstracts of quantities, amount and recoveries to type out the bill.
- 6.5. At the discretion of the Engineer or his Representative and only in respect of accepted offers/ where estimated amount put to tender would be Rs. 2,00,000/- or more, advance payment may be made to the extent of 75% of the value of any material purchased and brought to the site by the Contractor. Provided always that—
  - i. The materials shall, in the opinion of the Engineer or his Representative, be of imperishable nature.
  - ii. The value of such materials shall be assessed by the Engineer or his Representative, at their own discretions,
  - iii. A formal agreement has been drawn up with the contractor, under which the Trustees secure a lien on the contractor's materials.
  - iv. The materials are safe-guarded by the contractor against losses, shortage and misuse due to the contractor postponing the execution of the work or otherwise,
  - v. In the event of shortage of such materials within the Trustees' protected areas in the Docks, the contractor shall submit an indemnity Bond in the proforma and manner acceptable to Trustee' whereby the contractor shall indemnify the Trustees' against all financial loss/ damage, on account of loss/ damage to such materials for whatever reasons.
  - vi. In the event of storage of such materials outside the Trustees' protected areas the Contractor shall submit to the Engineer an irrevocable Bank Guarantee favouring the Trustees and for the same sum as is being advance, in the proforma and manner acceptable to the Trustees. The Guarantee shall be of a Kolkata / Haldia Branch of any Nationalised Bank or a Scheduled Commercial bank, as the case may be, acceptable to the Trustees and shall remain valid till the anticipated period of consumption of such materials in the work. The Bank Guarantee must bear an undertaking by the issuing Bank guaranteeing automatic payment of the guaranteed sum to the Trustees by the Bank on the date of expiry of the validity of the Guarantee, unless with the prior written approval of the Engineer on behalf of the Trustees, the Bank has extended the validity of the Guarantee.
  - vii. The amount of advance shall be recoverable from the contractor's bills or any other dues, progressively with the consumption of the materials on the basis of quantity consumed. Consequent on full recovery of the advance the Indemnity Bond / Bank Guarantee, vide sub-clause (v) & (vi) above, shall be returned to the Contractor duly discharged by the Engineer on behalf of the Trustees.

- 6.6. No Certificate of the Engineer or his Representative shall protect the Contractor against or prevent the Trustees from obtaining repayment from the Contractor, in case the Engineer or his Representative should over certify for payment or the Trustees should over-pay the Contractor on any account.
- 6.7. No claim for interest shall be admissible to the Contractor at any stage and in respect of any money or balance or Bank Guarantee, which may be due to the Contractor from the Trustees, owing to dispute or otherwise or for any delay on the part of the Trustees in making interim or final payment or otherwise.

## **7. VARIATION AND ITS VALUATION:**

- 7.0. The Quantities set out in the Bill of Quantities of the tender shall be treated as estimated quantities of the work and shall never be deemed as actual or correct quantities of the works to be executed by the contractor in fulfillment of his obligation under the contract.
- 7.1. The Engineer shall have the power to order the Contractor in writing to make any variation of the Quantity, quantity or form of the works or any part thereof that may, in his opinion, be necessary and the Contractor upon receipt of such an order shall act as follows:
- a) Increase or decrease the quantity of any work included in the contract.
  - b) Omit any work included in the contract.
  - c) Change the Character or quality or kind of any work included in the contract.
  - d) Change the levels, lines, position and dimensions of any part of the work, and
  - e) Execute extra and additional work of any kind necessary for completion of the works.
- 7.2. No such variation shall in any way vitiate or invalidate the contract or be treated as revocation of the contract, but the value (if any) of all such variations evaluated in accordance with the Engineer's sole decision shall be taken into account and the contract price shall be varied accordingly.
- 7.3. Provided always that written order of the Engineer shall not be required for increase or decrease in the quantity of any work up to 15% where such increase or decrease is not the result of any variation order given under this clause but is the result of the quantities exceeding or being less than those stated in the bill of quantities. Provided also that verbal order of variation from the Engineer shall be complied with by the Contractor and the Engineer's subsequent written confirmation of such verbal order shall be deemed to be an order in writing within the meaning of this clause.
- 7.4. **a)** The Contractor shall not be entitled to any claim of extra or additional work unless they have been carried out under the written orders of the Engineer.
- b)** The Engineer shall solely determine the amount (if any) to be added to or deducted from the sum named in the tender in respect of any extra work done or work omitted by his order.
  - c)** All extra, additional or substituted work done or work omitted by order of the Engineer shall be valued on the basis of the rates and prices set out in the contract, if in the opinion of the Engineer, the same shall be applicable. If the contract does not contain any rates or prices directly applicable to the extra additional or substituted work, then the Engineer may decide the suitable rates on the basis of Schedule of Rates (including surcharge in force at the time of acceptance of tender), if any, adopted by the Trustees with due regard to the accepted contractual percentage, if any thereon. In all other cases the Engineer shall solely determine suitable rates in the manner deemed by him as fair and reasonable, and his decision shall be final, binding and conclusive.
  - d)** If the nature or amount of any omission or addition relative to the nature or amount of the whole of the contract work or to any part thereof shall be such that, in the opinion of the Engineer, the rate of prices contained in the contract for any item of the works or the rate as evaluated under sub-clauses (b) and (c) of this clause, is by reason of such omission or addition rendered unreasonable or in-applicable the Engineer shall fix such other rate or price as he deems proper and the Engineer's decision shall be final, binding and conclusive.

## **8. DELAY / EXTENSION OF COMPLETION TIME / LIQUIDATED DAMAGE / TERMINATION OF CONTRACT.**

- 8.0. Should the quantum of extra or additional work of any kind or delayed availability of the Trustees' materials to be supplied as per contract or exceptionally adverse climatic conditions and natural phenomenon or strikes, lock-outs, civil commotions or other special circumstances of any kind beyond the control of the Contractor cause delay in completing the work, the contractor shall apply to the Engineer in writing for suitable extension of completion time within 7 days from the date of occurrence of the reason and the Engineer shall thereupon consider the stated reasons in the manner deemed necessary and shall either reject the application or determine and allow in writing the extension period as he would deem proper for completion of the work, with or without the imposition of "Liquidated Damaged" Clause (No.8.3hereof) on the Contractor and his decision shall be binding on the contractor. If an extension of completion time is granted by the Engineer, the clause No.8.3 of the Liquidated damage shall apply from its date of expiry, if the work be not completed within the extended time, unless stated otherwise in the decision communication by the Engineer, as aforesaid.
- 8.1. a) If the Contractor fails to complete the work within the stipulated dates or such extension thereof as communicated by the Engineer in writing, the contractor shall pay as compensation (Liquidated Damage) to the Trustees and not as a penalty, ½ % (half percent) of the total value of work (contract price) as mentioned in the latter of acceptance of the tender/offer, for every week or part thereof the work remains unfinished. Provided always that the amount of such compensation shall not exceed 10% the said value of work.
- b) Without prejudice to any of their legal rights, the Trustees shall have the power to recover the said amount of compensation / damage in Sub-Clause (a) of this clause, from any money due or likely to become due to the contractor. The payment or deduction of such compensation / damage shall not relieve the Contractor from his obligation to complete the work or from any of his other obligations / liabilities under the contract and in case of the Contractor's failure and at the absolute discretion of the Engineer, the work may be ordered to be completed by some other agency at the risk and expense of the Contractor, after a minimum three days notice in writing has been given to the contractor by the Engineer or his Representative.
- 8.2. Without being liable for any compensation to the Contractor, the Trustees may, in their absolute discretion, terminate the contract due to occurrence of any of the following reasons and decision of the Trustees in this respect, as communicated by the Engineer shall be final and conclusive :
- (i) The Contractor has abandoned the contract.
  - (ii) In the opinion of the Engineer, either the performance of the Contractor is not satisfactory or the work is not getting completed within the agreed period on account of Contractor's lapses.
  - (iii) The Contractor has failed to commence the work or has without any lawful excuse under these conditions, has kept the work suspended despite receiving the Engineer's or his Representative's written notice to proceed with the work.
  - (iv) The Contractor has failed to remove materials from site after receiving from the Engineer or his Representative the written notice stating that the said materials or work are rejected by him.
  - (v) The Contractor is not executing the work in accordance with the contract or is persistently or flagrantly neglecting to carry out his obligations under the contract.
  - (vi) Any bribe, commission, gift or advantage is given, promised or offered by or on behalf of the contractor to any officer, servant or representative of the Trustees or to any person on his or their behalf in relation to the obtaining or to the execution of the contract.
  - (vii) The Contractor is adjudged insolvent or enters in to composition with his creditors or being a company goes in to liquidation either compulsorily or voluntarily.
- 8.3.1 Upon receipt of the letter of termination of work, which may be issued by the Engineer on behalf of the Trustees, the Contractor shall hand over all the Trustees' tools, plant and materials issued to him at the place to be ascertained from the Engineer, within 7 days of receipt of such letter.
- 8.3.2 In all such cases of Termination of work, the Trustees shall have the power to complete the Work through any other agency of the Contractor's risk and expense and the Contractor shall be debited any sum or sums that may be expended in completing the work beyond the amount that would have been due to the contractor, had he duly completed the whole of the work in accordance with the contract.
- 8.3.3 Upon termination of contract, the contractor shall be entitled to receive payment of only 90 % of the value of the work actually done or materials actually supplied by him and subject to recoveries as per contracts, provided the work done and materials conform to specifications at the time of taking over by the Trustees. The payment for work shall be based on measurements of actual work done and priced at approved contract rates or other rates, as decided by the Engineer. The payment for materials supplied shall be at the rates as decided by the Engineer, which shall in no case be more than market rates prevailing at the time of talking over by the Trustees. The Engineer's decision in all such case shall be final, binding and conclusive.
- 8.3.4 The Trustees shall have the power to retain all moneys due to the Contractor until the work is completed by other agency and the Contractor's Liabilities to the Trustees and known in all respect.

## **9. MAINTENANCE AND REFUND OF SECURITY DEPOSIT :**

- 9.0. On completion of execution of the work the contractor shall maintain the same for a period, as may be specified in the form of a Special Condition of the Contract, from the date mentioned in the initial Completion Certificate in the Form G.C.1. Any defect / fault, which may appear in the work during aforesaid maintenance period, arising, in the sole opinion of the Engineer or his Representative, from materials or workmanship not in accordance with the contract or the instruction of the Engineer or his Representative, shall, upon the written notice of the Engineer or his Representative, be amended and made good by the Contractor at his own cost within seven days of the date of such notice, to the satisfaction of the Engineer or his Representative, failing which the Engineer or his Representative shall have the defects amended and made good through other agency at the Contractor's risk and cost and all expenses, consequent thereon or incidental thereto, shall be recoverable from the Contractor in manner deemed suitable by the Engineer.
- 9.1. The Contract shall not be considered completed and the work shall not be treated as finally accepted by the Trustees, until a final Completion Certificate in Form G.C. 2 annexed hereto shall have been signed and issued by the Engineer to the contractor after all obligations under the Contract including that in the maintenance period, if any, have been fulfilled by the Contractor. Previous entry on the works or taking possession, working or using thereof by the trustees shall not relieve the Contractor of his obligations under the contract for full and final completion of the work.
- 9.2. On completion of the contract in the manner aforesaid, the Contractor may apply for the refund of his Security Deposit by submitting to the Engineer (i) The Treasury Receipts granted for the amount of Security held by the Trustees, and (ii) his "No further claim" Certificate in Form G.C.3 annexed hereto (in original), whereupon the Engineer shall issue Certificate in Form G.C.2 and within two months of the Engineer's recommendation, the Trustees shall refund the balance due against the Security Deposit to the Contractor, after making deduction therefrom in respect of any sum due to the Trustees from the Contractor.

## **10. INTERPRETATION OF CONTRACT DOCUMENTS , DISPUTES & ARBITRATION**

- 10.0. In all disputes, matters, claims, demands or questions arising out of or connected with the interpretation of the Contract including the meaning of Specifications and Instructions or as to the quality of workmanship or as to the materials used in the work or the execution of the work whether during the progress of the work or after the completion and whether before or after the determination, abandonment or breach of the contract the decision of the Engineer shall be final and binding on all parties to the contract and shall forthwith be given effect to by the Contractor.
- 10.1. If, the Contractor be dissatisfied with any such decision of the Engineer, he shall within 15 days after receiving notice of such decision require that the matter shall be referred to Chairman, who shall thereupon consider and give a decision.
- 10.2. If, however, the contractor be still dissatisfied with the decision of the Chairman, he shall, within 15 days after receiving notice of such decision required that within 60 days from his written notice, the Chairman shall refer the matter to an Arbitrator of the panel of Arbitrators to be maintained by the Trustees for the purpose and any such reference shall be deemed to be a submission to arbitration within the meaning of Indian Arbitration Act, 1940 or any statutory modification thereof.
- 10.3.1 If the Arbitrator so appointed is unable or unwilling to act or resigns his appointment or vacates his office due to any reason whatsoever, another person from panel shall be appointed as Sole Arbitrator and he shall proceed from the stage at which it was left by his predecessor.
- 10.3.2 The Arbitrator shall be deemed to have entered on reference on the date he issues notice to both the parties fixing the date of first hearing.
- 10.3.3 The time limit within which the Arbitrator shall submit his award shall normally be 4 months as provided in Indian Arbitration Act, 1940 or any amendment thereof. The Arbitrator may, if found necessary, enlarge the time for making and publishing the award, with the consent of the parties.
- 10.3.4 The Venue of the arbitration shall be Kolkata or as may be fixed by the Arbitrator in his sole discretion. Upon every or any such reference to cost of any incidental to the reference and award respectively shall be in discretion of the Arbitrator who may determine, the amount thereof or by whom and to whom and in what manner the same shall be borne and paid.
- 10.3.5 The Award of the Arbitrator shall be final and binding on all parties subject to the provisions of the Indian Arbitration Act, 1940 or any amendment thereof. The Arbitrator shall give a separate award in respect of each item of disputes and respective claim referred to him by each party and give reason for the award.
- 10.3.6 The Arbitrator shall consider the claims of all the parties to the contract within only the parameters of scope and conditions of the contract in question.

- 10.3.7 Save as otherwise provided in the contract the provisions of the Arbitration Act, 1940 and rules made there under, for the time being in force, shall apply to the arbitration proceedings under this Clause.
- 10.3. The Contractor shall not suspend or delay the work and proceed with the work with due diligence in accordance with Engineer's decisions. The Engineer also shall not withhold any payment, which, according to him, is due or payable to the Contractor, on the ground that certain disputes have cropped up and are likely to be referred to arbitration.
- 10.4. Provided always as follows:
- (a) Nothing of the provisions in paragraphs 8.3 to 8.3.7 hereinabove would apply in the case of contracts , where tendered amount appearing in the letter of acceptance of the tender / offer is less than Rs.40,00,000/-.
  - (b) The Contractor shall have to raise disputes or differences of any kind whatsoever in relation to the execution of the work to the Engineer within 30 days from the date of occurrence of the cause of dispute and before the preparation of the final bill, giving detailed justifications, in the context of contract conditions.
  - (c) Contractor's dispute, if any, arising only during the maintenance period stipulated in the contract, must be submitted to the Engineer, with detailed justifications in the context of contract Conditions, before the final completion of the work.

No dispute or difference on any matter whatsoever, pertaining to the contract can be raised by the contractor after the completion of the work.

- (d) Contractor's claim / dispute raised beyond the time limits prescribed in sub-clauses 8.5(b) and 8.5(c) hereinabove, shall not be entertained by the Engineer and / or by any Arbitrator, subsequently.
- (e) The Chairman / Trustees shall have the right to alter the panel of Arbitrators on their sole discretion, by adding the names of new Arbitrators and / or by deleting the names of existing Arbitrators, without any reference to the Contractor.

**THE BOARD OF TRUSTEES FOR THE PORT OF KOLKATA**

**FORM OF TENDER**

**CONTRACT NO.**.....

To,

.....

.....

.....

I/We ..... of

.....

having examined the site of works, inspected the Drawings and read the Specifications, General and Special Conditions of Contract and Conditions of Tender, hereby tender and undertake to execute and complete all the works required to be performed in accordance with the Specification, Bill of Quantities, General & Special Conditions of Contract and Drawings prepared by or on behalf of the Trustees and at the rates and prices set out in the annexed Bill of Quantities with ..... month/week from the date of the order to commence the work and in the event of our Tender being accepted in full or in part, I/We also undertake to enter into a Contract Agreement in the Form hereto annexed with such alterations or additions thereto which may be necessary to give effect the acceptance of the Tender and incorporating such Specification, Bill of Quantities, Drawings and Special & General Conditions of Contract and I/We hereby agree that until such Contract Agreement is executed the said Specifications, Bill of Quantities, Conditions of Contract and the Tender, together with the acceptance thereof in writing by or on behalf of the Trustees shall be the Contract.

**THE TOTAL AMOUNT OF TENDER Rs** .....

(Repeat in words).....

.....

\*I/We require ..... days/months preliminary time to arrange and procure the materials required by the work from date of acceptance of the Tender before I/We could commence the Work.

(\* This should be scored out in the case of labour contracts)

I/We have deposited with the Trustees' Financial Advisor & Chief Accounts Officer / Manager (Finance), Haldia Dock Complex vide Receipt No ..... of ..... as Earnest Money.

I/We agree that period for which the Tender shall remain open for acceptance shall not be less than four months.

Signature of the Tenderer

Witness:

(Seal of the Tenderer)

Signature .....

Name of the Tenderer .....

Name .....

(In Block Letters)

(In Block Letters)

Address .....

Dated .....

.....

Address .....

Occupation .....

.....

KOPT

## THE BOARD OF TRUSTEES FOR THE PORT OF KOLKATA

### FORM OF AGREEMENT

THIS AGREEMENT made this .....day of.....200.....between the Board of Trustees for the Port of Kolkata, a body corporate constituted by the Major Port Trusts Act, 1963 (hereinafter called “Trustees” which expression shall unless excluded by or repugnant to the context be deemed to include their successors in office) of the one part and .....(hereinafter called “the Contractor”, which expression shall unless excluded by or repugnant to the context be deemed to include its heirs, executors, administrators, representatives and assignees or successors in office) of the other part.

WHEREAS the Trustees are desirous that certain works should be executed / constructed , viz. ....and have accepted a Tender / Offer by the Contractor for the execution and maintenance of such work NOW THIS AGREEMENT WITNESSETH as follows :

1. In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in General Conditions of Contract hereinafter referred to.
2. The following documents shall be deemed to form and be read and construed as part of this Agreement, viz.
  - (a) The said Tender / Offer & the acceptance of the Tender / Offer
  - (b) The General Conditions of Contract
  - (c) The Special Conditions of Contract
  - (d) The Conditions of Tender
  - (e) The Technical Specifications
  - (f) The Schedule of Rates
  - (g) The Terms of Payment
  - (h) All correspondence by which, the contract is added, amended, varied or modified in any way by mutual consent.



3. In consideration of the payments to be made by the Trustees to the Contractor as hereinafter mentioned, the Contractor hereby covenant with the Trustees to execute and maintain the work in conformity in all respects with the provisions of the contract.
4. The Trustees hereby covenants to pay to the Contractor, in consideration of such execution and maintenance of the Work, the Contract Prices at the times and in the manner prescribed by the Contract.

IN WITNESS whereof of the parties hereto have caused their respective Common Seals to be hereunto affixed  
(or have hereunto set their respective hands and seals) the day and year first above written.

The Seal of.....  
.....

Was hereunto affixed in the presence of:

Name .....

Address .....

.....

**Or**

**SIGNED, SEALED AND DELIVERED**

by the said .....

*In the presence of:*

Name .....

Address: .....

.....

*The Common Seal of the Trustees was hereunto affixed in the presence of:*

Name.....

Address: .....

## KOLKATA PORT TRUST

<b>FORM G.C.1</b>
-------------------

Contract .....

Address .....

.....

Date of Completion .....

Dear Sir/s,

This is to certify that the following works viz.

Name of the Work.....

Estimate Number E.E.O .....dt .....

C.E.O .....dt .....

Work Order Number .....

Allocation .....

Contract Number .....

Which was carried out by you is in the opinion of the undersigned completing in every respect on the ..... Day of .....20..... in accordance with clause 62 of the General Conditions of Contract and under the provisions of the Contract for a period of ..... Days /weeks / months / years.

From the ..... day of ..... 20 .....

of the ..... day of ..... 20 .....

Signature (.....)

(Engineer / Engineer's Representative)

Name.....

Designation.....

Office Seal

c.c. to The Deputy Chief Engineer ( )

The Deputy Manager ( )

Financial Adviser & Chief Accounts Officer/

Manager (Finance), Haldia Dock Complex.

## KOLKATA PORT TRUST

<b>FORM G.C.2</b>
-------------------

The Financial Adviser & Chief Accounts Officer.

The Manager (finance), Haldia Dock Complex.

### CERTIFICATE OF FINAL COMPLETION

This is to certify that the following works viz.

Name of Work .....

Estimate No. E.E.O. No. .... dt .....

C.E.O. No .....dt .....

Work Order No .....dt .....

Contract No .....

Resoln. No & Meeting No .....

Allocation .....

Which was carried out by Shri / Messrs.....is now complete in every respect in accordance with the terms of the Contract and that all the obligations under Contract have been fulfilled by the Contractor.

Signature (.....)  
(Engineer / Engineer's Representative)

Name.....

Designation.....

Office Seal

## KOLKATA PORT TRUST

<b>FORM G.C.3</b>
-------------------

(‘No Claim’ Certificate From Contractor)

The Engineer  
Kolkata Port Trust  
Kolkata / Haldia

(Attn .....)

(Address, the Trustees’ Official, mentioned in  
the work Order and under whom the Contract  
was executed)

Dear Sir,

I/We do hereby declare that I/We have received full and final payment from Kolkata Port Trust for the execution of the following work, viz.

Name of Work .....

Work Order No ..... dt .....

Contract No .....dt.....

Agreement No .....dt.....and I/We have no  
further claim against Kolkata Port Trust in respect of the above mentioned job.

Yours faithfully,

(Signature of Contractor)

Date .....

Name of Contractor .....

Address .....

.....

(Official Seal of the Contractor)

**Draft Proforma of Bank Guarantee (Performance Bond) in lieu of cash Security Deposit, to be issued by the Kolkata/Haldia, as the case may be, of any nationalized Bank of India on Non-Judicial Stamp Paper worth Rs.50/- or as decided by the Engineer / Legal Adviser of the Trustees.**

To

The Board of Trustees  
for the Port of Kolkata.

BANK GUARANTEE NO.....DATE.....

Name of issuing Bank.....

Name of Branch.....

Address.....

In consideration of the Board of Trustees of the Port Kolkata, a body corporate - duly constituted under the Major port Trust Act, 1963 ( Act 38 of 1963), having agreed to exempt Shri / Messrs ..... a proprietary / Partnership / Limited / Registered Company, having its Registered Office at ..... (hereinafter referred to as "The Contractor") from cash payment of Security Deposit / Payment of Security Deposit through deduction from the Contractors' bills under the terms and conditions of a contract made between the Trustees and the Contractor for ..... (write the name of the work as per Work Order) in terms of the Work order No ..... dated.....(hereinafter referred to as "the said contract"), for the due fulfillment by the contractor of all the terms and conditions contained in the said contract, on submission of a bank Guarantee for Rs ..... (Rupees ..... ) we,.....Branch, Kolkata...../Haldia, do on the advise of the contractor, hereby undertake to indemnify and keep indemnified the Trustees to the extent of the said sum of Rs ..... (Rupees ..... ) We.....Branch,Kolkata ...../Haldia, further agree that if a written demand is made by the Trustees through any of its officials for honoring the Bank Guarantee constituted by these presents, We,..... Branch, Kolkata ..... /Haldia shall have no right to decline to cash the same for any reason whatsoever and shall cash the same and pay the sum so demanded to the Trustees within a week from the date of such demand by an A/c. Payee Banker's Cheque drawn in favour of "Kolkata Port Trust", without any demur. Even if there be any dispute between the contractor and the Trustees, this would be no ground for us,.....(Name of Bank), ..... Branch, Kolkata...../Haldia to decline to honour the Bank Guarantee in the manner aforesaid. The very fact that We, .....Branch,Kolkata ..... /Haldia, decline or fail or neglect to honour the Bank Guaranteed in the manner aforesaid shall constitute sufficient reason for the Trustees to enforce the Bank Guarantee unconditionally without any reference, whatsoever, to the contractor.

2. We,.....Branch,Kolkata.....  
...../Haldia, further agree that a mere demand by the Trustees at any time and in the manner aforesaid, is sufficient for us, ..... Branch, Kolkata ..... / Haldia, to pay the amount covered by this Bank Guarantee in full and in the manner aforesaid and within the time aforesaid without reference to the contractor and no protest by the contractor, made either directly or indirectly or through Court , can be valid ground for us, .....Branch,Kolkata ..... /Haldia, to decline or fail or neglect to make payment to the Trustees in, the manner and within the time aforesaid.

3. We, ..... Branch, Kolkata ..... /Haldia, further agree that the Bank Guaranteed herein contained shall remain in full force and effect, during the period that is taken for the due performance of the said contract by the contractor and that is shall continue to be enforceable till all the dues of the Trustees under and/or by virtue of the terms and conditions of the said contract have been fully paid and its claim satisfied and/or discharged in full and/or till the Trustees certify that the terms and conditions of the said contract have been fully and properly observed/fulfilled by the contractor and accordingly, the Trustees have discharged the Bank Guarantee, subject however, that this guarantee shall remain valid up to and inclusive of .....day of .....19.....and subject all so that the provision that the Trustees shall have no right to demand payment against this guarantee after the expiry of 6(six) calendar months from the expiry of the aforesaid validity period up to ..... Or any extension thereof made by us, .....Branch, Kolkata ...../Haldia, in further extending the said validity period of this Bank Guarantee on Non-Judicial Stamp Paper of appropriate value, as required / determined by the Trustees, only on a written request by the Trustees to the contractor for such extension of validity of this Bank Guarantee.

4. We, ..... Branch, Kolkata ..... /Haldia, further agree that, without our consent and without affecting in any manner our obligations hereunder, the Trustees shall have the fullest liberty to vary from time to time any of the terms and conditions of the said contract or to extend the time for full performance of the said contract including fulfilling all obligations under the said contract by the contractor or to postpone for any time or from time to time any of the powers exercisable by the Trustees against the contractor and to forebear or enforce any of terms and conditions relating to the said contract and We, ..... Branch, Kolkata ...../Haldia, shall not be relieved from our liability by reason of any such variation or extension being granted to the contractor or for any fore-bearance, act or commission on the part of the Trustees or any indulgence by the Trustees to the contractor or by any such matter or thing of whatsoever nature, which under the law relating to sureties would, but for this provision, have effect of so relieving us, .....Branch, Kolkata...../Haldia.

5. We ..... Branch, Kolkata ...../Haldia, lastly undertake not to revoke this Bank Guarantee during its currency except with the previous consent of the Trustees in writing.

SIGNATURE.....

NAME.....

DESIGNATION.....

(Duly constituted attorney for and on behalf of)

BANK.....

BRANCH.....

Kolkata...../Haldia.

**(OFFICIAL SEAL OF THE BANK)**

### **ADDENDUM**

**Modification of clause no.3.4 of GCC as sanctioned vide Reso. No.210 by the Board of Trustees for the Port of Kolkata in the 13<sup>th</sup> Meeting held on 26.02.2013.**

---

- i. Earnest Money :** Earnest money deposit @ 2% of the estimated cost will be applicable for works / service / O&M contract only and not for procurement contract for which existing system as mentioned in the GCC should be followed.
- ii. There will be no minimum ceiling of Earnest Money** which will be @ 2% of estimated cost of projects upto Rs.10 crore. EMD of project estimated above Rs.10 crore will be Rs.20 lakh + 1% of estimated cost by which it exceeds Rs.10 crore.
- iii. Upto Rs.10 lakh Earnest Money** will be accepted by Banker's cheque / Demand Draft / Pay order. EMD beyond Rs.10 lakh may be accepted in the form of Bank Guarantee issued by an Indian Nationalized / Scheduled Bank.
- iv. Refund of Earnest money** to other than L-1 bidders will be made within 2 month of opening of bid or on finalization / acceptance of tender, whichever is earlier.

-----