

KOLKATA PORT TRUST
HALDIA DOCK COMPLEX

Tender No. SDM(P&E)/T/65/2020-2021
E-Tender No. 2020_KoPT_561722_1

ADDENDUM - I

CORRECTIONS / ADDITIONS / DELETIONS, ETC.

[Total Number of Pages : 1]

NOTE :

1. This "Addendum-I" should be read in conjunction with Bidding Document (including Notice Inviting e-Tender).
2. Consequential changes, arising out of this Addendum-I, will be deemed to have been effected, even if the same were not incorporated specifically in the Bidding Document.
3. All other terms and conditions of the Bidding Document (including Notice Inviting e-Tender) will remain unchanged.

Addendum -I

Tender No. SDM(P&E)/T/65/2020-2021

E-Tender No. 2020_KoPT_561722_1

Sl. No.	Page No.	Clause No.	As specified in the Bidding Document	To be deleted & read as / Remarks
1.	6	SOT 3.10	i) Starting date & time of submission of e-Tender at https://eprocure.gov.in/eprocure/app 16.06.2020 from 11:00 Hrs. (IST).	i) Starting date & time of submission of e-Tender at https://eprocure.gov.in/eprocure/app 19.06.2020 from 11:00 Hrs. (IST).
2.	6	SOT 3.10	ii) Closing date & time of submission of e-Tender at https://eprocure.gov.in/eprocure/app 23.06.2020 up to 15:00 Hrs. (IST).	ii) Closing date & time of submission of e-Tender at https://eprocure.gov.in/eprocure/app 30.06.2020 up to 15:00 Hrs. (IST).
3.	6	SOT 3.10	iii) Date & time of opening of Part-I (Techno-commercial Bid) 24.06.2020 up to 15:30 Hrs. (IST) onwards.	iii) Date & time of opening of Part-I (Techno-commercial Bid) 01.07.2020 up to 15:30 Hrs. (IST) onwards.
4.	91	8.0	Make- Battery - HBL/EXIDE/AMARON/ AMCO	Make- Battery / Battery charger - HBL/EXIDE/AMARON/ AMCO/KIRLOSKAR /HITACHI-HIREL

HALDIA DOCK COMPLEX

KOLKATA PORT TRUST

QUERIES OF DIFFERENT FIRMS IN CONNECTION WITH THE PRE-BID MEETING HELD ON 10.06.2020

for

“Supply, Installation, Testing and Commissioning of 33 kV Over Head Line & Under Ground Cable from Intake Substation to GC Berth Substation for strengthening of power supply arrangement of RMQC-3 of HDC, KoPT.”.

Tender No. SDM(P&E)/T/65/2020-2021)

E-Tender No. 2020_KoPT_561722_1

Sl. No.	Reference	Queries of the firms	HDC, KoPT's Clarifications
1.	BOQ item No.2 & 3	CT-PT:- To provide VA burden for metering and protection cores of the 33kV CT and also to provide the knee point voltage for the Class PS Core.	Please refer Page No.35, clause No.3.3 of section VI.
2.		To provide battery charger make.	Please see addendum.
3.		Regarding submission of Hard copy of NSIC certificate for exemption of EMD.	Please refer Page No.5, clause No.3.4
4.	Page No.02 , Clause No.2.1.2/2.1.3	To consider similar work as 11kV and above sub-station as 11/22/33kV since all voltage level are comes under HT.	Tender condition prevails.
5.	Page No. 06,Clause No. 3.10(ii)	To consider closing date on 10.07.2020	Please see addendum.