

**Minutes of the Pre-bid meeting held on 18.09.2020 of the Tender for the work “Electrical Installation work related to development of Reefer Park behind Lybian Tea Ware House”.**

Notice Inviting Tender No.: SMP/KDS/Mech/SE-II/ADV/561 dated 08.09.2020

**Officials of SMP Present:-**

- 1) Sri S. Sarkar - Supdt. Engineer(Elect)-II
- 2) Sri A. Sanyal - Executive Engineer(Elect)-I

**Representatives of Prospective Bidders Present :**

- 1) Sri D. Singh - M/s MARS Complete Power Solutions
- 2) Sri A.Roy - M/s Konstelec Engineers Pvt Ltd.

A detail discussion took place with the prospective bidders and the followings are mentioned:-

- 1) The short circuit rating of the VCB panel mentioned in BOQ SI No 7 is to be read as 25KA instead of 40 KA.
- 2) In BOQ SI No 15, for the LT panel the rating of incomer ACBs and Bus Coupler ACB is to be read as 1250 A instead of 1000A and that of outgoing ACBs are to be read as 800A instead of 630A
- 3) In BOQ SI No 17 , the rating of the incomer MCCBs are to be read as 250A instead of 400A and that of outgoing MCCBs are to be read as 100 A instead of 150A.
- 4) In BOQ SI No 19 , the rating of the outgoing MCCBs are to be read as 100 A instead of 150A.
- 5) In BOQ SI No 21 , the rating of the incomer MCCB is to be read as 100 A instead of 150A
- 6) The detuned reactance of APFC panel is to be considered as 7%.

All other terms and conditions of the Tender remain unchanged. This minute forms a part of the Tender Documents.

Chief Mechanical Engineer