

CORRIGENDUM-I**Ref. Tender Notice No.: SE/ KP/ 21-22/011/D/22 Dt 28.11.2021**

Name of Work :- E-Tender for Supplying and installation of High Capacity RO water purifier at different locations (both inside and outside) of K.P. Docks & N.S. Dock of SMPK.

Subject:- Please read modification of Technical specifications at page no 19 Sl.no.12 Of Special Condition of Contract

Sl. No	Technical specifications	
	Description	RO 50LPH Inbuild Storage Model
	Dimension	525 X 425 X 1450 (approx)
	Reservoir Capacity	50 LPH
	Production Capacity	50 LPH (0.830 LPM)
	RO Membrane (Thin Flim Composite)	80 GPD X 4 nos (0 .0001 Microns Pore Size)
	Maximum recommended Output	300 Liters/ Day X 4
	Filtration Stage / Cartridge	Particulate Filter →Membrane Life Enhancer Filter → Sediment filter →Pre Carbon Filter →RO Membrane Filter → Post Carbon Filter →Storage Tank
	Total No. of Faucets	2 or More
	Body Material	Powder Coated
	% of Recovery of Purified Water	20 and 25%
	% of Recovery in TDS	90 % (Approx)
	service related escalation request you to process the following process available in our	Mandotary
	Service Center And Service help Line Nos	Mandotary
	Certificate (Firm / OEM should have)	GC - Mark Certificate, ISO 14001 : 2015 , IS 14724:199, ISO/IEC 17025:2017 (NABL). In house NABL water testing certified laboratory of OEM, BIS certificate.
	Recommended Total Dissolved Solids in Input Water	2000 ppm (Max)
	Note : Input water 10ft pipe line work is under bidder own cost and output wastage water pipe line and electrical power point provided by the Organization itself.	

Note : Input water 10ft pipe line work is under bidder own cost and output wastage water pipe line and electrical power point provided by the Organization itself.

Instead of Specification at page no19 and Sl no 12 mark A sl. No 1 to 7 read the current uploaded
CORRIGENDUM-I

Mark A

Sl.no	Parameter	Eco smart RO water purifier
1	Purification flow rate	50 Liters/H
2	Recovery of pure water	Upto 70%
3	Rejection of Salts(TDS)	Upto 95%
4	Max. inlet water TRS	1500 PPM
5	Water Saver cartridge	Nova cartridge
6	Body	SSD make
7	Maximum recommended output	300 liters/Day

The bidders to ensure that for supply of RO water purifier that must have relevant ISO certificates or IS Codes or other equivalent certificates pertaining to quality control where they exist. Bidders must have attached documentary evidence that the consignment they intend to supply meets such standards.

All other terms & conditions and Clauses will remain same as per original

NIT No. **SE/ KP/ 21-22/011/D/22 Dt 28.10.2021**

Superintending Engineer
K.P.Docks.

Copy to the **Chief Engineer**, for favor of information please.

Copy to the Superintending Engineer, K.P.Docks / N.S.Dock / South / Contract / Development /Railways / River Training / Rabindra Setu / Env./ O.S. – I for information. This letter may be displayed along with the Tender Notice already sent to you.

Copy to the Director, P&R [**Attention: Incharge, Computer Centre**] For information please.

The tender documents are being sent to your intra-mail of **hocc@kolkataporttrust.gov.in** for insertion in Kolkata Port Trust website, www.kolkataporttrust.gov.in and **Railtel**. [http:// kopt.enivida.in](http://kopt.enivida.in) Down loading of tender documents shall be blocked just at 12 noon on **22.11.2021**