

Minutes of the Pre-bid meeting held on 30.11.2020 of the Tender for the work “**Electrical Installation work in relation to Improvement of Illumination of Sheds at both KPD-I &KPD-II, SMP Kolkata**”.

Notice Inviting Tender No.: **SMP/KDS/Mech/SE-I/ADV/594 dated 19.11.2021**

Officials of SMP Present:-

- 1) Sri R.Kumar - Supdt. Engineer(Elect)-I
- 2) Sri A. Sanyal - Executive Engineer(Elect)-I

Representatives of Prospective Bidders Present

- 1) Sri Sanjit Kr Das - M/s H.S.Enterprise
- 2) Smt Suparna Das & Sri S.Pande - M/s Bajaj Electricals Ltd

A detail discussion took place with the prospective bidders and the followings are mentioned:-

- 1) For High Bay/Mid bay and Flood light luminaries, system efficacy shall be greater than 130 Lumen/Watt @ minimum 350mA drive current
- 2) For the make of SMD type Chip the name of Bridgelux is included along with other make.
- 3) The Colour Rendering Index for R1 to R15 should be greater than or equal to 70 except R9.
- 4) The housing protection shall be IP 65 or above and IK 06 or above.

All other terms and conditions of the Tender remain unchanged. This minute forms a part of the Tender Documents.

Chief Mechanical Engineer